

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Tillamook
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP:-C Month/Year: 04/2024

Day	12:00 AM	4:00 AM	8:00 AM	NOON	4PM	8:00 PM	Highest Reading of
1	0.014	0.014	0.014	0.014	0.016	0.014	0.016
2	0.016	0.014	0.016	0.016	0.014	0.014	0.016
3	0.016	0.014	0.014	0.016	0.016	0.014	0.016
4	0.014	0.016	0.014	0.014	0.014	0.014	0.016
5	0.016	0.016	0.014	0.016	0.014	0.014	0.016
6	0.014	0.016	0.016	0.014	0.014	0.016	0.016
7	0.016	0.014	0.014	0.016	0.016	0.016	0.016
8	0.014	0.018	0.014	0.016	0.016	0.014	0.018
9	0.014	0.016	0.014	0.016	0.014	0.016	0.016
10	0.014	0.014	0.014	0.016	0.014	0.016	0.016
11	0.014	0.014	0.016	0.016	0.016	0.014	0.016
12	0.016	0.016	0.016	0.014	0.014	0.014	0.016
13	0.014	0.014	0.016	0.014	0.014	0.016	0.016
14	0.014	0.016	0.016	0.016	0.018	0.016	0.018
15	0.018	0.016	0.014	0.014	0.014	0.016	0.018
16	0.016	0.014	0.016	0.014	0.014	0.016	0.016
17	0.014	0.016	0.016	0.014	0.016	0.016	0.016
18	0.016	0.014	0.014	0.014	0.014	0.016	0.016
19	0.014	0.018	0.014	0.014	0.016	0.014	0.018
20	0.018	0.016	0.016	0.016	0.014	0.016	0.018
21	0.016	0.016	0.014	0.016	0.014	0.014	0.016
22	0.016	0.016	0.016	0.016	0.014	0.018	0.018
23	0.014	0.016	0.014	0.016	0.016	0.016	0.016
24	0.014	0.016	0.016	0.014	0.016	0.016	0.016
25	0.016	0.016	0.018	0.014	0.016	0.014	0.018
26	0.016	0.016	0.016	0.014	0.016	0.018	0.018
27	Offline	Offline	Offline	Offline	Offline	Offline	Offline
28	Offline	Offline	Offline	Offline	Offline	Offline	Offline
29	Offline	Offline	Offline	Offline	Offline	Offline	Offline
30	Offline	Offline	Offline	Offline	Offline	Offline	Offline

95% of daily turbidity readings < 1 NTU? <input checked="" type="checkbox"/> Yes/No	All daily	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes/No	All Cl2 residual at entry point 0.2 mg/l? <input checked="" type="checkbox"/> Yes/No
turbidity readings < 5 NTU? <input checked="" type="checkbox"/> Yes/No			

Notes:	Printed Name: Leonard Whiteman T-09364
	Signature <i>Leonard Whiteman</i>
	Phone # 503-965-6636

