


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Tillamook
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-:C Month/Year: 06/2024							
Day	12:00 AM	4:00 AM	8:00 AM	NOON	4PM	8:00 PM	Highest Reading of
1	Offline	Offline	Offline	Offline	Offline	Offline	Offline
2	Offline	Offline	Offline	Offline	Offline	Offline	Offline
3	Offline	Offline	Offline	Offline	Offline	Offline	Offline
4	Offline	Offline	Offline	Offline	Offline	Offline	Offline
5	0.014	0.016	0.016	0.016	0.016	0.016	0.016
6	0.016	0.018	0.016	0.016	0.016	0.016	0.018
7	0.016	0.016	0.018	0.016	0.014	0.016	0.018
8	0.014	0.016	0.014	0.016	0.014	0.016	0.016
9	0.016	0.016	0.014	0.014	0.016	0.016	0.016
10	0.016	0.018	0.014	0.016	0.014	0.014	0.018
11	0.016	0.016	0.018	0.014	0.014	0.014	0.018
12	0.016	0.016	0.016	0.023	0.019	0.018	0.023
13	0.018	0.019	0.019	0.019	0.019	0.018	0.019
14	0.019	0.021	0.018	0.018	0.018	0.018	0.021
15	0.019	0.019	0.018	0.018	0.018	0.016	0.019
16	0.018	0.019	0.014	0.014	0.016	0.014	0.019
17	0.016	0.016	0.014	0.014	0.014	0.014	0.016
18	0.016	0.016	0.016	0.016	0.014	0.016	0.016
19	0.016	0.016	0.014	0.016	0.014	0.019	0.019
20	0.016	0.018	0.016	0.016	0.016	0.018	0.018
21	0.016	0.016	0.016	0.016	0.018	0.016	0.018
22	0.014	0.016	0.016	0.019	0.016	0.019	0.019
23	0.016	0.016	0.016	0.016	0.016	0.018	0.018
24	0.018	0.018	0.016	0.014	0.016	0.014	0.018
25	0.016	0.016	0.016	0.016	0.016	0.016	0.016
26	0.014	0.014	0.014	0.014	0.018	0.016	0.018
27	0.016	0.016	0.016	0.016	0.016	0.016	0.016
28	0.016	0.018	0.016	0.014	0.016	0.018	0.018
29	0.016	0.016	0.016	0.016	0.016	0.016	0.016
30	0.014	0.016	0.014	0.016	0.016	0.014	0.016
95% of daily turbidity readings < 1 NTU? <input checked="" type="checkbox"/> Yes/ <input type="checkbox"/> No				All daily CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes/ <input type="checkbox"/> No		All Cl2 residual at entry point 0.2 mg/l? <input checked="" type="checkbox"/> Yes/ <input type="checkbox"/> No	
Notes:				Printed Name: Leonard Whiteman T-09364			
				Signature 			
				Phone # 503-965-6636			

OHA - Drinking Water Program - Surface Quality Data Form

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-:C Month/Year06/2024								
Day	Minimum CL2 residual at 1st User C3	Contact Time Minutes	Actual CT	Temp deg C	pH	Required CT Use Tables	CT Met? Yes / No	Peak Hourly Demand Flow GPM
	[ppm or mg/l]							
1	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
2	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
3	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
4	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
5	1.50	36.0	54.00	12.79	6.89	16.0	YES	700
6	1.63	36.0	58.68	13.23	6.92	16.0	YES	700
7	1.69	36.0	60.84	12.53	6.90	16.7	YES	700
8	1.67	36.0	60.12	13.52	6.96	16.0	YES	700
9	1.71	36.0	61.56	12.52	6.95	17.1	YES	700
10	1.61	36.0	57.96	13.60	6.97	15.9	YES	700
11	1.61	36.0	57.96	13.16	6.95	16.2	YES	700
12	1.66	36.0	59.76	12.74	7.21	18.5	YES	700
13	1.68	36.0	60.48	12.48	7.46	20.8	YES	700
14	1.70	36.0	61.20	12.34	7.21	19.3	YES	700
15	1.61	36.0	57.96	12.97	7.00	16.7	YES	700
16	1.49	36.0	53.64	12.30	6.94	17.2	YES	700
17	1.55	36.0	55.80	12.67	6.97	16.8	YES	700
18	1.62	36.0	58.32	13.01	7.01	16.8	YES	700
19	1.53	36.0	55.08	13.14	6.95	16.1	YES	700
20	1.59	36.0	57.24	13.46	6.92	15.7	YES	700
21	1.60	36.0	57.60	14.00	6.94	15.2	YES	700
22	1.63	36.0	58.68	13.46	6.95	15.9	YES	700
23	1.56	36.0	56.16	13.79	6.93	15.3	YES	700
24	1.55	36.0	55.80	13.92	6.95	15.3	YES	700
25	1.53	36.0	55.08	13.64	6.90	15.3	YES	700
26	1.57	36.0	56.52	13.62	6.92	15.5	YES	700
27	1.55	36.0	55.80	13.84	6.94	15.3	YES	700
28	1.43	36.0	51.48	13.74	6.87	14.8	YES	700
29	1.48	36.0	53.28	14.71	6.88	14.0	YES	700
30	1.52	36.0	54.72	14.31	6.84	14.3	YES	700