


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Tillamook
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP:-C Month/Year: 08/2024

Day	12:00 AM	4:00 AM	8:00 AM	NOON	4PM	8:00 PM	Highest Reading of
1	0.018	0.016	0.016	0.016	0.018	0.014	0.018
2	0.021	0.021	0.014	0.014	0.014	0.014	0.021
3	0.014	0.016	0.018	0.014	0.016	0.016	0.018
4	0.014	0.014	0.018	0.014	0.016	0.016	0.018
5	0.018	0.021	0.014	0.018	0.014	0.016	0.021
6	0.016	0.019	0.014	0.014	0.014	0.016	0.019
7	0.014	0.019	0.014	0.018	0.014	0.014	0.019
8	0.016	0.021	0.014	0.016	0.018	0.019	0.019
9	0.018	0.018	0.014	0.016	0.016	0.016	0.018
10	0.021	0.014	0.014	0.014	0.016	0.014	0.021
11	0.016	0.016	0.014	0.016	0.016	0.014	0.016
12	0.256	0.021	0.014	0.019	0.018	0.016	0.256
13	0.018	0.014	0.016	0.025	0.016	0.014	0.018
14	0.014	0.021	0.014	0.018	0.021	0.016	0.021
15	0.018	0.021	0.016	0.019	0.019	0.014	0.021
16	0.016	0.018	0.016	0.014	0.018	0.016	0.018
17	0.016	0.018	0.014	0.016	0.016	0.016	0.018
18	0.025	0.018	0.014	0.018	0.014	0.016	0.025
19	0.016	0.018	0.016	0.014	0.016	0.019	0.019
20	0.016	0.016	0.016	0.014	0.014	0.016	0.016
21	Offline	Offline	Offline	Offline	Offline	Offline	Offline
22	0.030	0.030	0.032	0.014	0.018	0.016	0.032
23	0.016	0.016	0.014	0.016	0.016	0.014	0.016
24	Offline	Offline	Offline	Offline	Offline	Offline	Offline
25	Offline	Offline	Offline	Offline	Offline	Offline	Offline
26	Offline	Offline	Offline	Offline	Offline	Offline	Offline
27	0.018	0.018	0.021	0.014	0.014	0.014	0.021
28	0.016	0.016	0.016	0.014	0.016	0.016	0.016
29	0.014	0.014	0.014	0.016	0.018	0.021	0.021
30	0.021	0.019	0.021	0.019	0.019	0.016	0.021
31	0.021	0.025	0.018	0.018	0.018	0.016	0.025

95% of daily turbidity readings < 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	All daily	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
turbidity readings < 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No			

Notes:	Printed Name: Leonard Whiteman T-09364
	Signature 
	Phone # 503-965-6636

OHA - Drinking Water Program - Surface Quality Data Form

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-:C Month/Year08/2024								
Day	Minimum CL2 residual at 1st User C3 [ppm or mg/l]	Contact Time Minutes	Actual CT	Temp deg C	pH	Required CT Use Tables	CT Met? Yes / No	Peak Hourly Demand Flow GPM
1	1.37	36.0	49.32	16.28	6.92	12.7	YES	700
2	1.50	36.0	54.00	16.10	6.90	12.9	YES	700
3	1.56	36.0	56.16	15.83	6.86	13.0	YES	700
4	1.48	36.0	53.28	15.78	6.86	13.0	YES	700
5	1.44	36.0	51.84	16.45	6.82	12.2	YES	700
6	1.58	36.0	56.88	15.31	6.76	13.0	YES	700
7	1.50	36.0	54.00	15.77	6.69	12.2	YES	700
8	1.52	36.0	54.72	15.48	6.69	12.5	YES	700
9	1.51	36.0	54.36	15.69	6.67	12.2	YES	700
10	1.49	36.0	53.64	15.50	6.58	11.9	YES	700
11	1.51	36.0	54.36	15.92	6.52	11.3	YES	700
12	1.43	36.0	51.48	15.05	6.46	11.7	YES	700
13	1.36	36.0	48.96	16.18	6.44	10.6	YES	700
14	1.48	36.0	53.28	15.19	6.35	11.1	YES	700
15	1.49	36.0	53.64	16.05	6.41	10.8	YES	700
16	1.50	36.0	54.00	15.63	6.32	10.7	YES	700
17	1.45	36.0	52.20	15.12	6.28	10.9	YES	700
18	1.23	36.0	44.28	14.75	6.13	10.3	YES	700
19	1.31	36.0	47.16	15.43	6.61	11.9	YES	700
20	1.23	36.0	44.28	15.76	6.80	12.3	YES	700
21	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
22	1.23	36.0	44.28	17.33	6.71	10.7	YES	700
23	1.44	36.0	51.84	14.85	6.47	11.9	YES	700
24	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
25	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
26	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
27	1.52	36.0	54.72	17.74	6.47	9.9	YES	700
28	1.37	36.0	49.32	15.39	6.71	12.4	YES	700
29	1.51	36.0	54.36	14.37	6.98	14.9	YES	700
30	1.46	36.0	52.56	15.79	7.06	13.9	YES	700
31	1.43	36.0	51.48	14.99	6.98	14.2	YES	700