


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Tillamook
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP:-C Month/Year: 09/2024

Day	12:00 AM	4:00 AM	8:00 AM	NOON	4PM	8:00 PM	Highest Reading of
1	0.018	0.018	0.016	0.018	0.018	0.016	0.018
2	0.018	0.019	0.019	0.016	0.019	0.018	0.019
3	0.019	0.019	0.019	0.018	0.016	0.014	0.019
4	0.016	0.014	0.016	0.014	0.014	0.014	0.016
5	0.014	0.014	0.014	0.014	0.016	0.014	0.016
6	0.016	0.016	0.016	0.014	0.014	0.014	0.016
7	0.016	0.016	0.014	0.016	0.019	0.014	0.019
8	0.016	0.014	0.016	0.014	0.014	0.014	0.016
9	0.016	0.018	0.018	0.018	0.014	0.016	0.018
10	Offline	Offline	Offline	Offline	Offline	Offline	Offline
11	Offline	Offline	Offline	Offline	Offline	Offline	Offline
12	Offline	Offline	Offline	Offline	Offline	Offline	Offline
13	0.014	0.018	0.018	0.016	0.016	0.016	0.018
14	0.014	0.018	0.014	0.016	0.016	0.014	0.018
15	0.016	0.016	0.018	0.016	0.016	0.016	0.018
16	0.019	0.018	0.012	0.014	0.014	0.012	0.019
17	0.018	0.016	0.016	0.014	0.014	0.016	0.018
18	0.014	0.018	0.018	0.016	0.016	0.016	0.018
19	0.016	0.016	0.016	0.018	0.016	0.016	0.018
20	0.018	0.016	0.016	0.016	0.014	0.018	0.018
21	0.016	0.014	0.016	0.014	0.018	0.014	0.018
22	0.016	0.021	0.016	0.014	0.016	0.019	0.021
23	0.016	0.018	0.014	0.019	0.016	0.016	0.019
24	0.018	0.018	0.016	0.016	0.014	0.016	0.018
25	Offline	Offline	Offline	Offline	Offline	Offline	Offline
26	Offline	Offline	Offline	Offline	Offline	Offline	Offline
27	0.019	0.021	0.021	0.014	0.014	0.016	0.021
28	0.016	0.018	0.014	0.016	0.014	0.014	0.018
29	0.014	0.018	0.016	0.014	0.018	0.018	0.018
30	0.018	0.014	0.014	0.016	0.014	0.016	0.018

95% of daily turbidity readings < 1 NTU? Yes/No turbidity readings < 5 NTU? Yes/No	5.1 NTU? Yes/No	All daily	CT's met everyday? (see back) Yes/No	All Cl2 residual at entry point 0.2 mg/l? Yes/No
---	-----------------	-----------	--------------------------------------	--

Notes:	Printed Name: Leonard Whiteman T-09364
	Signature 
	Phone # 503-965-6636

OHA - Drinking Water Program - Surface Quality Data Form

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-:C Month/Year09/2024								
Day	Minimum CL2 residual at 1st User C3	Contact Time	Actual CT	Temp	pH	Required CT	CT Met?	Peak Hourly Demand Flow
	[ppm or mg/l]	Minutes		deg C		Use Tables	Yes / No	GPM
1	1.51	36.0	54.36	14.73	6.88	14.1	YES	700
2	1.45	36.0	52.20	14.34	6.81	14.0	YES	700
3	1.37	36.0	49.32	15.82	6.86	12.8	YES	700
4	1.38	36.0	49.68	15.66	6.87	13.0	YES	700
5	1.45	36.0	52.20	16.51	6.78	11.9	YES	700
6	1.39	36.0	50.04	15.77	6.80	12.6	YES	700
7	1.45	36.0	52.20	15.61	6.67	12.2	YES	700
8	1.48	36.0	53.28	15.52	6.57	11.8	YES	700
9	1.33	36.0	47.88	16.45	6.67	11.3	YES	700
10	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
11	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
12	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
13	1.51	36.0	54.36	15.42	6.86	13.3	YES	700
14	1.36	36.0	48.96	14.96	6.34	11.1	YES	700
15	1.58	36.0	56.88	14.34	7.20	16.4	YES	700
16	1.51	36.0	54.36	15.03	7.24	15.7	YES	700
17	1.50	36.0	54.00	13.95	7.11	16.1	YES	700
18	1.04	36.0	37.44	14.85	6.88	13.2	YES	700
19	1.52	36.0	54.72	15.26	7.15	15.0	YES	700
20	1.80	36.0	64.80	14.32	7.08	16.1	YES	700
21	1.96	36.0	70.56	13.31	6.76	15.6	YES	700
22	1.86	36.0	66.96	14.08	6.85	15.1	YES	700
23	1.71	36.0	61.56	16.24	6.96	13.4	YES	700
24	1.71	36.0	61.56	15.24	6.89	14.0	YES	700
25	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
26	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
27	1.35	36.0	48.60	15.99	6.80	12.3	YES	700
28	1.32	36.0	47.52	14.16	6.48	12.3	YES	700
29	1.66	36.0	59.76	13.38	6.60	14.1	YES	700
30	1.77	36.0	63.72	12.79	6.89	16.5	YES	700