

OHA - DWS

Membrane Filter Monthly Operating Report

County: **Tillamook**

System Name: Pacific City Joint Water-Sanitary Authority

Month/Year: **Sep-2025**

PWS ID#: 41 - 00609

Minimum test pressure applied: 30.789 psi

Plant ID: WTP - C
(e.g., "A")

Minimum test pressure req'd: 17.47 psi

DIT = Direct Integrity Test on filter(s) [Yes, No, or "off" if all filters are offline] ⇔


PDR = Pressure Decay Rate

LRC = Log Removal Credit

Day	CFE Daily Turbidity [NTU]	Highest CFE* [NTU]	Highest IFE [NTU] (>15 minutes)	PDR _{Max} [^{psi} /min]	LRC [log removal]	DIT Daily [Y/N] or "off"
				0.090	4.00	
1	0.016	0.0176	0.018	0.019	4.74	Y
2	0.023	0.0229	0.023	0.019	4.74	Y
3	0.014	0.0176	0.018	0.026	4.76	Y
4	0.018	0.0176	0.018	0.019	4.60	Y
5	0.014	0.0176	0.018	0.019	4.90	Y
6	0.014	0.0194	0.019	0.019	4.71	Y
7	0.016	0.0176	0.018	0.013	4.88	Y
8	0.016	0.0212	0.021	0.019	4.87	Y
9	0.016	0.0194	0.019	0.019	4.89	Y
10	0.016	0.0459	0.046	0.019	4.83	Y
11	0.016	0.0406	0.041	0.019	4.91	Y
12	0.018	0.0229	0.023	0.019	4.70	Y
13	0.018	0.0212	0.021	0.019	4.88	Y
14	0.016	0.0247	0.025	0.019	4.87	Y
15	0.018	0.0247	0.025	0.019	4.71	Y
16	0.019	0.0212	0.021	0.019	4.75	Y
17	0.018	0.0229	0.023	0.026	4.77	Y
18	0.019	0.0212	0.021	0.013	4.75	Y
19	0.019	0.0212	0.021	0.013	5.06	Y
20	0.019	0.0212	0.021	0.013	4.89	Y
21	0.019	0.0229	0.023	0.013	5.04	Y
22	0.019	0.0212	0.021	0.013	4.86	Y
23	0.021	0.0229	0.023	0.013	4.90	Y
24	0.023	0.0247	0.025	0.013	5.01	Y
25	0.023	0.0247	0.025	0.013	4.90	Y
26	0.023	0.0318	0.032	0.013	5.01	Y
27	0.023	0.0282	0.028	0.019	4.72	Y
28	0.025	0.0423	0.042	0.013	4.86	Y
29	0.049	0.0635	0.064	0.013	5.04	Y
30						Off

Compliance summary (operator to complete any blank fields)

95% of daily turbidity readings ≤ 1 NTU? [Y/N]	All turbidity readings ≤ 5 NTU? [Y/N]	All IFE turbidity readings ≤ 0.15 NTU? [Y/N]	Performance std met? [Y/N] (PDR ≤ PDR _{Max} , LRV ≥ LRC)	DIT Daily?
Yes	Yes	Yes	Yes	Yes
CT's met daily? (p. 2)	All Cl ₂ residual at EP ≥ 0.2 mg/L?	PDR ≤ PDR _{Max} ?	LRV _{ambient} ≥ LRC?	
Yes	Yes	Yes	Yes	

PRINTED NAME: **Leonard Whiteman** DATE: **10/2/2025**
 SIGNATURE:  WT CERT #: **T-09364**
 Notes: PHONE #: **503-965-6636**

Disinfection Monthly Operating ReportSystem Name: **Pacific City Joint Water-Sanitary Authorit**PWS ID#: 41 - **00609**Plant ID : WTP - **C****0.5**
 ↩ Log
 Inactivation
 Required via
 Disinfection

Day	Minimum Cl ₂ Residual at 1 st User (C) * [mg/L = ppm]	Contact Time (T) [minutes]	Actual CT C x T (Formula)	Temp [° C]	pH	Required CT (Formula)	CT Met? * [Yes / No] (Formula)	Peak Hourly Demand Flow [GPM]	Notes (e.g. "Plant Off")
1	1.270	36	45.7	15.5	7.01	13.7	YES	700	
2	1.350	36	48.6	16.3	7.05	13.2	YES	700	
3	1.560	36	56.2	15.6	7.01	14.0	YES	700	
4	1.500	36	54.0	16.0	6.95	13.2	YES	700	
5	1.360	36	49.0	15.9	6.99	13.3	YES	700	
6	1.310	36	47.2	16.4	6.97	12.7	YES	700	
7	1.330	36	47.9	16.2	6.96	12.9	YES	700	
8	1.290	36	46.4	16.4	6.96	12.6	YES	700	
9	1.310	36	47.2	15.9	6.93	12.9	YES	700	
10	1.340	36	48.2	17.1	6.99	12.3	YES	700	
11	1.310	36	47.2	16.4	7.23	14.0	YES	700	
12	1.280	36	46.1	15.7	6.93	13.1	YES	700	
13	1.330	36	47.9	15.4	6.92	13.3	YES	700	
14	0.720	36	25.9	16.7	6.76	10.7	YES	700	
15	0.810	36	29.2	16.3	6.74	11.1	YES	700	
16	1.480	36	53.3	15.8	6.86	13.0	YES	700	
17	1.460	36	52.6	15.9	6.85	12.8	YES	700	
18	1.640	36	59.0	15.5	6.86	13.4	YES	700	
19	1.560	36	56.2	14.6	6.87	14.2	YES	700	
20	1.570	36	56.5	14.7	6.89	14.3	YES	700	
21	1.370	36	49.3	14.7	6.81	13.5	YES	700	
22	1.300	36	46.8	14.9	6.83	13.3	YES	700	
23	1.430	36	51.5	14.5	6.84	13.9	YES	700	
24	1.460	36	52.6	15.0	6.79	13.3	YES	700	
25	1.500	36	54.0	14.0	6.83	14.5	YES	700	
26	1.610	36	58.0	13.4	6.86	15.4	YES	700	
27	1.650	36	59.4	14.1	6.85	14.8	YES	700	
28	1.620	36	58.3	14.6	6.80	14.0	YES	700	
29	1.490	36	53.6	17.6	6.78	11.2	YES	700	
30		36						700	Plant Off
31		36						700	

* If chlorine concentration at entry point < 0.2 mg/L, or CT not met, notify DWS within 24 hours.

Submit this monthly report by the 10th of following month by

mail: Drinking Water Services
 PO Box 14350
 Portland, OR 97293-0350

email: dwp.dmce@odhsoha.oregon.gov

fax: 971-673-0458