


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Tillamook
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-:C Month/Year: 01/2021

Day	12:00 AM	4:00 AM	8:00 AM	NOON	4PM	8:00 PM	Highest Reading of
1	Offline	Offline	Offline	Offline	Offline	Offline	Offline
2	Offline	Offline	Offline	Offline	Offline	Offline	Offline
3	Offline	Offline	Offline	Offline	Offline	Offline	Offline
4	Offline	Offline	Offline	Offline	Offline	Offline	Offline
5	Offline	Offline	Offline	Offline	Offline	Offline	Offline
6	Offline	Offline	Offline	Offline	Offline	Offline	Offline
7	Offline	Offline	Offline	Offline	Offline	Offline	Offline
8	0.018	0.018	0.019	0.018	0.018	0.019	0.023
9	0.021	0.019	0.019	0.019	0.019	0.021	0.023
10	0.019	0.021	0.019	0.021	0.019	0.019	0.023
11	Offline	Offline	Offline	Offline	Offline	Offline	Offline
12	Offline	Offline	Offline	Offline	Offline	Offline	Offline
13	Offline	Offline	Offline	Offline	Offline	Offline	Offline
14	Offline	Offline	Offline	Offline	Offline	Offline	Offline
15	Offline	Offline	Offline	Offline	Offline	Offline	Offline
16	Offline	Offline	Offline	Offline	Offline	Offline	Offline
17	Offline	Offline	Offline	Offline	Offline	Offline	Offline
18	Offline	Offline	Offline	Offline	Offline	Offline	Offline
19	Offline	Offline	Offline	Offline	Offline	Offline	Offline
20	0.018	0.018	0.019	0.018	0.021	0.019	0.041
21	0.018	0.019	0.021	0.018	0.019	0.018	0.021
22	Offline	Offline	Offline	Offline	Offline	Offline	Offline
23	Offline	Offline	Offline	Offline	Offline	Offline	Offline
24	Offline	Offline	Offline	Offline	Offline	Offline	Offline
25	Offline	Offline	Offline	Offline	Offline	Offline	Offline
26	0.019	0.019	0.018	0.021	0.018	0.019	0.027
27	Offline	Offline	Offline	Offline	Offline	Offline	Offline
28	0.019	0.019	0.018	0.019	0.023	0.019	0.023
29	0.018	0.018	0.019	0.019	0.021	0.016	0.021
30	0.021	0.016	0.018	0.018	0.016	0.019	0.023
31	0.018	0.018	0.019	0.019	0.019	0.018	0.025

95% of daily turbidity readings < 1 NTU? <input checked="" type="checkbox"/> Yes/No turbidity readings < 5 NTU? <input checked="" type="checkbox"/> Yes/No	All daily	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes/No	All Cl2 residual at entry point 0.2 mg/l? <input checked="" type="checkbox"/> Yes/No
---	-----------	--	--

Notes:	Printed Name: Leonard Whiteman T-09364
	Signature 
	Phone # 503-965-6636

OHA - Drinking Water Program - Surface Quality Data Form

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-:C Month/Year 01/2021								
Day	Minimum CL2 residual at 1st User C3 [ppm or mg/l]	Contact Time Minutes	Actual CT	Temp deg C	pH	Required CT Use Tables	CT Met? Yes / No	Peak Hourly Demand Flow GPM
1	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
2	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
3	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
4	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
5	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
6	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
7	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
8	1.38	36.0	49.68	10.60	6.83	18.3	YES	700
9	1.35	36.0	48.60	10.88	6.85	18.0	YES	700
10	1.35	36.0	48.60	10.83	6.92	18.5	YES	700
11	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
12	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
13	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
14	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
15	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
16	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
17	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
18	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
19	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
20	1.12	36.0	40.32	9.68	7.11	20.7	YES	700
21	1.17	36.0	42.12	10.63	6.91	18.3	YES	700
22	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
23	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
24	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
25	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
26	1.27	36.0	45.72	9.15	6.95	20.7	YES	700
27	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
28	0.91	36.0	32.76	9.15	6.94	19.8	YES	700
29	1.39	36.0	50.04	9.84	7.04	20.7	YES	700
30	1.31	36.0	47.16	9.51	7.03	20.8	YES	700
31	1.22	36.0	43.92	11.45	6.91	17.5	YES	700