

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Tillamook
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-:C Month/Year: 02/2021

Day	12:00 AM	4:00 AM	8:00 AM	NOON	4PM	8:00 PM	Highest Reading of
1	Offline	Offline	Offline	Offline	Offline	Offline	Offline
2	Offline	Offline	Offline	Offline	Offline	Offline	Offline
3	Offline	Offline	Offline	Offline	Offline	Offline	Offline
4	0.016	0.023	0.021	0.021	0.019	0.018	0.025
5	0.019	0.018	0.018	0.016	0.021	0.018	0.021
6	0.019	0.023	0.018	0.016	0.018	0.021	0.023
7	0.018	0.019	0.021	0.018	0.018	0.016	0.023
8	0.018	0.019	0.018	0.019	0.019	0.019	0.023
9	0.023	0.016	0.023	0.018	0.016	0.019	0.023
10	0.021	0.019	0.021	0.018	0.018	0.018	0.025
11	0.021	0.021	0.018	0.019	0.019	0.019	0.023
12	0.019	0.019	0.019	0.018	0.021	0.019	0.021
13	Offline	Offline	Offline	Offline	Offline	Offline	Offline
14	Offline	Offline	Offline	Offline	Offline	Offline	Offline
15	Offline	Offline	Offline	Offline	Offline	Offline	Offline
16	Offline	Offline	Offline	Offline	Offline	Offline	Offline
17	0.041	0.042	0.041	0.018	0.021	0.021	0.042
18	0.019	0.018	0.019	0.018	0.018	0.019	0.021
19	0.019	0.019	0.019	0.018	0.016	0.019	0.019
20	0.016	0.018	0.018	0.019	0.016	0.021	0.021
21	0.018	0.019	0.018	0.016	0.018	0.021	0.021
22	Offline	Offline	Offline	Offline	Offline	Offline	Offline
23	Offline	Offline	Offline	Offline	Offline	Offline	Offline
24	Offline	Offline	Offline	Offline	Offline	Offline	Offline
25	Offline	Offline	Offline	Offline	Offline	Offline	Offline
26	Offline	Offline	Offline	Offline	Offline	Offline	Offline
27	0.018	0.019	0.021	0.018	0.016	0.019	0.023
28	0.021	0.018	0.021	0.019	0.018	0.018	0.021
95% of daily turbidity readings < 1 NTU? Yes/No turbidity readings < 5 NTU? Yes/No			All daily	CT's met everyday? (see back) Yes/No	All Cl2 residual at entry point 0.2 mg/l? Yes/No		
Notes:				Printed Name: Leonard Whiteman T-09364			
				Signature <i>Leonard Whiteman</i>			
				Phone # 503-965-6636			

OHA - Drinking Water Program - Surface Quality Data Form

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-C Month/Year 01/2021								
Day	Minimum CL2 residual at 1st User C3 [ppm or mg/l]	Contact Time Minutes	Actual CT	Temp deg C	pH	Required CT Use Tables	CT Met? Yes / No	Peak Hourly Demand Flow GPM
1	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
2	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
3	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
4	1.36	36.0	48.96	10.06	6.93	19.5	YES	700
5	1.24	36.0	44.64	10.74	6.94	18.5	YES	700
6	1.17	36.0	42.12	10.28	6.88	18.5	YES	700
7	1.25	36.0	45.00	10.56	6.95	18.8	YES	700
8	1.28	36.0	46.08	10.00	6.98	19.8	YES	700
9	1.29	36.0	46.44	9.04	7.05	21.6	YES	700
10	1.22	36.0	43.92	8.68	7.02	21.7	YES	700
11	1.29	36.0	46.44	10.24	6.78	18.2	YES	700
12	1.42	36.0	51.12	10.81	7.07	19.7	YES	700
13	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
14	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
15	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
16	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
17	0.76	36.0	27.36	11.90	6.89	16.0	YES	700
18	1.46	36.0	52.56	10.25	6.95	19.6	YES	700
19	1.59	36.0	57.24	9.98	6.91	20.0	YES	700
20	1.63	36.0	58.68	9.97	6.94	20.3	YES	700
21	1.51	36.0	54.36	10.08	6.87	19.4	YES	700
22	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
23	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
24	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
25	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
26	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
27	1.59	36.0	57.24	9.76	6.90	20.2	YES	700
28	1.60	36.0	57.60	10.69	6.86	18.8	YES	700