


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Tillamook
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-C Month/Year: 05/2021

| Day | 12:00 AM | 4:00 AM | 8:00 AM | NOON | 4PM | 8:00 PM | Highest Reading of |
|-----|----------|---------|---------|-------|-------|---------|--------------------|
| 1 | 0.016 | 0.019 | 0.018 | 0.019 | 0.016 | 0.018 | 0.019 |
| 2 | 0.018 | 0.016 | 0.016 | 0.019 | 0.019 | 0.016 | 0.019 |
| 3 | 0.018 | 0.019 | 0.021 | 0.019 | 0.018 | 0.016 | 0.021 |
| 4 | 0.016 | 0.018 | 0.021 | 0.019 | 0.018 | 0.019 | 0.023 |
| 5 | 0.019 | 0.019 | 0.019 | 0.016 | 0.019 | 0.021 | 0.030 |
| 6 | 0.014 | 0.021 | 0.018 | 0.016 | 0.019 | 0.016 | 0.032 |
| 7 | 0.019 | 0.019 | 0.021 | 0.018 | 0.019 | 0.019 | 0.023 |
| 8 | 0.016 | 0.021 | 0.019 | 0.018 | 0.016 | 0.018 | 0.025 |
| 9 | 0.016 | 0.021 | 0.018 | 0.019 | 0.016 | 0.018 | 0.025 |
| 10 | 0.019 | 0.021 | 0.025 | 0.021 | 0.018 | 0.019 | 0.025 |
| 11 | 0.018 | 0.021 | 0.021 | 0.021 | 0.021 | 0.018 | 0.025 |
| 12 | 0.025 | 0.023 | 0.021 | 0.019 | 0.019 | 0.016 | 0.024 |
| 13 | 0.019 | 0.021 | 0.021 | 0.018 | 0.016 | 0.021 | 0.027 |
| 14 | 0.027 | 0.021 | 0.019 | 0.019 | 0.018 | 0.018 | 0.027 |
| 15 | 0.019 | 0.021 | 0.021 | 0.018 | 0.016 | 0.018 | 0.023 |
| 16 | 0.023 | 0.023 | 0.016 | 0.019 | 0.019 | 0.018 | 0.023 |
| 17 | 0.021 | 0.019 | 0.019 | 0.016 | 0.018 | 0.018 | 0.025 |
| 18 | 0.016 | 0.016 | 0.016 | 0.019 | 0.023 | 0.027 | 0.027 |
| 19 | 0.027 | 0.028 | 0.028 | 0.016 | 0.023 | 0.037 | 0.037 |
| 20 | 0.018 | 0.023 | 0.019 | 0.014 | 0.021 | 0.023 | 0.025 |
| 21 | 0.021 | 0.019 | 0.018 | 0.016 | 0.021 | 0.018 | 0.023 |
| 22 | 0.016 | 0.019 | 0.018 | 0.019 | 0.018 | 0.019 | 0.023 |
| 23 | 0.019 | 0.019 | 0.019 | 0.018 | 0.018 | 0.023 | 0.023 |
| 24 | 0.019 | 0.018 | 0.019 | 0.019 | 0.018 | 0.018 | 0.025 |
| 25 | 0.025 | 0.018 | 0.018 | 0.018 | 0.019 | 0.019 | 0.025 |
| 26 | 0.019 | 0.019 | 0.018 | 0.019 | 0.018 | 0.021 | 0.023 |
| 27 | 0.021 | 0.021 | 0.018 | 0.018 | 0.018 | 0.019 | 0.025 |
| 28 | 0.018 | 0.019 | 0.019 | 0.019 | 0.021 | 0.018 | 0.025 |
| 29 | 0.018 | 0.018 | 0.018 | 0.018 | 0.016 | 0.021 | 0.021 |
| 30 | 0.021 | 0.021 | 0.019 | 0.019 | 0.018 | 0.018 | 0.021 |
| 31 | 0.019 | 0.021 | 0.018 | 0.018 | 0.018 | 0.019 | 0.021 |

| | | | |
|---|-----------|--|--|
| 95% of daily turbidity readings < 1 NTU? <input checked="" type="checkbox"/> Yes/No turbidity readings < 5 NTU? <input checked="" type="checkbox"/> Yes/No | All daily | CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes/No | All Cl2 residual at entry point 0.2 mg/l? <input checked="" type="checkbox"/> Yes/No |
|---|-----------|--|--|

| | |
|--------|--|
| Notes: | Printed Name: Leonard Whiteman T-09364 |
| | Signature  |
| | Phone # 503-965-6636 |

OHA - Drinking Water Program - Surface Quality Data Form

| System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP:-C Month/Year 05/2021 | | | | | | | | |
|---|--|-----------------|-----------|-------|------|----------------|----------|----------------------------------|
| Day | Minimum CL2 residual at 1st User C3 | Contact Time | Actual CT | Temp | pH | Required CT | CT Met? | Peak Hourly Demand Flow |
| | [ppm or mg/l] | Minutes | | deg C | | Use Tables | Yes / No | GPM |
| 1 | 1.24 | 36.0 | 44.64 | 11.76 | 6.89 | 17.0 | YES | 700 |
| 2 | 1.19 | 36.0 | 42.84 | 12.90 | 6.91 | 15.5 | YES | 700 |
| 3 | 1.19 | 36.0 | 42.84 | 11.79 | 6.92 | 17.1 | YES | 700 |
| 4 | 1.17 | 36.0 | 42.12 | 13.96 | 6.82 | 13.9 | YES | 700 |
| 5 | 1.12 | 36.0 | 40.32 | 13.13 | 6.74 | 14.2 | YES | 700 |
| 6 | 1.18 | 36.0 | 42.48 | 12.54 | 6.79 | 15.2 | YES | 700 |
| 7 | 1.12 | 36.0 | 40.32 | 12.61 | 6.89 | 15.5 | YES | 700 |
| 8 | 1.19 | 36.0 | 42.84 | 10.87 | 7.01 | 18.7 | YES | 700 |
| 9 | 1.23 | 36.0 | 44.28 | 12.53 | 6.94 | 16.1 | YES | 700 |
| 10 | 1.18 | 36.0 | 42.48 | 12.84 | 6.84 | 15.1 | YES | 700 |
| 11 | 1.21 | 36.0 | 43.56 | 13.01 | 6.80 | 14.8 | YES | 700 |
| 12 | 1.23 | 36.0 | 44.28 | 13.90 | 6.77 | 13.8 | YES | 700 |
| 13 | 1.28 | 36.0 | 46.08 | 13.12 | 6.86 | 15.1 | YES | 700 |
| 14 | 1.21 | 36.0 | 43.56 | 14.14 | 6.77 | 13.6 | YES | 700 |
| 15 | 1.20 | 36.0 | 43.20 | 13.09 | 6.78 | 14.6 | YES | 700 |
| 16 | 1.23 | 36.0 | 44.28 | 13.89 | 6.79 | 13.9 | YES | 700 |
| 17 | 1.20 | 36.0 | 43.20 | 12.62 | 6.80 | 15.2 | YES | 700 |
| 18 | 1.14 | 36.0 | 41.04 | 16.39 | 6.71 | 11.3 | YES | 700 |
| 19 | 1.06 | 36.0 | 38.16 | 15.26 | 6.67 | 11.9 | YES | 700 |
| 20 | 1.11 | 36.0 | 39.96 | 12.19 | 6.76 | 15.6 | YES | 700 |
| 21 | 1.16 | 36.0 | 41.76 | 12.50 | 6.87 | 15.6 | YES | 700 |
| 22 | 1.24 | 36.0 | 44.64 | 12.35 | 6.87 | 16.3 | YES | 700 |
| 23 | 1.18 | 36.0 | 42.48 | 12.42 | 6.78 | 15.6 | YES | 700 |
| 24 | 1.07 | 36.0 | 38.52 | 12.81 | 6.81 | 14.8 | YES | 700 |
| 25 | 0.90 | 36.0 | 32.40 | 12.67 | 6.74 | 14.3 | YES | 700 |
| 26 | 1.09 | 36.0 | 39.24 | 13.03 | 6.76 | 14.4 | YES | 700 |
| 27 | 1.21 | 36.0 | 43.56 | 12.39 | 6.70 | 15.3 | YES | 700 |
| 28 | 1.06 | 36.0 | 38.16 | 12.98 | 6.77 | 14.4 | YES | 700 |
| 29 | 1.31 | 36.0 | 47.16 | 13.03 | 6.73 | 14.6 | YES | 700 |
| 30 | 1.35 | 36.0 | 48.60 | 14.02 | 6.66 | 13.3 | YES | 700 |
| 31 | 1.32 | 36.0 | 47.52 | 14.13 | 6.61 | 13.0 | YES | 700 |