

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Tillamook  
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP:-C Month/Year: 09/2021

Day	12:00 AM	4:00 AM	8:00 AM	NOON	4PM	8:00 PM	Highest Reading of
1	0.021	0.025	0.021	0.019	0.023	0.027	0.027
2	0.023	0.021	0.021	0.023	0.023	0.019	0.025
3	0.021	0.019	0.023	0.019	0.019	0.019	0.023
4	0.019	0.021	0.019	0.025	0.021	0.021	0.025
5	0.021	0.021	0.019	0.019	0.023	0.021	0.028
6	0.021	0.021	0.023	0.021	0.021	0.019	0.028
7	0.028	0.023	0.021	0.025	0.023	0.023	0.028
8	0.021	0.021	0.023	0.025	0.019	0.018	0.831
9	0.023	0.021	0.018	0.021	0.018	0.018	0.028
10	0.019	0.018	0.016	0.016	0.014	0.016	0.019
11	0.016	0.019	0.018	0.019	0.016	0.018	0.023
12	0.016	0.018	0.016	0.016	0.014	0.016	0.021
13	0.021	0.016	0.016	0.016	0.016	0.018	0.021
14	0.014	0.014	0.014	0.014	0.014	0.014	0.018
15	0.018	0.016	0.016	0.014	0.014	0.019	0.019
16	0.016	0.016	0.014	0.016	0.014	0.018	0.019
17	0.016	0.018	0.019	0.016	0.019	0.018	0.019
18	Offline	Offline	Offline	Offline	Offline	Offline	Offline
19	Offline	Offline	Offline	Offline	Offline	Offline	Offline
20	Offline	Offline	Offline	Offline	Offline	Offline	Offline
21	Offline	Offline	Offline	Offline	Offline	Offline	Offline
22	0.014	0.016	0.018	0.018	0.018	0.014	0.018
23	0.016	0.014	0.014	0.014	0.018	0.014	0.018
24	0.016	0.014	0.016	0.014	0.016	0.012	0.021
25	0.012	0.014	0.014	0.016	0.016	0.018	0.019
26	0.018	0.014	0.016	0.018	0.018	0.016	0.018
27	0.018	0.016	0.014	0.016	0.012	0.018	0.021
28	0.016	0.018	0.016	0.016	0.019	0.016	0.019
29	0.018	0.021	0.021	0.014	0.014	0.016	0.025
30	0.019	0.018	0.016	0.060	0.016	0.012	0.060

95% of daily turbidity readings < 1 NTU? Yes/No turbidity readings < 5 NTU? Yes/No	All daily	CT's met everyday? (see back) Yes/No	All Cl2 residual at entry point 0.2 mg/l? Yes/No
---	-----------	--------------------------------------	--

Notes:	Printed Name: Leonard Whiteman T-09364
	Signature 
	Phone # 503-965-6636

OHA - Drinking Water Program - Surface Quality Data Form

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-:C Month/Year 09/2021								
Day	Minimum CL2 residual at 1st User C3 [ppm or mg/l]	Contact Time Minutes	Actual CT	Temp deg C	pH	Required CT Use Tables	CT Met? Yes / No	Peak Hourly Demand Flow GPM
1	1.49	36.0	53.64	14.20	6.75	13.8	YES	700
2	1.46	36.0	52.56	14.67	6.71	13.2	YES	700
3	1.59	36.0	57.24	13.58	6.79	14.8	YES	700
4	1.54	36.0	55.44	14.12	6.86	14.6	YES	700
5	1.46	36.0	52.56	15.41	6.59	12.0	YES	700
6	1.45	36.0	52.20	15.16	6.58	12.1	YES	700
7	1.43	36.0	51.48	15.36	6.48	11.5	YES	700
8	1.44	36.0	51.84	15.16	6.71	12.7	YES	700
9	1.46	36.0	52.56	15.89	6.72	12.2	YES	700
10	1.39	36.0	50.04	15.10	6.74	12.8	YES	700
11	1.38	36.0	49.68	14.77	6.82	13.5	YES	700
12	1.42	36.0	51.12	14.94	6.74	13.0	YES	700
13	1.38	36.0	49.68	14.80	6.80	13.4	YES	700
14	1.48	36.0	53.28	13.73	6.88	15.0	YES	700
15	1.50	36.0	54.00	15.48	6.70	12.5	YES	700
16	1.50	36.0	54.00	13.75	6.86	14.9	YES	700
17	1.53	36.0	55.08	15.05	6.83	13.5	YES	700
18	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
19	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
20	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
21	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
22	1.28	36.0	46.08	14.34	6.60	12.7	YES	700
23	1.32	36.0	47.52	15.07	6.71	12.6	YES	700
24	1.34	36.0	48.24	14.55	6.62	12.7	YES	700
25	1.34	36.0	48.24	14.61	6.66	12.8	YES	700
26	1.36	36.0	48.96	14.36	6.77	13.6	YES	700
27	0.98	36.0	35.28	14.52	6.72	12.6	YES	700
28	0.66	36.0	23.76	13.51	6.68	12.8	YES	700
29	0.60	36.0	21.60	15.13	6.68	11.4	YES	700
30	1.36	36.0	48.96	15.22	6.79	12.9	YES	700