


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Tillamook
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-:C Month/Year: 10/2021

Day	12:00 AM	4:00 AM	8:00 AM	NOON	4PM	8:00 PM	Highest Reading of
1	0.016	0.014	0.016	0.016	0.018	0.014	0.018
2	0.016	0.016	0.016	0.016	0.014	0.018	0.019
3	0.016	0.016	0.016	0.014	0.014	0.018	0.018
4	0.016	0.016	0.016	0.014	0.016	0.018	0.019
5	0.016	0.016	0.016	0.021	0.016	0.014	0.021
6	0.016	0.016	0.018	0.016	0.016	0.016	0.028
7	0.016	0.016	0.016	0.014	0.018	0.016	0.019
8	0.016	0.016	0.016	0.016	0.014	0.016	0.018
9	0.014	0.016	0.014	0.016	0.014	0.014	0.018
10	0.014	0.018	0.015	0.016	0.014	0.016	0.018
11	0.014	0.014	0.014	0.016	0.016	0.016	0.018
12	0.014	0.018	0.014	0.016	0.016	0.018	0.019
13	0.014	0.018	0.016	0.014	0.014	0.014	0.018
14	0.016	0.014	0.018	0.014	0.018	0.016	0.018
15	0.014	0.018	0.016	0.016	0.014	0.018	0.018
16	0.016	0.016	0.016	0.016	0.002	0.016	0.019
17	0.016	0.016	0.014	0.016	0.016	0.016	0.019
18	0.016	0.023	0.014	0.016	0.016	0.014	0.023
19	0.016	0.016	0.014	0.012	0.014	0.018	0.018
20	0.016	0.016	0.016	0.014	0.016	0.019	0.021
21	Offline	Offline	Offline	Offline	Offline	Offline	Offline
22	Offline	Offline	Offline	Offline	Offline	Offline	Offline
23	Offline	Offline	Offline	Offline	Offline	Offline	Offline
24	Offline	Offline	Offline	Offline	Offline	Offline	Offline
25	Offline	Offline	Offline	Offline	Offline	Offline	Offline
26	Offline	Offline	Offline	Offline	Offline	Offline	Offline
27	Offline	Offline	Offline	Offline	Offline	Offline	Offline
28	Offline	Offline	Offline	Offline	Offline	Offline	Offline
29	Offline	Offline	Offline	Offline	Offline	Offline	Offline
30	Offline	Offline	Offline	Offline	Offline	Offline	Offline
31	0.021	0.019	0.019	0.014	0.016	0.019	0.027

95% of daily turbidity readings < 1 NTU? <input checked="" type="checkbox"/> Yes/No turbidity readings < 5 NTU? <input checked="" type="checkbox"/> Yes/No	All daily	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes/No	All Cl2 residual at entry point 0.2 mg/l? <input checked="" type="checkbox"/> Yes/No
---	-----------	--	--

Notes:	Printed Name: Leonard Whiteman T-09364
	Signature 
	Phone # 503-965-6636

OHA - Drinking Water Program - Surface Quality Data Form

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP:-C Month/Year 10/2021								
Day	Minimum CL2 residual at 1st User C3 [ppm or mg/l]	Contact Time Minutes	Actual CT	Temp deg C	pH	Required CT Use Tables	CT Met? Yes / No	Peak Hourly Demand Flow GPM
1	1.19	36.0	42.84	13.38	6.77	14.2	YES	700
2	1.69	36.0	60.84	13.85	6.92	15.4	YES	700
3	1.57	36.0	56.52	12.85	7.01	16.8	YES	700
4	1.55	36.0	55.80	13.64	6.96	15.6	YES	700
5	1.48	36.0	53.28	12.95	6.88	15.8	YES	700
6	0.93	36.0	33.48	13.06	6.86	14.6	YES	700
7	1.10	36.0	39.60	11.83	6.94	17.0	YES	700
8	1.71	36.0	61.56	12.00	7.21	19.7	YES	700
9	1.60	36.0	57.60	12.37	7.10	18.3	YES	700
10	1.36	36.0	48.96	13.32	7.00	15.9	YES	700
11	1.12	36.0	40.32	11.85	7.04	17.6	YES	700
12	1.58	36.0	56.88	11.39	7.24	20.4	YES	700
13	1.57	36.0	56.52	10.98	7.33	21.6	YES	700
14	1.36	36.0	48.96	12.56	7.10	17.3	YES	700
15	1.18	36.0	42.48	12.36	7.01	17.0	YES	700
16	1.68	36.0	60.48	12.76	7.02	17.2	YES	700
17	1.71	36.0	61.56	12.55	7.00	17.4	YES	700
18	1.43	36.0	51.48	12.21	7.02	17.7	YES	700
19	1.78	36.0	64.08	11.38	7.13	20.1	YES	700
20	1.50	36.0	54.00	12.94	7.02	16.7	YES	700
21	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
22	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
23	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
24	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
25	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
26	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
27	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
28	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
29	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
30	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
31	1.58	36.0	56.88	11.14	7.29	21.1	YES	700