


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Tillamook
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-:C Month/Year: 11/2021

Day	12:00 AM	4:00 AM	8:00 AM	NOON	4PM	8:00 PM	Highest Reading of
1	0.019	0.018	0.018	0.019	0.016	0.018	0.021
2	0.018	0.018	0.016	0.018	0.016	0.016	0.021
3	0.014	0.018	0.016	0.014	0.014	0.014	0.018
4	0.016	0.016	0.014	0.023	0.012	0.014	0.023
5	0.012	0.012	0.014	0.019	0.012	0.012	0.019
6	0.012	0.012	0.014	0.014	0.014	0.014	0.018
7	0.012	0.014	0.011	0.012	0.011	0.012	0.014
8	0.012	0.014	0.014	0.012	0.011	0.012	0.014
9	0.012	0.011	0.012	0.012	0.012	0.014	0.014
10	0.012	0.012	0.012	0.012	0.012	0.014	0.016
11	offline	Offline	Offline	Offline	Offline	Offline	Offline
12	offline	Offline	Offline	Offline	Offline	Offline	Offline
13	offline	Offline	Offline	Offline	Offline	Offline	Offline
14	offline	Offline	Offline	Offline	Offline	Offline	Offline
15	offline	Offline	Offline	Offline	Offline	Offline	Offline
16	offline	Offline	Offline	Offline	Offline	Offline	Offline
17	offline	Offline	Offline	Offline	Offline	Offline	Offline
18	offline	Offline	0.012	0.014	0.014	0.014	0.030
19	0.014	0.014	0.016	0.014	0.014	0.014	0.016
20	0.012	0.014	0.014	0.014	0.012	0.012	0.016
21	0.014	0.011	0.014	0.019	0.014	0.016	0.019
22	0.012	0.011	0.011	0.014	0.016	0.011	0.016
23	0.014	0.012	0.016	0.012	0.012	0.014	0.016
24	0.011	0.012	0.012	0.014	0.012	0.012	0.014
25	0.014	0.012	0.012	0.014	0.012	0.012	0.016
26	0.016	0.012	0.014	0.012	0.012	0.012	0.016
27	0.011	0.012	0.012	0.012	0.012	0.016	0.016
28	0.012	0.012	0.012	0.014	0.014	0.014	0.014
29	0.014	0.012	0.014	0.012	0.012	0.012	0.016
30	0.014	0.014	0.014	0.011	0.012	0.012	0.016

95% of daily turbidity readings < 1 NTU? Yes/No turbidity readings < 5 NTU? Yes/No	Yes/No <input checked="" type="checkbox"/> Yes	All daily	CT's met everyday? (see back) Yes/No	Yes/No <input checked="" type="checkbox"/> Yes	All Cl2 residual at entry point 0.2 mg/l? Yes/No	Yes/No <input checked="" type="checkbox"/> Yes
---	--	-----------	--------------------------------------	--	--	--

Notes:	Printed Name: Leonard Whiteman T-09364
	Signature 
	Phone # 503-965-6636

OHA - Drinking Water Program - Surface Quality Data Form

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-:C Month/Year 11/2021								
Day	Minimum CL2 residual at 1st User C3	Contact Time Minutes	Actual CT	Temp deg C	pH	Required CT Use Tables	CT Met? Yes / No	Peak Hourly Demand Flow GPM
1	1.42	36.0	51.12	12.04	7.29	19.6	YES	700
2	1.27	36.0	45.72	11.92	7.26	19.2	YES	700
3	1.48	36.0	53.28	12.08	7.24	19.3	YES	700
4	1.36	36.0	48.96	13.09	7.20	17.4	YES	700
5	1.33	36.0	47.88	12.77	7.20	17.7	YES	700
6	1.32	36.0	47.52	11.87	7.18	18.8	YES	700
7	1.54	36.0	55.44	10.60	7.25	21.5	YES	700
8	1.50	36.0	54.00	10.80	7.27	21.3	YES	700
9	1.66	36.0	59.76	11.04	7.28	21.4	YES	700
10	1.72	36.0	61.92	12.55	7.27	19.2	YES	700
11	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
12	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
13	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
14	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
15	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
16	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
17	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
18	1.63	36.0	58.68	13.08	7.32	18.7	YES	700
19	1.63	36.0	58.68	13.14	7.36	18.9	YES	700
20	1.62	36.0	58.32	11.45	7.23	20.4	YES	700
21	1.75	36.0	63.00	10.09	7.24	22.7	YES	700
22	1.73	36.0	62.28	10.16	7.32	23.2	YES	700
23	1.53	36.0	55.08	10.93	7.41	22.2	YES	700
24	1.58	36.0	56.88	10.60	7.37	22.5	YES	700
25	1.65	36.0	59.40	10.37	7.30	22.5	YES	700
26	1.53	36.0	55.08	11.58	7.28	20.4	YES	700
27	1.55	36.0	55.80	11.62	7.39	21.1	YES	700
28	1.38	36.0	49.68	12.16	7.34	19.7	YES	700
29	1.52	36.0	54.72	12.11	7.36	20.2	YES	700
30	1.43	36.0	51.48	12.22	7.28	19.3	YES	700