


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Tillamook  
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP:-C Month/Year: 01/2022

Day	12:00 AM	4:00 AM	8:00 AM	NOON	4PM	8:00 PM	Highest Reading of
1	0.011	0.012	0.012	0.012	0.012	0.012	0.014
2	Offline	Offline	Offline	Offline	Offline	Offline	Offline
3	Offline	Offline	Offline	Offline	Offline	Offline	Offline
4	Offline	Offline	Offline	Offline	Offline	Offline	Offline
5	0.012	0.012	0.011	0.014	0.012	0.012	0.014
6	Offline	Offline	Offline	Offline	Offline	Offline	Offline
7	Offline	Offline	Offline	Offline	Offline	Offline	Offline
8	Offline	Offline	Offline	Offline	Offline	Offline	Offline
9	0.034	0.034	0.035	0.037	0.035	0.039	0.041
10	0.041	0.039	0.042	0.042	0.018	0.018	0.042
11	0.018	0.018	0.019	0.019	0.018	0.018	0.019
12	0.019	0.018	0.018	0.102	0.012	0.012	0.102
13	0.012	0.012	0.012	0.011	0.011	0.011	0.012
14	0.014	0.012	0.012	0.011	0.012	0.012	0.012
15	0.011	0.012	0.011	0.011	0.011	0.011	0.014
16	0.011	0.012	0.012	0.011	0.012	0.011	0.012
17	0.011	0.012	0.011	0.014	0.012	0.011	0.014
18	0.011	0.014	0.011	0.012	0.014	0.011	0.014
19	0.012	0.011	0.011	0.012	0.011	0.012	0.014
20	0.012	0.011	0.012	0.011	0.011	0.011	0.012
21	0.011	0.012	0.011	0.012	0.011	0.012	0.019
22	0.011	0.012	0.011	0.012	0.011	0.012	0.014
23	0.011	0.011	0.012	0.012	0.011	0.012	0.012
24	0.012	0.011	0.011	0.011	0.011	0.014	0.014
25	0.012	0.012	0.012	0.011	0.012	0.011	0.014
26	0.012	0.012	0.011	0.012	0.011	0.011	0.014
27	0.012	0.012	0.012	0.011	0.012	0.011	0.014
28	0.011	0.011	0.011	0.012	0.012	0.011	0.014
29	0.014	0.011	0.011	0.012	0.012	0.009	0.014
30	0.011	0.011	0.011	0.012	0.012	0.014	0.014
31	0.014	0.011	0.011	0.012	0.012	0.011	0.014

95% of daily turbidity readings < 1 NTU? <input checked="" type="checkbox"/> Yes/No turbidity readings < 5 NTU? <input checked="" type="checkbox"/> Yes/No	All daily	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes/No	All Cl2 residual at entry point 0.2 mg/l? <input checked="" type="checkbox"/> Yes/No
---	-----------	--	--

Notes:	Printed Name: Leonard Whiteman T-09364
	Signature 
	Phone # 503-965-6636

OHA - Drinking Water Program - Surface Quality Data Form

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-:C Month/Year 01/2022								
Day	Minimum CL2 residual at 1st User C3 [ppm or mg/l]	Contact Time Minutes	Actual CT	Temp deg C	pH	Required CT Use Tables	CT Met? Yes / No	Peak Hourly Demand Flow GPM
1	1.68	36.0	60.48	7.67	6.58	20.9	YES	700
2	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
3	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
4	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
5	1.52	36.0	54.72	10.27	6.57	17.3	YES	700
6	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
7	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
8	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
9	1.00	36.0	36.00	15.43	6.50	11.0	YES	700
10	1.11	36.0	39.96	13.16	6.47	12.8	YES	700
11	1.50	36.0	54.00	11.29	6.50	15.8	YES	700
12	1.61	36.0	57.96	11.25	6.63	16.8	YES	700
13	1.60	36.0	57.60	11.50	6.79	17.4	YES	700
14	1.44	36.0	51.84	10.60	6.75	17.9	YES	700
15	1.24	36.0	44.64	10.71	6.77	17.5	YES	700
16	1.23	36.0	44.28	9.79	6.76	18.5	YES	700
17	1.25	36.0	45.00	10.55	6.79	17.8	YES	700
18	1.15	36.0	41.40	10.87	6.78	17.2	YES	700
19	1.03	36.0	37.08	11.38	6.72	16.1	YES	700
20	1.12	36.0	40.32	10.95	6.71	16.7	YES	700
21	1.23	36.0	44.28	10.91	6.73	17.0	YES	700
22	1.60	36.0	57.60	9.88	6.80	19.4	YES	700
23	1.62	36.0	58.32	10.19	6.79	19.0	YES	700
24	1.70	36.0	61.20	10.30	6.85	19.4	YES	700
25	1.63	36.0	58.68	9.90	6.82	19.6	YES	700
26	1.55	36.0	55.80	11.05	6.80	17.9	YES	700
27	1.46	36.0	52.56	9.59	6.77	19.3	YES	700
28	1.55	36.0	55.80	8.70	6.82	21.0	YES	700
29	1.65	36.0	59.40	9.20	6.83	20.6	YES	700
30	1.57	36.0	56.52	9.64	6.84	19.9	YES	700
31	1.49	36.0	53.64	9.82	6.85	19.6	YES	700