

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Tillamook
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP:-C Month/Year: 09/2022

Day	12:00 AM	4:00 AM	8:00 AM	NOON	4PM	8:00 PM	Highest Reading of
1	0.027	0.028	0.039	0.012	0.012	0.012	0.039
2	0.012	0.016	0.012	0.018	0.014	0.012	0.018
3	0.014	0.012	0.012	0.012	0.012	0.012	0.014
4	0.012	0.014	0.012	0.012	0.014	0.014	0.014
5	0.014	0.012	0.012	0.012	0.012	0.012	0.014
6	0.014	0.012	0.012	0.014	0.014	0.012	0.014
7	0.012	0.014	0.012	0.012	0.012	0.012	0.014
8	0.012	0.014	0.012	0.021	0.014	0.011	0.021
9	0.012	0.016	0.012	0.012	0.012	0.014	0.016
10	0.014	0.014	0.012	0.012	0.012	0.012	0.014
11	0.014	0.012	0.012	0.012	0.016	0.014	0.016
12	0.012	0.014	0.012	0.014	0.012	0.012	0.014
13	0.012	0.012	0.012	0.012	0.016	0.012	0.016
14	0.012	0.011	0.012	0.012	0.012	0.012	0.012
15	0.012	0.012	0.012	0.014	0.014	0.014	0.014
16	0.016	0.018	0.016	0.014	0.016	0.014	0.018
17	0.014	0.014	0.014	0.018	0.018	0.016	0.018
18	0.016	0.014	0.016	0.014	0.014	0.014	0.016
19	0.014	0.014	0.014	0.019	0.014	0.016	0.019
20	0.016	0.012	0.012	0.016	0.014	0.014	0.016
21	0.016	0.012	0.016	0.016	0.016	0.014	0.016
22	0.012	0.016	0.014	0.014	0.016	0.012	0.016
23	0.012	0.016	0.016	0.019	0.014	0.016	0.019
24	0.016	0.016	0.014	0.018	0.016	0.014	0.018
25	0.014	0.014	0.014	0.014	0.014	0.014	0.014
26	0.014	0.014	0.014	0.014	0.014	0.016	0.016
27	0.016	0.014	0.016	0.014	0.014	0.016	0.016
28	0.014	0.018	0.016	0.019	0.014	0.012	0.018
29	Offline	Offline	Offline	Offline	Offline	Offline	Offline
30	Offline	Offline	Offline	Offline	Offline	Offline	Offline

95% of daily turbidity readings < 1 NTU? Yes/No No
 turbidity readings < 5 NTU? Yes/No No


All daily

CT's met everyday? (see back) Yes/No No

All Cl2 residual at entry point 0.2 mg/l? Yes/No No

Notes:

Printed Name: Leonard Whiteman T-09364

Signature 

Phone # 503-965-6636

