


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Tillamook
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP:-C Month/Year: 10/2022

Day	12:00 AM	4:00 AM	8:00 AM	NOON	4PM	8:00 PM	Highest Reading of
1	Offline	Offline	Offline	Offline	Offline	Offline	Offline
2	Offline	Offline	Offline	Offline	Offline	Offline	Offline
3	Offline	Offline	Offline	Offline	Offline	Offline	Offline
4	Offline	Offline	Offline	Offline	Offline	Offline	Offline
5	Offline	Offline	Offline	Offline	Offline	Offline	Offline
6	0.019	0.019	0.016	0.000	0.019	0.014	0.019
7	0.019	0.014	0.016	0.016	0.016	0.016	0.019
8	0.014	0.014	0.016	0.016	0.018	0.016	0.018
9	0.014	0.016	0.016	0.016	0.016	0.016	0.016
10	0.018	0.016	0.019	0.016	0.014	0.016	0.019
11	0.016	0.018	0.014	0.014	0.016	0.016	0.018
12	0.018	0.018	0.016	0.019	0.018	0.016	0.019
13	0.016	0.018	0.016	0.016	0.016	0.016	0.018
14	0.018	0.016	0.016	0.016	0.014	0.016	0.018
15	0.016	0.016	0.016	0.014	0.016	0.016	0.016
16	0.016	0.016	0.018	0.016	0.016	0.016	0.018
17	0.016	0.019	0.016	0.018	0.016	0.016	0.019
18	0.018	0.016	0.016	0.021	0.016	0.016	0.021
19	0.014	0.018	0.018	0.016	0.012	0.021	0.021
20	Offline	Offline	Offline	Offline	Offline	Offline	Offline
21	Offline	Offline	Offline	Offline	Offline	Offline	Offline
22	Offline	Offline	Offline	Offline	Offline	Offline	Offline
23	Offline	Offline	Offline	Offline	Offline	Offline	Offline
24	Offline	Offline	Offline	Offline	Offline	Offline	Offline
25	0.018	0.018	0.019	0.016	0.014	0.016	0.019
26	0.014	0.016	0.014	0.014	0.014	0.016	0.016
27	0.014	0.014	0.014	0.014	0.016	0.016	0.018
28	0.014	0.014	0.016	0.018	0.014	0.016	0.018
29	0.016	0.014	0.016	0.014	0.016	0.014	0.016
30	0.018	0.016	0.014	0.016	0.018	0.014	0.018
31	0.016	0.014	0.018	0.016	0.016	0.014	0.018

95% of daily turbidity readings < 1 NTU? <input checked="" type="radio"/> Yes/No turbidity readings < 5 NTU? <input checked="" type="radio"/> Yes/No	All daily	CT's met everyday? (see back) <input checked="" type="radio"/> Yes/No	All Cl2 residual at entry point 0.2 mg/l? <input checked="" type="radio"/> Yes/No
---	-----------	---	---

Notes:	Printed Name: Leonard Whiteman T-09364
	Signature: 
	Phone # 503-965-6636

OHA - Drinking Water Program - Surface Quality Data Form

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-:C Month/Year 10/2022								
Day	Minimum CL2 residual at 1st User C3	Contact Time	Actual CT	Temp	pH	Required CT	CT Met?	Peak Hourly Demand Flow
	[ppm or mg/l]	Minutes		deg C		Use Tables	Yes / No	GPM
1	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
2	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
3	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
4	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
5	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
6	1.66	36.0	59.76	15.12	6.60	12.6	YES	700
7	1.40	36.0	50.40	14.19	6.83	14.1	YES	700
8	1.47	36.0	52.92	14.43	6.84	14.1	YES	700
9	1.51	36.0	54.36	13.47	6.85	15.1	YES	700
10	1.45	36.0	52.20	13.89	6.88	14.8	YES	700
11	1.28	36.0	46.08	13.67	6.84	14.5	YES	700
12	1.49	36.0	53.64	13.78	6.85	14.8	YES	700
13	1.62	36.0	58.32	13.04	6.81	15.5	YES	700
14	1.56	36.0	56.16	13.67	6.84	15.0	YES	700
15	1.62	36.0	58.32	13.01	6.85	15.8	YES	700
16	1.54	36.0	55.44	14.20	6.85	14.5	YES	700
17	1.55	36.0	55.80	13.89	6.82	14.6	YES	700
18	1.63	36.0	58.68	14.67	6.81	13.9	YES	700
19	1.69	36.0	60.84	12.73	6.81	16.0	YES	700
20	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
21	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
22	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
23	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
24	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
25	1.42	36.0	51.12	13.93	6.85	14.5	YES	700
26	1.22	36.0	43.92	11.69	6.83	16.7	YES	700
27	1.38	36.0	49.68	11.47	6.86	17.4	YES	700
28	1.63	36.0	58.68	11.94	6.88	17.5	YES	700
29	1.17	36.0	42.12	11.91	6.82	16.3	YES	700
30	1.71	36.0	61.56	12.14	6.89	17.5	YES	700
31	1.57	36.0	56.52	12.29	6.87	17.0	YES	700