

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Tillamook
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-:C Month/Year: 11/2022

Day	12:00 AM	4:00 AM	8:00 AM	NOON	4PM	8:00 PM	Highest Reading of
1	0.016	0.016	0.014	0.016	0.012	0.016	0.016
2	0.014	0.018	0.014	0.016	0.014	0.016	0.018
3	Offline	Offline	Offline	Offline	Offline	Offline	Offline
4	Offline	Offline	Offline	Offline	Offline	Offline	Offline
5	Offline	Offline	Offline	Offline	Offline	Offline	Offline
6	Offline	Offline	Offline	Offline	Offline	Offline	Offline
7	Offline	Offline	Offline	Offline	Offline	Offline	Offline
8	0.044	0.048	0.048	0.018	0.016	0.016	0.048
9	0.016	0.016	0.016	0.018	0.016	0.016	0.018
10	0.016	0.016	0.016	0.014	0.016	0.016	0.016
11	0.019	0.016	0.014	0.014	0.016	0.016	0.019
12	0.014	0.016	0.016	0.018	0.016	0.016	0.018
13	0.014	0.016	0.016	0.018	0.016	0.014	0.018
14	0.016	0.018	0.016	0.016	0.016	0.016	0.018
15	0.016	0.018	0.016	0.018	0.018	0.016	0.018
16	0.016	0.018	0.016	0.014	0.016	0.016	0.018
17	0.018	0.016	0.016	0.018	0.016	0.016	0.018
18	0.018	0.016	0.016	0.018	0.018	0.016	0.018
19	0.018	0.018	0.018	0.018	0.016	0.018	0.018
20	0.018	0.018	0.018	0.018	0.018	0.018	0.018
21	0.016	0.016	0.019	0.019	0.016	0.016	0.019
22	0.018	0.016	0.016	0.016	0.016	0.018	0.018
23	0.016	0.019	0.018	0.025	0.019	0.019	0.025
24	0.016	0.016	0.018	0.018	0.014	0.016	0.018
25	0.016	0.016	0.016	0.018	0.018	0.016	0.018
26	0.016	0.016	0.016	0.016	0.016	0.016	0.016
27	0.016	0.018	0.016	0.016	0.018	0.016	0.018
28	0.018	0.016	0.016	0.019	0.016	0.018	0.019
29	0.016	0.018	0.016	0.016	0.016	0.019	0.019
30	0.018	0.021	0.023	0.025	0.028	0.028	0.028

95% of daily turbidity readings < 1 NTU? Yes/No turbidity readings < 5 NTU? Yes/No	All daily	CT's met everyday? (see back) Yes/No	All Cl2 residual at entry point 0.2 mg/l? Yes/No
---	-----------	--------------------------------------	--

Notes:	Printed Name: Leonard Whiteman T-09864
	Signature 
	Phone # 503-965-6636

OHA - Drinking Water Program - Surface Quality Data Form

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP:-C Month/Year 11/2022								
Day	Minimum CL2 residual at 1st User C3 [ppm or mg/l]	Contact Time Minutes	Actual CT	Temp deg C	pH	Required CT Use Tables	CT Met? Yes / No	Peak Hourly Demand Flow GPM
1	1.29	36.0	46.44	11.86	6.85	16.8	YES	700
2	1.58	36.0	56.88	9.90	6.91	20.1	YES	700
3	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
4	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
5	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
6	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
7	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
8	1.62	36.0	58.32	11.84	6.94	18.0	YES	700
9	2.03	36.0	73.08	9.84	6.98	21.7	YES	700
10	2.02	36.0	72.72	9.43	6.98	22.3	YES	700
11	1.95	36.0	70.20	9.90	7.00	21.6	YES	700
12	1.80	36.0	64.80	9.59	6.97	21.5	YES	700
13	1.82	36.0	65.52	9.60	7.02	21.9	YES	700
14	1.83	36.0	65.88	8.81	7.00	22.9	YES	700
15	1.79	36.0	64.44	9.52	7.02	21.9	YES	700
16	1.75	36.0	63.00	9.15	7.01	22.3	YES	700
17	1.81	36.0	65.16	8.54	7.00	23.3	YES	700
18	1.93	36.0	69.48	8.59	7.08	24.2	YES	700
19	1.88	36.0	67.68	7.48	7.03	25.4	YES	700
20	1.84	36.0	66.24	8.40	7.07	24.2	YES	700
21	1.79	36.0	64.44	8.75	7.04	23.2	YES	700
22	1.71	36.0	61.56	9.45	6.94	21.2	YES	700
23	1.63	36.0	58.68	10.09	6.97	20.4	YES	700
24	1.82	36.0	65.52	8.81	6.98	22.7	YES	700
25	1.81	36.0	65.16	9.22	6.98	22.1	YES	700
26	1.62	36.0	58.32	8.21	6.93	22.7	YES	700
27	1.74	36.0	62.64	9.56	6.97	21.3	YES	700
28	1.77	36.0	63.72	8.99	6.98	22.3	YES	700
29	2.01	36.0	72.36	8.56	7.01	23.9	YES	700
30	2.16	36.0	77.76	16.14	7.06	14.7	YES	700