

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Tillamook  
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-:C Month/Year: 12/2022

Day	12:00 AM	4:00 AM	8:00 AM	NOON	4PM	8:00 PM	Highest Reading of
1	Offline	Offline	Offline	Offline	Offline	Offline	Offline
2	0.016	0.018	0.018	0.018	0.016	0.018	0.018
3	0.018	0.018	0.018	0.018	0.016	0.018	0.018
4	0.016	0.018	0.016	0.016	0.016	0.018	0.018
5	0.018	0.018	0.016	0.018	0.016	0.016	0.018
6	0.016	0.018	0.018	0.018	0.016	0.018	0.018
7	0.018	0.018	0.016	0.018	0.016	0.018	0.018
8	0.019	0.018	0.018	0.018	0.018	0.018	0.019
9	0.018	0.016	0.018	0.018	0.018	0.019	0.019
10	0.021	0.019	0.019	0.018	0.019	0.019	0.021
11	0.021	0.021	0.021	0.016	0.018	0.019	0.021
12	0.021	0.021	0.021	0.023	0.018	0.018	0.023
13	0.018	0.018	0.016	0.018	0.023	0.027	0.027
14	0.023	0.030	0.032	0.030	0.030	0.030	0.032
15	0.028	0.030	0.030	0.028	0.025	0.027	0.030
16	0.025	0.027	0.027	0.021	0.021	0.021	0.027
17	0.023	0.023	0.023	0.019	0.018	0.019	0.023
18	0.019	0.019	0.019	0.016	0.018	0.018	0.019
19	0.016	0.016	0.016	0.018	0.014	0.018	0.018
20	0.014	0.014	0.018	0.016	0.016	0.016	0.018
21	0.016	0.016	0.018	0.016	0.018	0.016	0.018
22	0.016	0.018	0.018	0.018	0.016	0.016	0.018
23	0.016	0.016	0.016	0.014	0.018	0.016	0.018
24	Offline	Offline	Offline	Offline	Offline	Offline	Offline
25	Offline	Offline	Offline	Offline	Offline	Offline	Offline
26	Offline	Offline	Offline	Offline	Offline	Offline	Offline
27	Offline	Offline	Offline	Offline	Offline	Offline	Offline
28	0.023	0.023	0.023	0.023	0.016	0.018	0.023
29	0.019	0.021	0.018	0.016	0.018	0.018	0.021
30	0.018	0.018	0.016	0.016	0.016	0.018	0.018
31	0.018	0.018	0.016	0.016	0.018	0.016	0.018

95% of daily turbidity readings $\leq$ 1 NTU? <input checked="" type="checkbox"/> Yes/No turbidity readings $<$ 5 NTU? <input checked="" type="checkbox"/> Yes/No	All daily	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes/No	All Cl2 residual at entry point 0.2 mg/l? <input checked="" type="checkbox"/> Yes/No
--	-----------	--	--

Notes:	Printed Name: Leonard Whiteman T-09364
	Signature 
	Phone # 503-965-6636

OHA - Drinking Water Program - Surface Quality Data Form

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-:C Month/Year 12/2022								
Day	Minimum CL2 residual at 1st User C3 [ppm or mg/l]	Contact Time Minutes	Actual CT	Temp deg C	pH	Required CT Use Tables	CT Met? Yes / No	Peak Hourly Demand Flow GPM
1	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
2	1.90	36.0	68.40	8.00	6.98	24.2	YES	700
3	1.80	36.0	64.80	9.06	7.03	22.7	YES	700
4	1.88	36.0	67.68	8.02	7.05	24.7	YES	700
5	1.89	36.0	68.04	8.77	7.05	23.5	YES	700
6	1.85	36.0	66.60	8.71	7.03	23.4	YES	700
7	1.84	36.0	66.24	9.31	7.04	22.5	YES	700
8	1.71	36.0	61.56	8.96	6.99	22.3	YES	700
9	1.97	36.0	70.92	9.73	7.05	22.3	YES	700
10	1.72	36.0	61.92	11.89	7.11	19.2	YES	700
11	1.56	36.0	56.16	12.60	7.07	17.5	YES	700
12	1.61	36.0	57.96	11.54	6.79	17.4	YES	700
13	1.98	36.0	71.28	8.96	6.72	20.9	YES	700
14	1.91	36.0	68.76	8.16	6.71	21.8	YES	700
15	1.90	36.0	68.40	8.30	6.76	21.9	YES	700
16	1.87	36.0	67.32	7.84	6.75	22.5	YES	700
17	1.91	36.0	68.76	7.70	6.77	22.9	YES	700
18	1.82	36.0	65.52	9.08	6.74	20.5	YES	700
19	1.77	36.0	63.72	8.50	6.75	21.3	YES	700
20	1.74	36.0	62.64	8.85	6.72	20.5	YES	700
21	1.63	36.0	58.68	8.51	6.73	20.8	YES	700
22	1.82	36.0	65.52	5.94	6.79	25.7	YES	700
23	1.85	36.0	66.60	6.65	6.78	24.5	YES	700
24	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
25	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
26	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
27	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
28	1.13	36.0	40.68	13.24	6.78	14.3	YES	700
29	1.63	36.0	58.68	11.42	6.74	17.3	YES	700
30	1.88	36.0	67.68	10.60	6.71	18.5	YES	700
31	1.93	36.0	69.48	10.64	6.77	19.0	YES	700