


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Tillamook
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP:-C Month/Year: 01/2023

Day	12:00 AM	4:00 AM	8:00 AM	NOON	4PM	8:00 PM	Highest Reading of
1	0.018	0.018	0.016	0.016	0.018	0.016	0.018
2	0.016	0.016	0.018	0.018	0.016	0.014	0.018
3	0.016	0.016	0.016	0.018	0.018	0.019	0.019
4	0.018	0.016	0.018	0.019	0.016	0.016	0.019
5	0.018	0.016	0.016	0.016	0.019	0.019	0.019
6	0.019	0.021	0.021	0.025	0.018	0.016	0.025
7	0.016	0.018	0.016	0.016	0.016	0.018	0.018
8	0.018	0.018	0.018	0.016	0.018	0.016	0.018
9	0.016	0.018	0.016	0.016	0.016	0.019	0.019
10	0.018	0.018	0.018	0.016	0.016	0.019	0.019
11	0.016	0.018	0.018	0.018	0.018	0.018	0.018
12	0.018	0.018	0.016	0.018	0.018	0.016	0.018
13	0.018	0.018	0.016	0.018	0.018	0.018	0.018
14	0.018	0.018	0.018	0.018	0.018	0.018	0.018
15	0.016	0.018	0.018	0.016	0.018	0.016	0.018
16	0.014	0.016	0.016	0.016	0.018	0.018	0.018
17	0.016	0.018	0.018	0.018	0.018	0.016	0.018
18	0.018	0.018	0.018	0.018	0.021	0.019	0.021
19	0.023	0.025	0.018	0.018	0.018	0.016	0.025
20	0.019	0.018	0.016	0.016	0.018	0.018	0.019
21	0.016	0.018	0.016	0.019	0.018	0.018	0.019
22	0.018	0.018	0.016	0.018	0.019	0.018	0.019
23	0.018	0.018	0.016	0.016	0.018	0.018	0.018
24	0.019	0.018	0.018	0.019	0.018	0.018	0.019
25	0.016	0.018	0.018	0.018	0.016	0.016	0.018
26	0.016	0.018	0.019	0.018	0.016	0.016	0.019
27	0.018	0.016	0.019	0.018	0.018	0.016	0.019
28	0.018	0.016	0.018	0.018	0.016	0.018	0.018
29	0.016	0.019	0.018	0.018	0.016	0.018	0.019
30	0.018	0.019	0.018	0.016	0.016	0.014	0.019
31	0.014	0.016	0.014	0.014	0.016	0.012	0.016

95% of daily turbidity readings \leq 1 NTU? <input checked="" type="radio"/> Yes/No turbidity readings $<$ 5 NTU? <input checked="" type="radio"/> Yes/No	All daily	CT's met everyday? (see back) <input checked="" type="radio"/> Yes/No	All Cl2 residual at entry point 0.2 mg/l? <input checked="" type="radio"/> Yes/No
--	-----------	---	---

Notes:	Printed Name: Leonard Whiteman T-09864
	Signature: 
	Phone # 503-965-6636

OHA - Drinking Water Program - Surface Quality Data Form

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-:C Month/Year 01/2023								
Day	Minimum CL2 residual at 1st User C3	Contact Time	Actual CT	Temp	pH	Required CT	CT Met?	Peak Hourly Demand Flow
	[ppm or mg/l]	Minutes		deg C		Use Tables	Yes / No	GPM
1	1.93	36.0	69.48	9.87	6.79	20.1	YES	700
2	1.98	36.0	71.28	9.13	6.82	21.4	YES	700
3	1.94	36.0	69.84	10.17	6.83	20.0	YES	700
4	1.90	36.0	68.40	10.00	6.84	20.2	YES	700
5	1.81	36.0	65.16	11.68	6.84	17.9	YES	700
6	1.74	36.0	62.64	12.53	6.86	16.6	YES	700
7	1.70	36.0	61.20	10.28	6.78	19.0	YES	700
8	1.73	36.0	62.28	10.04	6.80	19.5	YES	700
9	1.79	36.0	64.44	10.36	6.84	19.5	YES	700
10	1.84	36.0	66.24	9.68	6.83	20.4	YES	700
11	1.81	36.0	65.16	10.26	6.85	19.7	YES	700
12	1.72	36.0	61.92	10.64	6.81	18.8	YES	700
13	1.76	36.0	63.36	11.18	6.81	18.2	YES	700
14	1.84	36.0	66.24	10.73	6.84	19.1	YES	700
15	1.74	36.0	62.64	10.02	6.81	19.6	YES	700
16	1.67	36.0	60.12	10.18	6.81	19.2	YES	700
17	1.70	36.0	61.20	9.81	6.81	19.8	YES	700
18	1.76	36.0	63.36	11.87	6.83	17.5	YES	700
19	1.70	36.0	61.20	11.46	6.85	18.0	YES	700
20	1.83	36.0	65.88	9.81	6.85	20.3	YES	700
21	1.93	36.0	69.48	9.45	6.94	21.7	YES	700
22	1.86	36.0	66.96	10.12	6.92	20.5	YES	700
23	1.86	36.0	66.96	9.90	6.90	20.7	YES	700
24	1.81	36.0	65.16	11.55	6.80	17.8	YES	700
25	1.74	36.0	62.64	9.69	6.74	19.5	YES	700
26	1.76	36.0	63.36	9.35	6.78	20.3	YES	700
27	1.77	36.0	63.72	10.47	6.81	19.1	YES	700
28	1.70	36.0	61.20	9.99	6.78	19.3	YES	700
29	1.74	36.0	62.64	8.34	6.79	21.7	YES	700
30	1.80	36.0	64.80	7.86	6.84	23.0	YES	700
31	1.80	36.0	64.80	7.77	6.84	23.1	YES	700