

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Tillamook
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-:C Month/Year: 04/2023

Day	12:00 AM	4:00 AM	8:00 AM	NOON	4PM	8:00 PM	Highest Reading of
1	0.019	0.019	0.018	0.019	0.018	0.018	0.019
2	0.019	0.018	0.019	0.018	0.019	0.018	0.019
3	0.019	0.019	0.019	0.018	0.018	0.018	0.019
4	0.019	0.019	0.021	0.018	0.019	0.021	0.021
5	0.019	0.018	0.018	0.019	0.019	0.019	0.019
6	0.018	0.021	0.018	0.014	0.016	0.014	0.021
7	0.016	0.014	0.014	0.016	0.016	0.016	0.016
8	0.014	0.014	0.014	0.014	0.014	0.014	0.014
9	Offline	Offline	Offline	Offline	Offline	Offline	Offline
10	Offline	Offline	Offline	Offline	Offline	Offline	Offline
11	Offline	Offline	Offline	Offline	Offline	Offline	Offline
12	Offline	Offline	Offline	Offline	Offline	Offline	Offline
13	0.018	0.019	0.019	0.014	0.014	0.014	0.019
14	0.014	0.014	0.014	0.016	0.016	0.014	0.016
15	0.014	0.014	0.012	0.014	0.014	0.014	0.014
16	Offline	Offline	Offline	Offline	Offline	Offline	Offline
17	0.018	0.021	0.021	0.032	0.014	0.018	0.032
18	0.014	0.014	0.018	0.018	0.016	0.014	0.018
19	0.016	0.016	0.016	0.014	0.021	0.018	0.021
20	0.018	0.019	0.018	0.014	0.016	0.014	0.019
21	0.014	0.012	0.011	0.012	0.012	0.014	0.014
22	0.014	0.012	0.012	0.012	0.012	0.012	0.014
23	0.012	0.012	0.012	0.012	0.012	0.012	0.012
24	0.012	0.012	0.012	0.012	0.012	0.012	0.012
25	0.012	0.012	0.012	0.012	0.012	0.014	0.014
26	0.012	0.014	0.012	0.012	0.012	0.014	0.014
27	0.012	0.012	0.014	0.012	0.012	0.014	0.014
28	0.012	0.012	0.012	0.014	0.012	0.012	0.014
29	0.012	0.012	0.012	0.012	0.012	0.012	0.012
30	0.012	0.012	0.012	0.012	0.012	0.012	0.012

95% of daily turbidity readings < 1 NTU? <input checked="" type="radio"/> Yes/No turbidity readings < 5 NTU? <input checked="" type="radio"/> Yes/No	All daily	CT's met everyday? (see back) <input checked="" type="radio"/> Yes/No	All Cl2 residual at entry point 0.2 mg/l? <input checked="" type="radio"/> Yes/No
---	-----------	---	---

Notes:	Printed Name: Leonard Whiteman T-09364
	Signature 
	Phone # 503-965-6636

OHA - Drinking Water Program - Surface Quality Data Form

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP:-:C Month/Year 04/2023								
Day	Minimum CL2 residual at 1st User C3	Contact Time Minutes	Actual CT	Temp deg C	pH	Required CT Use Tables	CT Met? Yes / No	Peak Hourly Demand Flow GPM
1	1.58	36.0	56.88	9.53	6.76	19.5	YES	700
2	1.65	36.0	59.40	9.73	6.79	19.6	YES	700
3	1.61	36.0	57.96	8.97	6.78	20.5	YES	700
4	1.72	36.0	61.92	10.00	6.82	19.6	YES	700
5	1.65	36.0	59.40	9.38	6.80	20.2	YES	700
6	1.58	36.0	56.88	10.10	6.75	18.8	YES	700
7	1.46	36.0	52.56	11.26	6.72	17.0	YES	700
8	1.59	36.0	57.24	10.43	6.76	18.4	YES	700
9	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
10	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
11	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
12	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
13	1.50	36.0	54.00	11.73	6.71	16.5	YES	700
14	1.75	36.0	63.00	10.55	6.75	18.6	YES	700
15	1.75	36.0	63.00	10.63	6.78	18.7	YES	700
16	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
17	1.56	36.0	56.16	12.47	6.74	16.0	YES	700
18	1.58	36.0	56.88	10.03	6.67	18.3	YES	700
19	1.66	36.0	59.76	10.01	6.65	18.4	YES	700
20	1.68	36.0	60.48	10.44	6.69	18.2	YES	700
21	1.74	36.0	62.64	10.38	6.70	18.4	YES	700
22	1.79	36.0	64.44	11.33	6.67	17.3	YES	700
23	1.66	36.0	59.76	11.10	6.69	17.4	YES	700
24	1.61	36.0	57.96	11.50	6.72	17.0	YES	700
25	1.64	36.0	59.04	11.22	6.77	17.7	YES	700
26	1.63	36.0	58.68	11.89	6.71	16.6	YES	700
27	1.59	36.0	57.24	13.83	6.69	14.0	YES	700
28	1.62	36.0	58.32	12.75	6.66	15.0	YES	700
29	1.70	36.0	61.20	11.93	6.71	16.7	YES	700
30	1.68	36.0	60.48	12.12	6.80	16.9	YES	700