

OHA - Drinking Water Program

County: TILLAMOOK


Month/Year: Jun-22

System Name: Tierra Del Mar Water Co WTP ID: 41-00610-A

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	16.00	10.00	6.00	10.00	0.047	.05
2	11.00	7.00	4.00	10.00	0.042	.04
3	16.00	10.00	6.00	10.00	0.031	.03
4	12.00	7.00	5.00	10.00	0.041	.04
5	12.00	7.00	5.00	10.00	0.062	.06
6	12.00	7.00	5.00	10.00	0.038	.04
7	12.00	7.00	5.00	10.00	0.035	.04
8	14.00	9.00	5.00	10.00	0.028	.03
9	24.00	18.00	6.00	10.00	0.030	.03
10	24.00	19.00	5.00	10.00	0.093	.09
11	11.00	6.00	5.00	10.00	0.055	.06
12	25.00	20.00	5.00	10.00	0.039	.04
13	25.00	20.00	5.00	10.00	0.036	.04
14	25.00	20.00	5.00	10.00	0.047	.05
15	18.00	12.00	6.00	10.00	0.035	.04
16	20.00	14.00	6.00	10.00	0.039	.04
17	15.00	10.00	5.00	10.00	0.036	.04
18	26.00	20.00	6.00	10.00	0.039	.04
19	26.00	20.00	6.00	10.00	0.034	.03
20	26.00	20.00	6.00	10.00	0.036	.04
21	23.00	18.00	5.00	10.00	0.033	.03
22	15.00	9.00	6.00	10.00	0.044	.04
23	15.00	9.00	6.00	10.00	0.041	.04
24	15.00	9.00	6.00	10.00	0.040	.04
25	18.00	12.00	6.00	10.00	0.033	.03
26	14.00	8.00	6.00	10.00	0.035	.04
27	25.00	18.00	7.00	10.00	0.078	.08
28	12.00	5.00	7.00	10.00	0.034	.03
29	18.00	12.00	6.00	10.00	0.044	.04
30	22.00	16.00	6.00	10.00	0.047	.05
31						

Cartridge & Bag Filtration 95% of daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No	
--	--	---	--

Notes: PSI = pounds per square inch
 PSID = pounds per square inch difference (before filter - after filter)
 PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

JASON L. GREEN
 SIGNATURE:  DATE: 7/7/22
 PHONE #: (503) 965-5140 CERT #: 5186

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: Tierra Del Mar Water Co

ID#: 41 00610

Month/Year: 44713

Disinfection *Giardia*
Log Inactiv:

1

Date / Time	Residual at 1st User (C) <small>2Minimum Cl₂</small> Residual at 1st [ppm or mg/L]	Contact Time (T)Contact Time (T)Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ² 2CT Met? ² 2CT Met? ² Yes / No	Peak Hourly Demand Flow [GPM]
1	0.80	181	144.4	13.0	7.500	36.6	YES	25
2	0.90	238	213.8	13.0	7.500	37.0	YES	19
3	0.90	181	162.5	13.0	7.500	37.0	YES	25
4	0.90	188	169.3	13.0	7.500	37.0	YES	24
5	0.80	226	180.6	13.0	7.500	36.6	YES	20
6	0.90	150	135.4	13.0	7.500	37.0	YES	30
7	0.80	181	144.4	13.0	7.500	36.6	YES	25
8	0.70	167	117.0	14.0	7.500	33.9	YES	27
9	0.80	161	129.0	14.0	7.500	34.3	YES	28
10	0.80	196	157.0	14.0	7.500	34.3	YES	23
11	0.70	174	121.5	14.0	7.500	33.9	YES	26
12	0.60	167	100.3	14.0	7.500	33.5	YES	27
13	0.60	156	93.4	14.0	7.500	33.5	YES	29
14	0.80	167	133.7	14.0	7.500	34.3	YES	27
15	0.50	174	86.8	14.0	7.500	33.1	YES	26
16	0.90	181	162.5	14.0	7.500	34.6	YES	25
17	0.90	150	135.4	14.0	7.500	34.6	YES	30
18	0.90	167	150.5	14.0	7.500	34.6	YES	27
19	0.80	161	129.0	14.0	7.500	34.3	YES	28
20	0.90	122	109.8	14.0	7.500	34.6	YES	37
21	0.80	156	124.5	14.0	7.500	34.3	YES	29
22	0.90	150	135.4	14.0	7.500	34.6	YES	30
23	0.80	167	133.7	14.0	7.500	34.3	YES	27
24	0.80	137	109.4	14.0	7.500	34.3	YES	33
25	0.90	129	116.1	14.0	7.500	34.6	YES	35
26	0.80	105	84.0	14.0	7.500	34.3	YES	43
27	0.80	89	70.8	15.0	7.500	32.0	YES	51
28	0.80	129	103.2	16.0	7.500	30.0	YES	35
29	0.80	161	129.0	16.0	7.500	30.0	YES	28
30	0.80	161	129.0	16.0	7.500	30.0	YES	28
31								

² If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012