


OHA - Drinking Water Program

County: TILLAMOOK

Month/Year: Jul-22

System Name: Tierra Del Mar Water Co WTP ID: 41-00610-A

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	22.00	19.00	3.00	10.00	0.046	0.05
2	25.00	19.00	6.00	10.00	0.042	0.05
3	22.00	19.00	3.00	10.00	0.043	0.05
4	30.00	24.00	6.00	10.00	0.041	0.05
5	24.00	18.00	6.00	10.00	0.040	0.04
6	25.00	19.00	6.00	10.00	0.041	0.05
7	25.00	19.00	6.00	10.00	0.043	0.05
8	18.00	10.00	8.00	10.00	0.045	0.05
9	26.00	19.00	7.00	10.00	0.042	0.05
10	25.00	18.00	7.00	10.00	0.044	0.05
11	25.00	18.00	7.00	10.00	0.041	0.05
12	24.00	19.00	5.00	10.00	0.040	0.04
13	22.00	19.00	3.00	10.00	0.042	0.05
14	25.00	18.00	7.00	10.00	0.045	0.05
15	25.00	18.00	7.00	10.00	0.043	0.05
16	25.00	18.00	7.00	10.00	0.046	0.05
17	25.00	18.00	7.00	10.00	0.042	0.05
18	26.00	19.00	7.00	10.00	0.043	0.05
19	16.00	10.00	6.00	10.00	0.042	0.05
20	12.00	4.00	8.00	10.00	0.043	0.05
21	26.00	19.00	7.00	10.00	0.043	0.05
22	12.00	4.00	8.00	10.00	0.047	0.05
23	18.00	11.00	7.00	10.00	0.047	0.05
24	18.00	11.00	7.00	10.00	0.045	0.05
25	20.00	14.00	6.00	10.00	0.046	0.05
26	20.00	14.00	6.00	10.00	0.046	0.05
27	21.00	14.00	7.00	10.00	0.046	0.05
28	21.00	14.00	7.00	10.00	0.046	0.05
29	22.00	14.00	8.00	10.00	0.044	0.05
30	22.00	14.00	8.00	10.00	0.043	0.05
31	22.00	14.00	8.00	10.00	0.044	0.05

<p>Cartridge & Bag Filtration</p> <p>95% of daily turbidity readings ≤ 1 NTU? <input type="radio"/> Yes / <input type="radio"/> No</p> <p>All daily turbidity readings ≤ 5 NTU? <input type="radio"/> Yes / <input type="radio"/> No</p>		<p>Monthly Summary (Answer Yes or No)</p> <p>CT's met everyday? (see back) <input type="radio"/> Yes / <input type="radio"/> No</p> <p>All Cl2 residual at entry point ≥ 0.2 mg/l? <input type="radio"/> Yes / <input type="radio"/> No</p>	
<p>Notes: PSI = pounds per square inch</p> <p>PSID = pounds per square inch difference (before filter - after filter)</p> <p>PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.</p>		<p>JASON L. GREEN</p> <p>SIGNATURE: </p> <p>DATE: 16 Aug 22</p> <p>PHONE #: (503)965-5140</p> <p>CERT #: 5186</p>	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP- :

System Name:	Tierra Del Mar Water Co	ID#: 41	00610	Month/Year:	44743	Disinfection <i>Giardia</i> Log Inactiv:	1
--------------	-------------------------	---------	-------	-------------	-------	--	---

Date / Time	Residual at 1st User (C) 2Minimum Cl ₂ Residual at 1st	Contact Time (T)Contact Time (T)Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 2CT Met? 2CT Met? 2	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.90	161	145.1	14.0	7.500	34.6	YES	28
2	0.90	150	135.4	15.0	7.500	32.4	YES	30
3	0.90	122	109.8	15.0	7.400	31.2	YES	37
4	0.70	94	65.8	15.0	7.500	31.7	YES	48
5	0.80	98	78.5	16.0	7.400	28.9	YES	46
6	0.80	119	95.0	14.0	7.500	34.3	YES	38
7	0.70	119	83.2	14.0	7.500	33.9	YES	38
8	0.70	119	83.2	15.0	7.500	31.7	YES	38
9	0.90	137	123.1	16.0	7.500	30.3	YES	33
10	0.70	137	95.8	16.0	7.500	29.6	YES	33
11	0.70	105	73.5	16.0	7.500	29.6	YES	43
12	0.70	116	81.0	16.0	7.500	29.6	YES	39
13	0.90	137	123.1	15.0	7.500	32.4	YES	33
14	0.90	110	99.1	14.0	7.500	34.6	YES	41
15	0.50	133	66.4	15.0	7.500	31.0	YES	34
16	0.70	110	77.1	16.0	7.500	29.6	YES	41
17	0.80	129	103.2	16.0	7.500	30.0	YES	35
18	0.90	100	90.3	15.0	7.500	32.4	YES	45
19	0.70	129	90.3	15.0	7.500	31.7	YES	35
20	0.90	133	119.5	14.0	7.500	34.6	YES	34
21	0.70	122	85.4	14.0	7.500	33.9	YES	37
22	0.90	133	119.5	15.0	7.500	32.4	YES	34
23	0.80	133	106.2	14.0	7.500	34.3	YES	34
24	0.80	125	100.3	15.0	7.500	32.0	YES	36
25	0.70	119	83.2	14.0	7.500	33.9	YES	38
26	0.70	119	83.2	15.0	7.500	31.7	YES	38
27	0.80	119	95.0	14.0	7.500	34.3	YES	38
28	0.70	119	83.2	14.0	7.500	33.9	YES	38
29	0.80	107	86.0	15.0	7.500	32.0	YES	42
30	0.70	113	79.0	15.0	7.500	31.7	YES	40
31	0.70	100	70.2	15.0	7.500	31.7	YES	45

² If Cl2 at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012