

OHA - Drinking Water Program

County: TILLAMOOK

Month/Year: June 2023

System Name: Tierra Del Mar Water Co

WTP ID: 41-00610-A

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	14.00	13.00	1.00	10.00	0.028	.03
2	13.00	12.00	1.00	10.00	0.031	.03
3	14.00	13.00	1.00	10.00	0.038	.04
4	13.00	12.00	1.00	10.00	0.039	.04
5	13.00	12.00	1.00	10.00	0.031	.03
6	12.00	11.00	1.00	10.00	0.027	.03
7	12.00	11.00	1.00	10.00	0.036	.04
8	18.00	17.00	1.00	10.00	0.031	.03
9	13.00	12.00	1.00	10.00	0.030	.03
10	13.00	12.00	1.00	10.00	0.036	.04
11	13.00	12.00	1.00	10.00	0.041	.04
12	12.00	11.00	1.00	10.00	0.041	.04
13	13.00	12.00	1.00	10.00	0.036	.04
14	14.00	13.00	1.00	10.00	0.044	.04
15	12.00	11.00	1.00	10.00	0.045	.05
16	14.00	12.00	2.00	10.00	0.028	.03
17	14.00	12.00	2.00	10.00	0.034	.03
18	20.00	19.00	1.00	10.00	0.034	.03
19	20.00	19.00	1.00	10.00	0.034	.03
20	20.00	19.00	1.00	10.00	0.043	.04
21	20.00	18.00	2.00	10.00	0.043	.04
22	25.00	24.00	1.00	10.00	0.043	.04
23	20.00	18.00	2.00	10.00	0.043	.04
24	20.00	18.00	2.00	10.00	0.017	.02
25	20.00	18.00	2.00	10.00	0.026	.03
26	20.00	18.00	2.00	10.00	0.019	.02
27	18.00	17.00	1.00	10.00	0.029	.04
28	18.00	18.00	0.00	10.00	0.032	.04
29	19.00	18.00	1.00	10.00	0.040	.05
30	17.00	17.00	0.00	10.00	0.039	.05
31						

Cartridge & Bag Filtration

95% of daily turbidity readings ≤ 1 NTU?

Yes No

All daily turbidity readings ≤ 5 NTU?

Yes No

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back)

Yes No

All Cl2 residual at entry point ≥ 0.2 mg/l?

Yes No

Notes: PSI = pounds per square inch

PSID = pounds per square inch difference (before filter - after filter)

PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

JASON L. GREEN

SIGNATURE: *[Signature]*

DATE: 7/10/23

PHONE #: (503)965-5140

CERT #: 5186

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

