


OHA - Drinking Water Program						County:	TILLAMOOK
						Month/Year:	SEPTEMBER 2023
System Name: Tierra Del Mar Water Co				WTP ID: 41-00610-A			
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU] Highest Reading of the day ¹ [NTU]	
1	20.00	20.00	0.00	10.00	0.052	.07	
2	22.00	20.00	2.00	10.00	0.040	.06	
3	20.00	20.00	0.00	10.00	0.051	.06	
4	20.00	18.00	2.00	10.00	0.063	.06	
5	20.00	20.00	0.00	10.00	0.055	.06	
6	14.00	12.00	2.00	10.00	0.043	.06	
7	14.00	12.00	2.00	10.00	0.061	.07	
8	10.00	9.00	1.00	10.00	0.029	.05	
9	12.00	11.00	1.00	10.00	0.039	.05	
10	12.00	11.00	1.00	10.00	0.040	.06	
11	13.00	12.00	1.00	10.00	0.036	.05	
12	20.00	18.00	2.00	10.00	0.030	.05	
13	12.00	11.00	1.00	10.00	0.059	.07	
14	12.00	11.00	1.00	10.00	0.067	.07	
15	12.00	11.00	1.00	10.00	0.045	.06	
16	12.00	11.00	1.00	10.00	0.034	.05	
17	12.00	11.00	1.00	10.00	0.041	.06	
18	10.00	9.00	1.00	10.00	0.061	.06	
19	13.00	12.00	1.00	10.00	0.038	.04	
20	13.00	12.00	1.00	10.00	0.044	.04	
21	11.00	10.00	1.00	10.00	0.035	.04	
22	10.00	8.00	2.00	10.00	0.033	.05	
23	10.00	8.00	2.00	10.00	0.029	.03	
24	11.00	10.00	1.00	10.00	0.035	.04	
25	11.00	10.00	1.00	10.00	0.037	.04	
26	10.00	8.00	2.00	10.00	0.095	.10	
27	11.00	10.00	1.00	10.00	0.029	.03	
28	0.00	0.00	0.00	10.00	0.052	.05	
29	12.00	10.00	2.00	10.00	0.052	.05	
30	13.00	12.00	1.00	10.00	0.025	.03	
Cartridge & Bag Filtration					Monthly Summary (Answer Yes or No)		
95% of daily turbidity readings ≤ 1 NTU?				<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?	
All daily turbidity readings ≤ 5 NTU?				<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	
Notes: PSI = pounds per square inch					JASON L. GREEN		
PSID = pounds per square inch difference (before filter - after filter)					SIGNATURE: 		DATE: 10-09-23
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.					PHONE #: (503) 965-5140		CERT #: 5186
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.							

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: Tierra Del Mar Water Co ID#: 41 00610 Month/Year: SEPTEMBER 2023 Disinfection *Giardia* Log Inactiv: 1

Date / Time	Residual at 1st User (C) 2Minimum Cl ₂ Residual at 1st	Contact Time (T) Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 2CT Met? 2CT Met? 2CT Met? 2CT Met? 2CT Met? Met? 2CT Met? 2	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.70	226	158.0	15.0	7.500	31.7	YES	20
2	0.80	205	164.1	15.0	7.500	32.0	YES	22
3	0.70	141	98.7	16.0	7.600	30.8	YES	32
4	0.60	150	90.3	16.0	7.700	31.6	YES	30
5	0.70	125	87.8	15.0	7.600	32.9	YES	36
6	0.60	196	117.8	15.0	7.600	32.5	YES	23
7	0.80	251	200.6	15.0	7.600	33.3	YES	18
8	0.70	188	131.7	14.0	7.600	35.1	YES	24
9	0.90	196	176.6	14.0	7.600	36.0	YES	23
10	0.80	167	133.7	14.0	7.600	35.5	YES	27
11	0.90	137	123.1	14.0	7.500	34.6	YES	33
12	0.80	226	180.6	14.0	7.500	34.3	YES	20
13	0.70	205	143.6	14.0	7.500	33.9	YES	22
14	0.90	188	169.3	15.0	7.500	32.4	YES	24
15	0.50	196	98.1	15.0	7.500	31.0	YES	23
16	0.70	125	87.8	15.0	7.500	31.7	YES	36
17	0.90	167	150.5	14.0	7.500	34.6	YES	27
18	0.90	150	135.4	15.0	7.500	32.4	YES	30
19	0.80	181	144.4	14.0	7.500	34.3	YES	25
20	0.90	205	184.7	14.0	7.500	34.6	YES	22
21	0.80	196	157.0	15.0	7.500	32.0	YES	23
22	0.80	226	180.6	14.0	7.500	34.3	YES	20
23	0.90	251	225.7	14.0	7.500	34.6	YES	18
24	0.80	226	180.6	14.0	7.500	34.3	YES	20
25	0.90	215	193.5	14.0	7.500	34.6	YES	21
26	0.80	282	225.7	14.0	7.500	34.3	YES	16
27	0.80	266	212.4	14.0	7.500	34.3	YES	17
28	0.80	301	240.7	14.0	7.500	34.3	YES	15
29	0.90	282	253.9	14.0	7.500	34.6	YES	16
30	0.90	266	239.0	14.0	7.500	34.6	YES	17

² If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012