


OHA - Drinking Water Program					County:	TILLAMOOK
					Month/Year:	October 2023
System Name:	Tierra Del Mar Water Co				WTP ID: 41-00610-A	
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day <sup>1</sup> [NTU] Highest Reading of the day <sup>1</sup> [NTU]
1	12.00	10.00	2.00	10.00	0.031	.03
2	12.00	10.00	2.00	10.00	0.036	.04
3	12.00	10.00	2.00	10.00	0.086	.09
4	14.00	12.00	2.00	10.00	0.054	.05
5	14.00	12.00	2.00	10.00	0.053	.05
6	14.00	12.00	2.00	10.00	0.039	.04
7	14.00	12.00	2.00	10.00	0.031	.03
8	12.00	10.00	2.00	10.00	0.029	.03
9	12.00	10.00	2.00	10.00	0.044	.04
10	13.00	10.00	3.00	10.00	0.043	.04
11	13.00	10.00	3.00	10.00	0.044	.04
12	13.00	10.00	3.00	10.00	0.079	.08
13	16.00	12.00	4.00	10.00	0.072	.07
14	15.00	10.00	5.00	10.00	0.072	.07
15	16.00	10.00	6.00	10.00	0.064	.06
16	18.00	11.00	7.00	10.00	0.027	.03
17	18.00	11.00	7.00	10.00	0.036	.04
18	20.00	9.00	11.00	10.00	0.049	.06
19	24.00	13.00	11.00	10.00	0.024	.04
20	10.00	8.00	2.00	10.00	0.047	.06
21	10.00	8.00	2.00	10.00	0.043	.06
22	10.00	8.00	2.00	10.00	0.040	.06
23	10.00	9.00	1.00	10.00	0.042	.06
24	10.00	9.00	1.00	10.00	0.033	.05
25	10.00	8.00	2.00	10.00	0.062	.08
26	14.00	13.00	1.00	10.00	0.051	.07
27	10.00	9.00	1.00	10.00	0.039	.05
28	10.00	9.00	1.00	10.00	0.039	.05
29	12.00	11.00	1.00	10.00	0.028	.05
30	10.00	9.00	1.00	10.00	0.037	.05
31	10.00	8.00	2.00	10.00	0.027	.04

Cartridge & Bag Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No

Notes: PSI = pounds per square inch  
PSID = pounds per square inch difference (before filter - after filter)  
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

JASON L. GREEN	DATE: 11/2/2023
SIGNATURE: 	CERT #: 5186
PHONE #: ( 503 )965-5140	

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP- :

System Name:	Tierra Del Mar Water Co	ID#:	41 00610	Month/Year:	October 2023	Disinfection <i>Giardia</i> Log Inactiv:	1	
Date / Time	Residual at 1st User (C) <small>2</small> Minimum Cl <sub>2</sub> Residual at 1st User (C)	Contact Time (T)Contact Time (T)Contact Time	Actual CT	Temp	pH	Required CT	CT Met? Met? 2CT Met? 2CT Met? 2CT Met? 2CT Met? 2CT Met? Met? 2CT Met? 2	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.10	205	225.7	14.0	7.500	35.4	YES	22
2	0.90	196	176.6	14.0	7.500	34.6	YES	23
3	0.80	251	200.6	14.0	7.500	34.3	YES	18
4	0.60	301	180.6	14.0	7.500	33.5	YES	15
5	0.70	301	210.7	14.0	7.500	33.9	YES	15
6	0.80	266	212.4	15.0	7.500	32.0	YES	17
7	0.80	266	212.4	15.0	7.500	32.0	YES	17
8	0.90	266	239.0	15.0	7.500	32.4	YES	17
9	0.90	167	150.5	15.0	7.500	32.4	YES	27
10	0.80	238	190.1	15.0	7.500	32.0	YES	19
11	0.70	282	197.5	15.0	7.500	31.7	YES	16
12	0.50	282	141.1	15.0	7.500	31.0	YES	16
13	0.70	282	197.5	15.0	7.500	31.7	YES	16
14	0.60	251	150.5	15.0	7.500	31.3	YES	18
15	0.50	188	94.0	15.0	7.500	31.0	YES	24
16	0.80	196	157.0	15.0	7.500	32.0	YES	23
17	0.60	301	180.6	15.0	7.500	31.3	YES	15
18	0.60	301	180.6	15.0	7.500	31.3	YES	15
19	0.80	301	240.7	14.0	7.500	34.3	YES	15
20	0.60	301	180.6	14.0	7.700	36.1	YES	15
21	0.80	301	240.7	14.0	7.600	35.5	YES	15
22	0.80	226	180.6	14.0	7.600	35.5	YES	20
23	0.80	251	200.6	14.0	7.600	35.5	YES	18
24	0.80	301	240.7	13.0	7.700	39.4	YES	15
25	0.70	301	210.7	13.0	7.700	39.0	YES	15
26	0.80	301	240.7	11.0	7.700	45.1	YES	15
27	0.60	266	159.3	11.0	7.700	44.1	YES	17
28	0.60	301	180.6	10.0	7.600	45.5	YES	15
29	0.80	251	200.6	10.0	7.560	45.9	YES	18
30	0.70	251	175.5	10.0	7.500	44.4	YES	18
31	0.50	282	141.1	10.0	7.500	43.4	YES	16

<sup>2</sup> If Cl2 at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012