


OHA - Drinking Water Program					County:	TILLAMOOK
					Month/Year:	March 2023
System Name:	Tierra Del Mar Water Co			WTP ID: 41-00610-A		
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU] Highest Reading of the day ¹ [NTU]
1	12.00	11.00	1.00	10.00	0.067	.07
2	16.00	15.00	1.00	10.00	0.054	.05
3	12.00	11.00	1.00	10.00	0.039	.04
4	12.00	11.00	1.00	10.00	0.041	.04
5	13.00	12.00	1.00	10.00	0.038	.04
6	18.00	17.00	1.00	10.00	0.030	.04
7	18.00	17.00	1.00	10.00	0.031	.05
8	12.00	11.00	1.00	10.00	0.029	.03
9	18.00	17.00	1.00	10.00	0.030	.03
10	12.00	11.00	1.00	10.00	0.030	.03
11	12.00	11.00	1.00	10.00	0.029	.03
12	14.00	13.00	1.00	10.00	0.054	.05
13	19.00	18.00	1.00	10.00	0.030	.05
14	12.00	11.00	1.00	10.00	0.058	.07
15	12.00	11.00	1.00	10.00	0.028	.04
16	12.00	11.00	1.00	10.00	0.033	.05
17	16.00	15.00	1.00	10.00	0.035	.05
18	12.00	11.00	1.00	10.00	0.042	.04
19	14.00	13.00	1.00	10.00	0.049	.05
20	14.00	13.00	1.00	10.00	0.073	.07
21	15.00	14.00	1.00	10.00	0.074	.07
22	15.00	14.00	1.00	10.00	0.077	.08
23	15.00	14.00	1.00	10.00	0.490	.49
24	17.00	16.00	1.00	10.00	0.240	.24
25	17.00	16.00	1.00	10.00	0.080	.08
26	17.00	16.00	1.00	10.00	0.250	.25
27	12.00	11.00	1.00	10.00	0.085	.08
28	12.00	11.00	1.00	10.00	0.122	.12
29	18.00	17.00	1.00	10.00	0.100	.12
30	18.00	17.00	1.00	10.00	0.023	.02
31	18.00	17.00	1.00	10.00	0.010	.01

Cartridge & Bag Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	Yes/No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes/No	Yes/No	Yes/No

Notes: PSI = pounds per square inch
PSID = pounds per square inch difference (before filter - after filter)
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

JASON L. GREEN	
SIGNATURE: 	DATE: 4/4/24
PHONE #: (503) 965-5140	CERT #: 5186

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not

correspond to continuous readings' maximum.

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP- :

System Name:	Tierra Del Mar Water Co	ID#: 41	00610	Month/Year:	March 2023	Disinfection <i>Giardia</i> Log Inactiv:	1
--------------	-------------------------	---------	-------	-------------	------------	---	---

Date / Time	Residual at 1st User (C) ² Minimum Cl ₂ Residual at 1st User (C)	Contact Time (T)Contact Time (T)Contact Time	Actual CT	Temp	pH	Required CT	CT Met? Met? 2CT Met? 2CT Met? 2CT Met? 2CT Met? 2CT Met? 2CT Met? 2CT	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.50	376	188.1	9.0	7.500	46.4	YES	12
2	0.60	301	180.6	9.0	7.500	46.9	YES	15
3	0.50	282	141.1	8.0	7.500	49.6	YES	16
4	0.60	266	159.3	8.0	7.500	50.2	YES	17
5	0.80	301	240.7	8.0	7.500	51.3	YES	15
6	1.00	347	347.2	8.0	7.400	50.7	YES	13
7	1.00	347	347.2	7.0	7.500	56.2	YES	13
8	1.00	347	347.2	9.0	7.600	50.9	YES	13
9	0.90	266	239.0	9.0	7.600	50.3	YES	17
10	0.90	266	239.0	9.0	7.600	50.3	YES	17
11	0.90	238	213.8	9.0	7.600	50.3	YES	19
12	0.90	251	225.7	9.0	7.600	50.3	YES	18
13	0.90	282	253.9	10.0	7.500	45.4	YES	16
14	0.90	322	290.2	8.0	7.500	51.9	YES	14
15	0.50	322	161.2	9.0	7.600	48.1	YES	14
16	0.80	251	200.6	10.0	7.500	44.9	YES	18
17	0.70	196	137.4	12.0	7.500	39.0	YES	23
18	0.80	188	150.5	11.0	7.500	42.1	YES	24
19	0.90	251	225.7	10.0	7.500	45.4	YES	18
20	0.80	301	240.7	11.0	7.500	42.1	YES	15
21	0.90	282	253.9	11.0	7.500	42.5	YES	16
22	0.90	266	239.0	11.0	7.500	42.5	YES	17
23	0.90	251	225.7	11.0	7.500	42.5	YES	18
24	0.80	226	180.6	11.0	7.500	42.1	YES	20
25	0.90	188	169.3	11.0	7.500	42.5	YES	24
26	0.80	181	144.4	11.0	7.500	42.1	YES	25
27	0.90	161	145.1	11.0	7.500	42.5	YES	28
28	0.90	188	169.3	11.0	7.500	42.5	YES	24
29	0.80	188	150.5	11.0	7.500	42.1	YES	24
30	0.90	188	169.3	11.0	7.500	42.5	YES	24
31	0.80	150	120.4	11.0	7.500	42.1	YES	30

² If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012