

OHA - Drinking Water Program					County:	TILLAMOOK
					Month/Year:	July 2024
System Name:	Tierra Del Mar Water Co				WTP ID: 41-00610-A	
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU] Highest Reading of the day ¹ [NTU]
1	32.00	31.00	1.00	10.00	0.033	.05
2	32.00	31.00	1.00	10.00	0.040	.05
3	32.00	31.00	1.00	10.00	0.012	.04
4	32.00	31.00	1.00	10.00	0.043	.05
5	15.00	14.00	1.00	10.00	0.039	.03
6	15.00	14.00	1.00	10.00	0.051	.06
7	15.00	14.00	1.00	10.00	0.042	.05
8	22.00	21.00	1.00	10.00	0.039	.05
9	25.00	24.00	1.00	10.00	0.038	.04
10	25.00	24.00	1.00	10.00	0.040	.05
11	33.00	32.00	1.00	10.00	0.029	.03
12	25.00	24.00	1.00	10.00	0.029	.03
13	25.00	24.00	1.00	10.00	0.035	.03
14	25.00	24.00	1.00	10.00	0.052	.06
15	25.00	24.00	1.00	10.00	0.039	.04
16	24.00	23.00	1.00	10.00	0.043	.05
17	24.00	23.00	1.00	10.00	0.038	.04
18	20.00	19.00	1.00	10.00	0.046	.05
19	12.00	12.00	0.00	10.00	0.048	.06
20	14.00	13.00	1.00	10.00	0.054	.06
21	33.00	32.00	1.00	10.00	0.032	.04
22	16.00	12.00	4.00	10.00	0.081	.04
23	15.00	14.00	1.00	10.00	0.025	.02
24	14.00	13.00	1.00	10.00	0.022	.02
25	15.00	14.00	1.00	10.00	0.033	.03
26	15.00	14.00	1.00	10.00	0.026	.03
27	20.00	19.00	1.00	10.00	0.034	.04
28	20.00	18.00	2.00	10.00	0.028	.03
29	20.00	18.00	2.00	10.00	0.036	.04
30	20.00	18.00	2.00	10.00	0.040	.04
31	20.00	18.00	2.00	10.00	0.043	.04

Cartridge & Bag Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	Yes / No	<input checked="" type="radio"/> Yes / <input type="radio"/> No

Notes: PSI = pounds per square inch
PSID = pounds per square inch difference (before filter - after filter)
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

JASON L. GREEN
SIGNATURE: *[Signature]* DATE: 8/7/24
PHONE #: (503) 965-5140 CERT #: 5186

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

PAGE 1 of 2

