

*For issue corrected input  
input error*

System Name:		Terra Del Mar Water Co		WTP ID: 41-00610-A				
Day		PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day <sup>1</sup> [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	19.00	19.00	16.00	3.00	10.00	0.030		.04
2	19.00	19.00	16.00	3.00	10.00	0.020		.03
3	19.00	19.00	16.00	3.00	10.00	0.022		.032
4	18.00	18.00	15.00	3.00	10.00	0.020		.03
5	17.00	17.00	14.00	3.00	10.00	0.061		.07
6	18.00	18.00	15.00	3.00	10.00	0.052		.06
7	18.00	18.00	15.00	3.00	10.00	0.020		.03
8	17.00	17.00	14.00	3.00	10.00	0.140		.03
9	14.00	14.00	8.00	6.00	10.00	0.061		.07
10	16.00	16.00	10.00	6.00	10.00	0.070		.08
11	19.00	19.00	14.00	5.00	10.00	0.050		.06
12	18.00	18.00	13.00	5.00	10.00	0.062		.07
13	18.00	18.00	14.00	4.00	10.00	0.031		.05
14	20.00	20.00	14.00	6.00	10.00	0.053		.060
15	20.00	20.00	13.00	7.00	10.00	0.017		.02
16	20.00	20.00	14.00	6.00	10.00	0.010		.02
17	21.00	21.00	13.00	8.00	10.00	0.011		.021
18	22.00	22.00	11.00	11.00	10.00	0.027		.037
19	23.00	23.00	13.00	10.00	10.00	0.021		.02
20	23.00	23.00	13.00	10.00	10.00	0.022		.02
21	13.00	13.00	10.00	3.00	10.00	0.054		.05
22	13.00	13.00	10.00	3.00	10.00	0.420		.05
23	12.00	12.00	12.00	0.00	10.00	0.140		.24
24	12.00	12.00	7.00	5.00	10.00	0.071		.08
25	13.00	13.00	9.00	4.00	10.00	0.021		.031
26	14.00	14.00	12.00	2.00	10.00	0.034		.03
27	16.00	16.00	15.00	1.00	10.00	0.025		.03
28	16.00	16.00	12.00	4.00	10.00	0.042		.05
29	14.00	14.00	12.00	2.00	10.00	0.165		.26
30	27.00	27.00	26.00	1.00	10.00	0.185		.18

  

Cartridge & Bag Filtration		95% of daily turbidity readings ≤ 1 NTU?		All daily turbidity readings ≤ 5 NTU?	
Yes / No	Yes / No	Yes / No	Yes / No	Yes / No	Yes / No

  

Monthly Summary (Answer Yes or No)	
CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
Yes / No	Yes / No

  

Notes: PSI = pounds per square inch	
PSID = pounds per square inch difference (before filter - after filter)	
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.	

  

DATE: 10/3/24	SIGNATURE: <i>[Signature]</i>	PHONE # (503) 965-5140	CERT #: 5186
---------------	-------------------------------	------------------------	--------------

  

JASON L. GREEN

Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not

OHA - Drinking Water Program - Surface Water Quality Data Form									
System Name:		Tierra Del Mar Water Co		ID#: 41	00610	Month/Year:	September 2024	Disinfection Giardia	Log Inactiv:
Date / Time		Residual at 1st User (C) <sup>2</sup> Residual at 1st User (C) [ppm or mg/L]	Contact Time (T)Contact Time [minutes]	Actual CT	Temp [C]	pH	Required CT	formula	Yes / No
1		0.80	150	120.4	18.0	7.500			YES
2		0.70	181	126.4	15.0	7.500			YES
3		0.70	129	90.3	15.0	7.500			YES
4		0.80	251	200.6	15.0	7.500			YES
5		0.80	251	200.6	19.0	7.500			YES
6		0.80	322	257.9	17.0	7.500			YES
7		0.70	251	175.5	16.0	7.500			YES
8		0.80	167	133.7	16.0	7.500			YES
9		0.80	215	172.0	17.0	7.500			YES
10		0.70	251	175.5	16.0	7.500			YES
11		0.70	226	158.0	15.0	7.500			YES
12		0.90	266	239.0	14.4	7.300			YES
13		0.90	266	239.0	14.8	7.150			YES
14		0.90	251	225.7	15.0	7.200			YES
15		0.80	226	180.6	15.0	7.300			YES
16		0.65	181	117.4	15.0	7.200			YES
17		0.50	226	112.9	15.0	7.200			YES
18		0.70	251	175.5	15.0	7.100			YES
19		0.50	238	118.8	15.0	7.500			YES
20		0.70	205	143.6	15.0	7.500			YES
21		0.50	196	98.1	15.0	7.500			YES
22		0.60	196	117.8	14.0	7.400			YES
23		0.50	181	90.3	15.0	7.300			YES
24		0.80	251	200.6	15.0	7.450			YES
25		0.50	301	150.5	15.0	7.400			YES
26		1.80	266	478.0	15.0	7.400			YES
27		1.10	282	310.3	15.0	7.300			YES
28		1.30	301	391.2	14.0	7.450			YES
29		1.10	251	275.9	13.0	7.450			YES
30		1.00	188	188.1	14.0	7.500			YES

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

<sup>2</sup> If C12 at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012