


OHA - Drinking Water Program						County:	TILLAMOOK
						Month/Year:	JUNE 2025
System Name:		Tierra Del Mar Water Co			WTP ID: 41-00610-A		
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]	Highest Reading of the day ¹ [NTU]
1	24.00	22.00	2.00	10.00	0.032	.04	
2	23.00	21.00	2.00	10.00	0.032	.04	
3	24.00	22.00	2.00	10.00	0.032	.04	
4	23.00	22.00	1.00	10.00	0.031	.04	
5	24.00	22.00	2.00	10.00	0.034	.04	
6	23.00	22.00	1.00	10.00	0.034	.04	
7	23.00	22.00	1.00	10.00	0.032	.04	
8	24.00	22.00	2.00	10.00	0.032	.04	
9	24.00	22.00	2.00	10.00	0.031	.04	
10	24.00	22.00	2.00	10.00	0.031	.04	
11	24.00	22.00	2.00	10.00	0.030	.04	
12	23.00	22.00	1.00	10.00	0.033	.04	
13	24.00	22.00	2.00	10.00	0.030	.04	
14	23.00	20.00	3.00	10.00	0.030	.04	
15	24.00	22.00	2.00	10.00	0.030	.04	
16	24.00	21.00	3.00	10.00	0.030	.04	
17	24.00	21.00	3.00	10.00	0.031	.03	
18	23.00	21.00	2.00	10.00	0.030	.03	
19	22.00	19.00	3.00	10.00	0.034	.03	
20	22.00	19.00	3.00	10.00	0.031	.03	
21	22.00	19.00	3.00	10.00	0.031	.03	
22	13.00	8.00	5.00	10.00	0.058	.06	
23	13.00	7.00	6.00	10.00	0.036	.04	
24	14.00	7.00	7.00	10.00	0.029	.03	
25	14.00	7.00	7.00	10.00	0.030	.03	
26	16.00	8.00	8.00	10.00	0.034	.03	
27	16.00	8.00	8.00	10.00	0.039	.05	
28	16.00	8.00	8.00	10.00	0.033	.03	
29	16.00	8.00	8.00	10.00	0.036	.04	
30	19.00	7.00	12.00	10.00	0.029	.03	

Cartridge & Bag Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 1 NTU?	Yes / No	CI's met everyday? (see back)	All CI2 residual at entry point $\geq$ 0.2 mg/l?
All daily turbidity readings $\leq$ 5 NTU?	Yes / No	Yes / No	Yes / No

Notes: PSI = pounds per square inch

PSID = pounds per square inch difference (before filter - after filter)

PSID When to Change Filter = look in manual for manufacturer's specifications when

JASON L. GREEN
 SIGNATURE: 
 PHONE #: (503) 965-5140
 DATE: 7-9-25
 CERT #: 5186

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP- :

System Name:	Tierra Del Mar Water Co		ID#: 41	00610	Month/Year:	JUNE 2025	Disinfection <i>Giardia</i> Log Inactiv:
Date / Time	Residual at 1st User (C) ² Minimum Cl ₂ Residual at 1st User (C)	Contact Time (T)Contact Time (T)Contact Time	Actual CT	Temp	pH	Required CT	CT Met?
							Met? 2CT Met? 2CT Met? 2CT Met? 2CT Met? 2CT Met? 2CT Met? 2CT Met? 2CT Met? 2CT Met? 2CT Met? 2CT Met? 2CT
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No
1	0.90	205	184.7	13.0	7.500	37.0	YES
2	0.90	226	203.1	13.0	7.500	37.0	YES
3	0.90	226	203.1	13.0	7.500	37.0	YES
4	0.90	181	162.5	13.5	7.400	34.5	YES
5	0.90	238	213.8	13.5	7.400	34.5	YES
6	0.90	251	225.7	13.5	7.400	34.5	YES
7	0.90	251	225.7	13.5	7.500	35.8	YES
8	0.90	119	106.9	13.5	7.400	34.5	YES
9	0.90	137	123.1	15.0	7.400	31.2	YES
10	0.90	161	145.1	14.0	7.400	33.4	YES
11	0.90	150	135.4	14.5	7.400	32.3	YES
12	0.90	150	135.4	14.0	7.500	34.6	YES
13	0.90	205	184.7	14.0	7.500	34.6	YES
14	0.90	226	203.1	13.0	7.500	37.0	YES
15	0.90	226	203.1	13.0	7.500	37.0	YES
16	0.90	137	123.1	13.0	7.400	35.7	YES
17	0.80	167	133.7	14.0	7.400	33.0	YES
18	0.80	141	112.9	14.0	7.400	33.0	YES
19	0.90	141	127.0	14.0	7.500	34.6	YES
20	0.80	150	120.4	14.0	7.500	34.3	YES
21	0.90	129	116.1	14.0	7.500	34.6	YES
22	0.90	129	116.1	13.0	7.500	37.0	YES
23	0.80	85	68.1	14.0	7.300	31.8	YES
24	0.80	103	82.1	14.0	7.300	31.8	YES
25	0.90	90	81.3	14.0	7.300	32.2	YES
26	0.80	85	68.1	14.0	7.400	33.0	YES
27	0.90	205	184.7	14.0	7.500	34.6	YES
28	0.80	150	120.4	14.0	7.400	33.0	YES
29	0.90	107	96.7	14.0	7.400	33.4	YES
30	0.90	105	94.5	14.0	7.500	34.6	YES

² If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 201