

OHA - Drinking Water Program

County: TILLAMOOK

Month/Year: MARCH 2026

System Name:	Tierra Del Mar Water Co				WTP ID: 41-00610-A	
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU] Highest Reading of the day ¹ [NTU]
1	0.00	0.00	0.00	10.00	0.028	.03
2	9.00	7.00	2.00	10.00	0.028	.03
3	0.00	0.00	0.00	10.00	0.030	.04
4	19.00	17.00	2.00	10.00	0.041	.04
5	19.00	17.00	2.00	10.00	0.034	.03
6	19.00	17.00	2.00	10.00	0.031	.03
7	19.00	17.00	2.00	10.00	0.032	.03
8	19.00	17.00	2.00	10.00	0.032	.03
9	19.00	17.00	2.00	10.00	0.038	.04
10	19.00	16.00	3.00	10.00	0.031	.03
11	19.00	16.00	3.00	10.00	0.035	.04
12	19.00	16.00	3.00	10.00	0.092	.09
13	18.00	16.00	2.00	10.00	0.076	.07
14	18.00	16.00	2.00	10.00	0.128	.13
15	18.00	16.00	2.00	10.00	0.054	.05
16	19.00	16.00	3.00	10.00	0.054	.05
17	17.00	15.00	2.00	10.00	0.032	.03
18	19.00	17.00	2.00	10.00	0.037	.04
19	19.00	17.00	2.00	10.00	0.038	.04
20	19.00	17.00	2.00	10.00	0.036	.04
21	19.00	17.00	2.00	10.00	0.037	.04
22	9.00	7.00	2.00	10.00	0.035	.04
23	9.00	7.00	2.00	10.00	0.032	.04
24	9.00	7.00	2.00	10.00	0.031	.03
25	9.00	7.00	2.00	10.00	0.038	.04
26	9.00	7.00	2.00	10.00	0.035	.04
27	9.00	7.00	2.00	10.00	0.030	.03
28	10.00	7.00	3.00	10.00	0.029	.03
29	10.00	7.00	3.00	10.00	0.028	.03
30	10.00	7.00	3.00	10.00	0.029	.03
31	10.00	7.00	3.00	10.00	0.028	.03

Cartridge & Bag Filtration

95% of daily turbidity readings ≤ 1 NTU?

Yes / No

All daily turbidity readings ≤ 5 NTU?

Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back)

Yes / No

All Cl2 residual at entry point ≥ 0.2 mg/l?

Yes / No

Notes: PSI = pounds per square inch

PSID = pounds per square inch difference (before filter - after filter)

PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

JASON L. GREEN

SIGNATURE: 

DATE: 4-1-26

PHONE #: 503 965-5140

CERT #: 5186

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not

correspond to continuous readings' maximum.

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP- :

System Name:	Tierra Del Mar Water Co	ID#:	41 00610	Month/Year:	MARCH 2026	Disinfection <i>Giardia</i> Log Inactiv:	1	
Date / Time	Residual at 1st User (C) 2Minimum Cl ₂ Residual at 1st	Contact Time (T)Contact Time (T)Contact Time	Actual CT	Temp	pH	Required CT	CT Met? Met? 2CT Met? 2CT Met? 2CT Met? 2CT Met? 2CT Met? 2CT Met? 2CT Met? 2CT Met? 2CT Met? 2CT Met? 2CT Met? 2CT	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1	188	188.1	10.0	7.200	41.4	YES	24
2	1	156	155.7	10.0	7.200	41.4	YES	29
3	0.9	181	162.5	10.0	7.200	40.9	YES	25
4	0.9	347	312.5	10.0	7.200	40.9	YES	13
5	0.9	266	239.0	10.0	7.200	40.9	YES	17
6	0.9	347	312.5	10.0	7.200	40.9	YES	13
7	0.9	322	290.2	10.0	7.100	39.5	YES	14
8	0.9	238	213.8	10.0	7.100	39.5	YES	19
9	0.9	238	213.8	10.0	7.200	40.9	YES	19
10	0.9	282	253.9	10.0	7.200	40.9	YES	16
11	0.9	347	312.5	9.0	7.200	43.7	YES	13
12	0.9	301	270.8	11.0	7.100	37.0	YES	15
13	0.8	282	225.7	11.0	7.100	36.6	YES	16
14	0.7	205	143.6	10.0	7.100	38.6	YES	22
15	0.7	174	121.5	10.0	7.100	38.6	YES	26
16	0.7	181	126.4	10.0	7.100	38.6	YES	25
17	0.7	266	185.9	10.0	7.100	38.6	YES	17
18	0.8	322	257.9	10.0	7.100	39.1	YES	14
19	0.9	301	270.8	10.0	7.100	39.5	YES	15
20	0.8	322	257.9	11.0	7.100	36.6	YES	14
21	0.9	196	176.6	11.0	7.100	37.0	YES	23
22	0.9	137	123.1	11.0	7.100	37.0	YES	33
23	0.9	167	150.5	10.0	7.200	40.9	YES	27
24	0.80	161	129.0	10.0	7.200	40.5	YES	28
25	0.9	181	162.5	10.0	7.200	40.9	YES	25
26	0.9	196	176.6	10.0	7.100	39.5	YES	23
27	0.9	156	140.1	10.0	7.100	39.5	YES	29
28	0.9	167	150.5	10.0	7.100	39.5	YES	27
29	0.9	133	119.5	10.0	7.100	39.5	YES	34
30	0.9	141	127.0	10.0	7.100	39.5	YES	32
31	0.9	226	203.1	10.0	7.100	39.5	YES	20

² If Cl2 at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.