

OHA - DWS

Membrane Filter Monthly Operating Report

System Name: **City of Pendleton**

PWS ID#: 41 - **000613**

Plant ID: WTP - **A**
(e.g., "A")

County: **Umatilla**

Month/Year: **Oct-2025**

Minimum test pressure **applied**: **10.5** psi

Minimum test pressure **req'd**: **10.07** psi

DIT = Direct Integrity Test on filter(s) [Yes, No, or "off" if all filters are offline] ⇄

PDR = Pressure Decay Rate

LRC = Log Removal Credit

PDR_{Max} [^{psi}/_{min}]

LRC [log removal]

0.154

4.00

DIT
Daily

Day	CFE Daily Turbidity [NTU]	Highest CFE* [NTU]	Highest IFE [NTU]	Highest PDR of day [^{psi} / _{min}]	Lowest LRV _{ambient} of day [log removal]	[Y/N] or "off"
1	0.059	0.062	N/A	0.09	4.04	Y
2	0.059	0.070	N/A	0.09	4.04	Y
3	0.058	0.064	N/A	0.09	4.04	Y
4	0.058	0.082	N/A	0.09	4.07	Y
5	0.058	0.063	N/A	0.09	4.05	Y
6	0.060	0.063	N/A	0.09	4.07	Y
7	0.061	0.063	N/A	0.09	4.03	Y
8	0.059	0.064	N/A	0.09	4.05	Y
9	0.060	0.063	N/A	0.09	4.05	Y
10	0.061	0.063	N/A	0.10	4.07	Y
11	0.058	0.064	N/A	0.10	4.05	Y
12	0.059	0.063	N/A	0.08	4.07	Y
13	0.061	0.063	N/A	0.09	4.05	Y
14	0.061	0.065	N/A	0.09	4.03	Y
15	0.061	0.064	N/A	0.09	4.05	Y
16	0.059	0.077	N/A	0.09	4.07	Y
17	0.063	0.070	N/A	0.09	4.05	Y
18	0.059	0.065	N/A	0.08	4.07	Y
19	0.059	0.064	N/A	0.09	4.07	Y
20	0.061	0.065	N/A	0.09	4.05	Y
21	0.061	0.064	N/A	0.09	4.07	Y
22	0.061	0.065	N/A	0.09	4.06	Y
23	0.061	0.063	N/A	0.09	4.06	Y
24	0.064	0.065	N/A	0.09	4.04	Y
25	0.059	0.064	N/A	0.09	4.02	Y
26	0.059	0.064	N/A	0.08	4.07	Y
27	0.061	0.064	N/A	0.09	4.05	Y
28	0.062	0.068	N/A	0.09	4.07	Y
29	0.062	0.075	N/A	0.09	4.07	Y
30	0.060	0.071	N/A	0.09	4.07	Y
31	0.064	0.066	N/A	0.09	4.05	Y

Compliance summary (operator to complete any blank fields)

95% of daily turbidity readings ≤ 1 NTU? [Y/N]	All turbidity readings ≤ 5 NTU? [Y/N]	All IFE turbidity readings ≤ 0.15 NTU? [Y/N]	Performance std met? [Y/N] (PDR ≤ PDR _{Max} , LRV ≥ LRC)	DIT Daily?
Yes	Yes	Yes	Yes	Yes
CT's met daily? (p. 2)	All Cl ₂ residual at EP ≥ 0.2 mg/L?	PDR ≤ PDR _{Max} ?	LRV _{ambient} ≥ LRC?	
Yes	Yes	Yes	Yes	

PRINTED NAME: *Scott Roe*
SIGNATURE: *[Signature]*
Notes:

DATE: *11-03-25*
WT CERT #: *D-08331*
PHONE #: *541-969-3148*

OHA-DWS

Disinfection Monthly Operating Report

System Name: City of Pendleton
 PWS ID#: 41 - 613
 Plant ID : WTP - A

0.5

Log
Inactivation
Disinfection

Day	Minimum Cl ₂ Residual at 1 st User (C) * [mg/L = ppm]	Contact Time (T) [minutes]	Actual CT C x T (Formula)	Temp [° C]	pH	Required CT (Formula)	CT Met? * [Yes / No] (Formula)	Peak Hourly Demand Flow [GPM]	Notes (e.g. "Plant Off")
1	0.745	95	70.8	17.2	7.72	15	YES	1,682	
2	0.735	96	70.6	16.9	7.72	15	YES	1,658	
3	0.546	97	52.9	17.3	7.69	14	YES	1,603	
4	0.536	97	52.0	16.8	7.69	15	YES	1,600	
5	0.655	93	60.9	16.4	7.65	15	YES	1,653	
6	0.605	96	58.1	16.4	7.63	15	YES	1,581	
7	0.645	96	61.9	15.7	7.65	16	YES	1,618	
8	0.575	105	60.4	14.8	7.60	16	YES	1,634	
9	0.505	69	34.9	14.7	7.62	16	YES	1,679	
10	0.625	99	61.9	14.9	7.59	16	YES	1,551	
11	0.605	96	58.0	15.4	7.62	16	YES	1,592	
12	0.604	92	55.6	14.5	7.63	17	YES	1,600	
13	0.604	92	55.6	14.5	7.63	17	YES	1,600	
14	0.694	94	65.2	13.6	7.59	18	YES	1,641	
15	0.733	90	66.0	12.8	7.49	18	YES	1,597	
16	0.683	102	69.7	11.9	7.53	20	YES	1,703	
17	0.692	97	67.2	11.8	7.48	20	YES	1,598	
18	0.744	106	78.9	12.6	7.53	19	YES	1,633	
19	0.744	106	78.9	12.6	7.53	19	YES	1,633	
20	0.764	104	79.5	13.0	7.53	18	YES	1,673	
21	0.694	89	61.8	12.3	7.50	19	YES	1,623	
22	0.655	86	56.3	12.2	7.49	19	YES	1,619	
23	0.744	92	68.5	12.6	7.51	19	YES	1,579	
24	0.784	91	71.3	12.5	7.49	19	YES	1,529	
25	0.804	88	70.7	11.5	7.46	20	YES	1,609	
26	0.733	86	63.1	10.8	7.46	21	YES	1,607	
27	0.664	84	55.7	10.2	7.44	21	YES	1,659	
28	0.664	96	63.7	11.2	7.45	20	YES	1,559	
29	0.689	92	63.4	11.9	7.55	20	YES	1,563	
30	0.672	89	59.8	12.2	7.49	19	YES	1,601	
31	0.691	94	65.0	12.1	7.53	20	YES	1,587	

* If chlorine concentration at entry point < 0.2 mg/L, or CT not met, notify DWS within 24 hours.

Submit this monthly report by the 10th of following month by

mail: Drinking Water Services
 PO Box 14350
 Portland, OR 97293-0350

email: dlwp.dmcce@odhsoha.oregon.gov
 fax: 971-673-0458