

OHA - DWS

Membrane Filter Monthly Operating Report

System Name: City of Pendleton

County: Umatilla

PWS ID#: 41 - 000613

Month/Year: Jan-2026

Plant ID: WTP - A

Minimum test pressure **applied**: 10.5 psi

Minimum test pressure **req'd**: 10.07 psi

(e.g., "A")

DIT = Direct Integrity Test on filter(s) [Yes, No, or "off" if all filters are offline] ⇔

PDR = Pressure Decay Rate

LRC = Log Removal Credit

Day	CFE Daily Turbidity [NTU]	Highest CFE* [NTU]	Highest IFE [NTU]	Highest PDR of day [^{psi} /min]	Lowest LRV _{ambient} of day [log removal]	DIT Daily
				0.154	4.00	
1	0.065	0.066	N/A	0.07	4.05	Y
2	0.065	0.067	N/A	0.08	4.07	Y
3	0.066	0.067	N/A	0.07	4.07	Y
4	0.066	0.067	N/A	0.07	4.06	Y
5	0.066	0.067	N/A	0.07	4.07	Y
6	0.066	0.067	N/A	0.08	4.07	Y
7	0.066	0.068	N/A	0.07	4.07	Y
8	0.066	0.068	N/A	0.07	4.08	Y
9	0.066	0.069	N/A	0.07	4.07	Y
10	0.066	0.069	N/A	0.07	4.08	Y
11	0.066	0.067	N/A	0.07	4.08	Y
12	0.066	0.067	N/A	0.07	4.06	Y
13	0.066	0.068	N/A	0.07	4.07	Y
14	0.067	0.068	N/A	0.08	4.09	Y
15	0.067	0.075	N/A	0.09	4.11	Y
16	0.066	0.070	N/A	0.09	4.13	Y
17	0.067	0.073	N/A	0.08	4.04	Y
18	0.066	0.068	N/A	0.08	4.08	Y
19	0.067	0.078	N/A	0.07	4.10	Y
20	0.066	0.072	N/A	0.07	4.13	Y
21	0.066	0.068	N/A	0.07	4.12	Y
22	0.065	0.069	N/A	0.07	4.11	Y
23	0.000	0.000	N/A	0.00	0.00	OFF
24	0.000	0.000	N/A	0.00	0.00	OFF
25	0.000	0.000	N/A	0.00	0.00	OFF
26	0.000	0.000	N/A	0.00	0.00	OFF
27	0.000	0.000	N/A	0.00	0.00	OFF
28	0.000	0.000	N/A	0.00	0.00	OFF
29	0.000	0.000	N/A	0.00	0.00	OFF
30	0.000	0.000	N/A	0.00	0.00	OFF
31	0.000	0.000	N/A	0.00	0.00	OFF

Compliance summary (operator to complete any blank fields)

95% of daily turbidity readings ≤ 1 NTU? [Y/N] Yes	All turbidity readings ≤ 5 NTU? [Y/N] Yes	All IFE turbidity readings ≤ 0.15 NTU? [Y/N] Yes	Performance std met? [Y/N] (PDR ≤ PDR _{Max} , LRV ≥ LRC) Yes	DIT Daily? Yes
CT's met daily? (p. 2) Yes	All Cl ₂ residual at EP ≥ 0.2 mg/L? Yes	PDR ≤ PDR _{Max} ? Yes	LRV _{ambient} ≥ LRC? Yes	

PRINTED NAME: Scott Roe DATE: 2-2-26
 SIGNATURE: [Signature] WT CERT #: D-08231
 Notes: Plant off 1/23/26-1/31/26 PHONE #: 541-969-3148

♣ Used for optimization purposes only.

OHA-DWS

Disinfection Monthly Operating Report

Jan-2026

System Name: City of Pendleton

PWS ID#: 41 - 613

Plant ID : WTP - A

0.5 ↩ Log
Inactivation
Disinfection

Day	Minimum Cl ₂ Residual at 1 st User (C) * [mg/L = ppm]	Contact Time (T) [minutes]	Actual CT C x T (Formula)	Temp [° C]	pH	Required CT (Formula)	CT Met? * [Yes / No] (Formula)	Peak Hourly Demand Flow [GPM]	Notes (e.g. "Plant Off")
1	0.693	51	35.3	4.0	6.91	27	YES	6,638	
2	0.713	54	38.5	4.8	6.91	26	YES	6,633	
3	0.733	55	40.3	5.5	6.92	25	YES	6,636	
4	0.703	53	37.3	6.2	6.91	23	YES	6,645	
5	0.683	53	36.2	7.4	6.91	21	YES	6,649	
6	0.654	53	34.7	7.0	6.92	22	YES	6,638	
7	0.673	55	37.0	6.7	6.92	22	YES	6,635	
8	0.677	55	37.3	5.9	6.92	24	YES	6,627	
9	0.713	51	36.4	6.1	6.91	23	YES	6,645	
10	0.842	52	43.8	6.0	6.91	24	YES	6,644	
11	0.852	55	46.9	6.1	6.93	24	YES	6,644	
12	0.852	55	46.9	6.4	6.94	24	YES	6,638	
13	0.853	56	47.8	6.6	6.95	23	YES	6,640	
14	0.882	56	49.4	6.1	6.96	24	YES	6,643	
15	0.892	52	46.4	5.6	6.98	25	YES	6,633	
16	0.902	58	52.3	5.7	6.98	25	YES	6,624	
17	0.902	53	47.8	5.1	6.98	26	YES	6,638	
18	0.892	50	44.6	5.0	6.98	26	YES	7,090	
19	0.782	45	35.2	4.6	6.98	27	YES	6,648	
20	0.822	48	39.5	4.4	6.97	27	YES	6,645	
21	0.703	49	34.4	4.0	6.98	28	YES	6,632	
22	0.703	49	34.4	4.0	6.97	28	YES	6,118	
23	0.000	0	0.0	0.0	0.00	0	YES	-	Plant off
24	0.000	0	0.0	0.0	0.00	0	YES	-	Plant off
25	0.000	0	0.0	0.0	0.00	0	YES	-	Plant off
26	0.000	0	0.0	0.0	0.00	0	YES	-	Plant off
27	0.000	0	0.0	0.0	0.00	0	YES	-	Plant off
28	0.000	0	0.0	0.0	0.00	0	YES	-	Plant off
29	0.000	0	0.0	0.0	0.00	0	YES	-	Plant off
30	0.000	0	0.0	0.0	0.00	0	YES	-	Plant off
31	0.000	0	0.0	0.0	0.00	0	YES	-	Plant off

* If chlorine concentration at entry point < 0.2 mg/L, or CT not met, notify DWS within 24 hours.

Submit this monthly report by the 10th of following month by

mail: Drinking Water Services
PO Box 14350
Portland, OR 97293-0350

email: dlp_dmce@odhsoha.oregon.gov

fax: 971-673-0458