

# OHA - Drinking Water Services - Turbidity Monitoring Report Form: Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

## Water system information

System Name: Portland Water Bureau  
ID #: OR 4100657  
County: Multnomah

## Report information

Month/Year: 02/2026  
Water treatment plant (WTP): WTP- A  
Type: Unfiltered system

### Data table: Turbidity readings at compliance times

DAY	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Daily Reading (NTU)
1	0.65	0.64	0.64	0.64	0.64	0.63	0.65
2	0.63	0.63	0.62	0.62	0.63	0.62	0.63
3	0.62	0.60	0.60	0.59	0.59	0.59	0.62
4	0.59	0.58	0.58	0.59	0.57	0.57	0.59
5	0.58	0.57	0.58	0.56	0.57	0.57	0.58
6	0.56	0.57	0.56	0.57	0.57	0.57	0.57
7	0.57	0.57	0.56	0.55	0.55	0.55	0.57
8	0.57	0.60	0.57	0.58	0.57	0.56	0.60
9	0.54	0.52	0.51	0.51	0.51	0.51	0.54
10	0.49	0.50	0.51	0.52	0.54	0.53	0.54
11	0.52	0.52	0.51	0.53	0.54	0.53	0.54
12	0.52	0.52	0.51	0.48	0.48	0.48	0.52
13	0.47	0.48	0.47	0.46	0.46	0.47	0.48
14	0.62	0.58	0.51	0.49	0.47	0.47	0.62
15	0.48	0.51	0.52	0.51	0.48	0.43	0.52
16	0.44	0.46	0.43	0.43	0.44	0.42	0.46
17	0.42	0.43	0.41	0.45	0.43	0.42	0.45
18	0.42	0.42	0.41	0.41	0.41	0.38	0.42
19	0.40	0.42	0.40	0.41	0.42	0.42	0.42
20	0.42	0.40	0.38	0.39	0.38	0.40	0.42
21	0.41	0.43	0.46	0.42	0.41	0.43	0.46
22	0.42	0.42	0.41	0.41	0.42	0.42	0.42
23	0.42	0.42	0.44	0.41	0.40	0.41	0.44
24	0.40	0.41	0.41	0.40	0.41	0.38	0.41
25	0.41	0.42	0.43	0.52	0.51	0.47	0.52
26	0.47	0.49	0.49	0.48	0.47	0.48	0.49
27	0.49	0.49	0.49	0.48	0.47	0.46	0.49
28	0.46	0.46	0.43	0.43	0.46	0.43	0.46

### Data table: Monthly summary

Filtered systems only: 95% of daily turbidity readings $\leq$ 1 NTU?	All daily turbidity readings $\leq$ 5 NTU?	Chlorine contact times met everyday?	Chlorine residual at entry point always $\geq$ 0.2 mg/L?	Chlorine residual measured in 95% of distribution samples?
N/A	Yes	Yes	Yes	Yes

Signature: Anna Vosa  
Anna Vosa, P.E.

Date: 3/6/26

## OHA Drinking Water Services Report Form: Raw Coliform Data (Unfiltered systems)

### Water system information

**System Name:** Portland Water Bureau

**ID #:** OR 4100657

### Report information

**Month/Year:** 02/2026

**Sample location:** active Headworks  
Raw Water Intake (2P or 2PIS)

### Data Table: Raw Water Coliform Results

Date	Fecal Coliform (CFU/100 mL)	Comments
2/1/2026	1	-
2/2/2026	1	-
2/3/2026	2	-
2/4/2026	2	-
2/5/2026	<1	-
2/6/2026	1	-
2/7/2026	1	-
2/8/2026	1	-
2/9/2026	1	-
2/10/2026	1	-
2/11/2026	1	-
2/12/2026	<1	-
2/13/2026	2	-
2/14/2026	<1	-
2/15/2026	<1	-
2/16/2026	1	-
2/17/2026	1	-
2/18/2026	1	-
2/19/2026	<1	-
2/20/2026	<1	-
2/21/2026	<1	-
2/22/2026	<1	-
2/23/2026	1	-
2/24/2026	<1	-
2/25/2026	1	-
2/26/2026	<1	-
2/27/2026	1	-
2/28/2026	<1	-

### Data Table: Six Month Summary

Date range	Total no. of fecal coliform samples	No. fecal coliform samples >20 CFU/100 mL	Percent of fecal coliform samples >20 CFU/100 mL
9/1/25-2/28/26	172	0	0%

# OHA - Drinking Water Services

## Surface Water Quality Data Conduit 2

Portland Water Bureau

ID#: OR 4100657

WTP-A

Month/Year: 02/2026

Date / Time	Peak Hourly Flow	Hourly Average Free Chlorine during Peak	Contact Time (T)	Actual CT	Temp	pH	Req'd CT	CT Met?	Min. Hourly Average Total Chlorine at First User
	MGD	ppm or mg/L	min.	C x T	°C		Tables	Y/N	ppm or mg/L
1 / 3	44.39	2.20	256.3	563.2	5.0	6.60	146.0	Y	2.16
2 / 10	44.35	2.30	256.3	588.9	4.9	6.59	147.8	Y	2.21
3 / 5	44.37	2.23	256.2	570.8	5.0	6.60	145.9	Y	2.21
4 / 4	43.72	2.20	259.9	572.9	5.2	6.61	145.5	Y	2.17
5 / 18	43.43	2.26	261.8	591.9	5.3	6.62	145.6	Y	2.23
6 / 5	43.97	2.26	258.7	585.1	5.2	6.62	146.5	Y	2.21
7 / 23	44.61	2.24	254.8	571.2	5.2	6.61	145.5	Y	2.18
8 / 16	47.48	2.23	239.6	534.1	5.2	6.61	145.6	Y	2.18
9 / 10	46.72	2.25	243.4	548.4	5.1	6.62	146.8	Y	2.19
10 / 10	41.64	2.14	272.7	583.8	5.2	6.65	146.4	Y	2.10
11 / 3	40.66	2.23	277.2	616.8	5.3	6.64	146.1	Y	2.19
12 / 20	39.27	2.25	289.4	652.5	5.3	6.65	147.5	Y	2.29
13 / 4	39.25	2.25	289.5	651.1	5.3	6.63	146.1	Y	2.37
14 / 13	38.48	2.27	292.4	662.6	5.4	6.66	147.7	Y	2.25
15 / 22	38.83	2.28	293.0	666.7	5.4	6.66	147.6	Y	2.21
16 / 17	44.60	2.26	255.2	577.0	5.3	6.66	147.8	Y	2.25
17 / 3	44.55	2.21	255.3	565.3	5.3	6.67	147.9	Y	2.23
18 / 9	44.72	2.16	254.3	548.2	5.4	6.68	147.1	Y	2.23
19 / 18	48.62	2.26	233.8	528.8	5.4	6.63	145.2	Y	2.32
20 / 17	49.28	2.25	232.5	523.5	5.4	6.65	146.5	Y	2.41
21 / 18	49.20	2.26	232.1	525.5	5.4	6.68	148.4	Y	2.37
22 / 8	42.72	2.21	265.8	588.1	5.3	6.69	148.6	Y	2.26
23 / 7	46.04	2.15	246.5	530.0	5.4	6.67	146.7	Y	2.12
24 / 21	40.10	2.25	283.2	636.4	5.3	6.67	148.5	Y	2.24
25 / 10	40.13	2.25	283.2	637.3	5.3	6.66	148.0	Y	2.21
26 / 16	40.13	2.21	283.3	626.0	5.5	6.65	145.7	Y	2.19
27 / 3	40.18	2.21	283.1	625.6	5.5	6.64	144.8	Y	2.19
28 / 10	39.10	2.27	290.8	660.0	5.5	6.65	145.6	Y	2.22

**Notes for Conduit 2 (C2):**

February 1 to 24, 2026: Conduit 2 out of service from Headworks to Hudsons Intertie; Conduit 4 feeding Conduit 2 at Hudsons  
 February 24 to 28, 2026: Conduit 2 in service from Headworks to Larson's Intertie; Conduit 2 feeding Conduit 3 at Larson's Intertie; Conduit 2 out of service from Larson's Intertie to Hudson's Intertie; Conduit 4 feeding Conduit 2 at Hudson's Intertie; Conduit 2 in service from Hudson's through Lusted and on to town.

Signature: Anna Vosa  
 Anna Vosa, P.E., Water Quality Engineer

Date: 3/6/26

# OHA - Drinking Water Services

## Surface Water Quality Data Conduit 3

Portland Water Bureau

ID#: OR 4100657

WTP-A

Month/Year: 02/2026

Date / Time	Peak Hourly Flow	Hourly Average Free Chlorine during Peak	Contact Time (T)	Actual CT	Temp	pH	Req'd CT	CT Met?	Min. Hourly Average Total Chlorine at First User
	MGD	ppm or mg/L	min.	C x T	°C		Tables	Y/N	ppm or mg/L
1 / 6	33.90	2.22	289.7	643.3	5.0	6.66	150.4	Y	2.21
2 / 6	33.90	2.28	289.9	660.8	4.9	6.65	151.3	Y	2.20
3 / 7	33.89	2.22	289.8	642.9	5.1	6.66	149.2	Y	2.18
4 / 8	33.45	2.19	293.8	642.6	5.2	6.67	148.8	Y	2.14
5 / 16	33.25	2.25	295.7	665.4	5.3	6.74	152.6	Y	2.26
6 / 23	33.63	2.23	292.3	651.0	5.2	6.69	150.4	Y	2.23
7 / 23	34.06	2.22	288.1	639.7	5.2	6.70	150.7	Y	2.22
8 / 16	36.20	2.20	271.7	597.6	5.2	6.70	150.5	Y	2.19
9 / 22	35.31	2.23	278.2	620.0	5.1	6.70	151.3	Y	2.19
10 / 9	35.34	2.13	278.1	591.1	5.2	6.73	150.4	Y	2.14
11 / 0	34.91	2.25	281.8	633.4	5.4	6.71	150.3	Y	2.15
12 / 21	33.36	2.25	294.6	661.6	5.3	6.65	147.6	Y	2.22
13 / 4	33.35	2.24	294.7	661.3	5.3	6.67	148.6	Y	2.28
14 / 2	33.08	2.26	297.0	669.9	5.3	6.66	148.0	Y	2.28
15 / 23	33.16	2.30	296.1	680.3	5.4	6.69	149.6	Y	2.25
16 / 22	33.31	2.21	295.3	651.6	5.3	6.71	150.0	Y	2.28
17 / 2	33.28	2.21	295.4	652.3	5.3	6.71	150.0	Y	2.26
18 / 9	33.40	2.14	294.2	629.8	5.4	6.72	148.8	Y	2.26
19 / 23	36.43	2.26	267.6	605.9	5.4	6.69	148.6	Y	2.35
20 / 9	37.72	2.23	260.5	581.7	5.4	6.70	149.7	Y	2.34
21 / 11	37.71	2.15	260.5	559.5	5.4	6.73	149.6	Y	2.29
22 / 0	37.69	2.29	260.6	596.2	5.4	6.72	151.0	Y	2.23
23 / 22	35.36	2.28	277.9	634.2	5.4	6.72	151.1	Y	2.11
24 / 0	35.32	2.28	278.2	635.3	5.4	6.72	150.8	Y	1.79
25 / 5	30.75	2.27	299.3	680.7	5.3	6.73	152.3	Y	2.21
26 / 7	30.57	2.22	300.8	666.4	5.4	6.72	149.6	Y	2.19
27 / 23	35.48	2.23	259.1	578.3	5.5	6.69	147.6	Y	2.17
28 / 23	41.29	2.26	222.5	503.0	5.5	6.70	148.9	Y	2.21

**Notes for Conduit 3 (C3):**

February 1 to 24, 2026: Conduit 3 in service from Headworks through Lusted and on to town.

February 24 to 28, 2026: Conduit 3 out of service from Headworks to Larson's Intertie; Conduit 2 feeding Conduit 3 at Larson's Intertie; Conduit 3 in service from Larson's Intertie through Lusted and on to town.

Signature: Anna Vosa  
 Anna Vosa, P.E., Water Quality Engineer

Date: 3/6/26

# OHA - Drinking Water Services

## Surface Water Quality Data Conduit 4

Portland Water Bureau

ID#: OR 4100657

WTP-A

Month/Year: 02/2026

Date / Time	Peak Hourly Flow	Hourly Average Free Chlorine during Peak Hour (C)	Contact Time (T)	Actual CT	Temp	pH	Req'd CT	CT Met?	Min. Hourly Average Total Chlorine at First User	
	MGD	ppm or mg/L	min.	C x T	°C		Tables	Y/N	ppm or mg/L	
1										
2										
3										
4										
5										
6										
7										
8										
9										
10										
11										
12										
13				Conduit 4 out of service						
14										
15										
16										
17										
18										
19										
20										
21										
22										
23										
24										
25										
26										
27										
28										

**Notes for Conduit 4 (C4):**

February 1 to 28, 2026: Conduit 4 in service from Headworks to Hudsons; Conduit 4 feeding Conduit 2 at Hudsons Intertie; Conduit 4 out of service from Hudsons through Lusted and on to town.

Signature: Anna Vosa  
 Anna Vosa, P.E., Water Quality Engineer

Date: 3/6/26