



OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Curry
 Month/Year: Nov. 2021

Conventional or Direct Filtration

System Name:	City of Port Orford		4100670				WTP-A:	WTP-A:
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1			0.03				0.03	
2			0.03	0.03	0.03	0.03	0.03	
3			0.03	0.03	0.03		0.03	
4			NO	ENTRIES				
5			0.03	0.03	0.19	0.03	0.19	
6	0.03		0.02	0.02	0.02		0.03	
7			0.02	0.02	0.02		0.02	
8			0.02	0.02	0.02	0.02	0.02	
9			0.02	0.02	0.02	0.02	0.02	
10			0.02	0.02	0.02		0.02	
11			0.02	0.02	0.02		0.02	
12			0.02	0.02	0.02		0.02	
13			0.02	0.02	0.02		0.02	
14			0.02	0.02	0.02		0.02	
15			0.02	0.02			0.02	
16			0.03	0.02	0.02		0.03	
17			0.02	0.02	0.02		0.02	
18			0.02	0.02	0.02		0.02	
19			0.02	0.02	0.02		0.02	
20			0.02	0.02	0.02		0.02	
21			0.02	0.02	0.02		0.02	
22			0.02	0.02	0.02	0.02	0.02	
23			0.02	0.02	0.02		0.02	
24			0.02	0.02	0.02		0.02	
25			0.02	0.02	0.02		0.02	
26			0.02	0.02	0.02		0.02	
27			0.02	0.02	0.02		0.02	
28			0.02	0.02	0.02		0.02	
29			0.02	0.02	0.02		0.02	
30			0.02	0.02	0.02		0.02	
31								

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE ² triggers	Yes / No		
Notes:  Digitally signed by Dave Terrusa DN: cn=Dave Terrusa, o=US, ou=H2o System Consulting, ou=DRC, email=treatment6930@gmail.com Reason: I have reviewed this document Location: (541) 253-7556 Date: 2021.12.06 12:53:44 -0800		David Terrusa SIGNATURE:  541-253-7556	6 Dec 2021 CERT# 6930

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: City of Port Orford	ID# 4100670	Month/Year: Nov. 2021	WTP-A: Disinfection <i>Giardia</i> Log Inactive:	1
---	--------------------	------------------------------	---	---

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm ormg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1@1pm	1.2	37.5	45.0	13.0	7.20	34.3	YES	255
2@1pm	1.2	37.5	45.0	13.0	7.20	34.3	YES	255
3@1pm	1.2	37.5	45.0	13.0	7.20	34.3	YES	255
4@1pm				NO	ENTRIES			
5@1pm	1.2	37.5	45.0	13.0	7.20	34.3	YES	255
6@1pm	1.2	37.5	45.0	12.0	7.20	37.1	YES	255
7@1pm	1.2	37.5	45.0	12.0	7.20	37.1	YES	255
8@1pm	1.2	37.5	45.0	11.0	7.20	39.6	YES	255
9@1pm	1.2	37.5	45.0	12.0	7.20	37.1	YES	255
10@1pm	1.3	37.5	48.8	11.0	7.30	41.5	YES	255
11@1pm	1.2	37.5	45.0	12.0	7.30	38.4	YES	255
12@1pm	1.2	37.5	45.0	13.0	7.30	35.6	YES	255
13@1pm	1.2	37.5	45.0	13.0	7.30	35.6	YES	255
14@1pm	1.2	37.5	45.0	13.0	7.30	35.6	YES	255
15@1pm	1.2	37.5	45.0	13.0	7.30	35.6	YES	255
16@1pm	1.2	37.5	45.0	11.0	7.30	41.0	YES	255
17@1pm	1.2	37.5	45.0	10.0	7.30	43.8	YES	255
18@1pm	1.2	37.5	45.0	11.0	7.30	41.0	YES	255
19@1pm	1.3	37.5	48.8	12.0	7.30	38.9	YES	255
20@1pm	1.3	37.5	48.8	11.0	7.20	40.1	YES	255
21@1pm	1.3	37.5	48.8	10.0	7.20	42.8	YES	255
22@9:30am	1.2	37.5	45.0	10.0	7.20	42.3	YES	255
23@1pm	1.3	37.5	48.8	10.0	7.30	44.3	YES	255
24@1pm	1.2	37.5	45.0	10.0	7.20	42.3	YES	255
25@1pm	1.3	37.5	48.8	9.0	7.20	45.7	YES	255
26@1pm	1.2	37.5	45.0	10.0	7.30	43.8	YES	255
27@1pm	1.3	37.5	48.8	11.0	7.20	40.1	YES	255
28@1pm	1.2	37.5	45.0	11.0	7.30	41.0	YES	255
29@1pm	1.2	37.5	45.0	11.0	7.30	41.0	YES	255
30@1pm	1.3	37.5	48.8	11.0	7.30	41.5	YES	255
31@1pm								

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
 dwp.dnce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97283-0350

REVIEWED (D. DeLeon)