

OHA - Drinking Water Services -Turbidity Monitoring Report Form


County: **Curry**

Conventional or Direct Filtration

Month/Year: **Jan. 2022**

System Name:	City of Port Orford		4100670		WTP-A:		WTP-A:
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1			0.02				0.02
2			0.03	0.03	0.03		0.03
3			PLANT	OFF			
4			PLANT	OFF			
5				0.03	0.03		0.03
6			0.03	0.03	0.03	0.03	0.03
7				0.03	0.03	0.03	0.03
8			0.03	0.03	0.03	0.03	0.03
9			0.03	0.03	0.03	0.03	0.03
10			0.03	0.03	0.03	0.03	0.03
11			0.03	0.03	0.03	0.03	0.03
12			0.03	0.03	0.03	0.03	0.03
13			0.03	0.04	0.04	0.04	0.04
14			0.04	0.04	0.04		0.04
15			0.04	0.04	0.04	0.04	0.04
16			0.04	0.04	0.04		0.04
17			0.04	0.04	0.04		0.04
18			0.04	0.04	0.04	0.04	0.04
19			0.02	0.02	0.02	0.02	0.02
20			0.02	0.02	0.02	0.02	0.02
21			0.02	0.02	0.02	0.02	0.02
22			0.02	0.02	0.02		0.02
23			0.02	0.02	0.02		0.02
24			0.02	0.02	0.02		0.02
25			0.03	0.02	0.03		0.03
26			0.02	0.02	0.02		0.02
27			0.02	0.02	0.02	0.02	0.02
28			0.02	0.02	0.02		0.02
29			0.02	0.02	0.02		0.02
30			0.02	0.02	0.02		0.02
31			0.02	0.02	0.02		0.02

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	Yes / No	Yes / No
All turbidity readings < IFE ² triggers	Yes / No	Yes / No

Notes: Digitally signed by Dave Terrusa DN: cn=Dave Terrusa, c=US, o=H2O System Consulting, ou=DRG, email=treatment6930@gmail.com Reason: I have reviewed this document Location: (541) 253-7556 Date: 2022.02.01 21:36:55 -08'00'		
	David Terrusa SIGNATURE: /s/ Dave Terrusa	
	541-253-7556	Feb 1, 2022 CERT# 6930

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP-A:

System Name: City of Port Orford	ID# 4100670	Month/Year: Jan. 2022	Disinfection Giardia Log Inactive:	1
---	--------------------	------------------------------	---	---

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm ormg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1@8:40am	1.4	37.5	52.5	9.0	7.40	49.6	YES	255
2@1pm	1.3	37.5	48.8	9.0	7.30	47.4	YES	255
3@1pm				NO	ENTRIES			
4@1pm				NO	ENTRIES			
5@1pm	1.3	37.5	48.8	10.0	7.30	44.3	YES	255
6@1pm	1.3	37.5	48.8	10.0	7.20	42.8	YES	255
7@1:30pm	1.2	37.5	45.0	10.0	7.20	42.3	YES	255
8@1pm	1.3	37.5	48.8	10.0	7.20	42.8	YES	255
9@1pm	1.3	37.5	48.8	9.0	7.30	47.4	YES	255
10@1pm	1.3	37.5	48.8	10.0	7.20	42.8	YES	255
11@1pm	1.3	37.5	48.8	10.0	7.30	44.3	YES	255
12@1pm	1.2	37.5	45.0	11.0	7.30	41.0	YES	255
13@1pm	1.3	37.5	48.8	10.0	7.20	42.8	YES	255
14@1pm	1.2	37.5	45.0	11.0	7.30	41.0	YES	255
15@1pm	1.1	37.5	41.3	11.0	7.20	39.2	YES	255
16@1pm	1.3	37.5	48.8	10.0	7.20	42.8	YES	255
17@1pm	1.3	37.5	48.8	10.0	7.20	42.8	YES	255
18@1pm	1.3	37.5	48.8	12.0	7.20	37.6	YES	255
19@1pm	1.3	37.5	48.8	10.0	7.30	44.3	YES	255
20@1pm	1.3	37.5	48.8	10.0	7.20	42.8	YES	255
21@1pm	1.4	37.5	52.5	10.0	7.20	43.3	YES	255
22@1pm	1.3	37.5	48.8	9.0	7.20	45.7	YES	255
23@1pm	1.2	37.5	45.0	10.0	7.30	43.8	YES	255
24@1pm	1.3	37.5	48.8	10.0	7.30	44.3	YES	255
25@1pm	1.3	37.5	48.8	9.0	7.30	47.4	YES	255
26@1pm	1.2	37.5	45.0	9.0	7.20	45.2	YES	255
27@1pm	1.4	37.5	52.5	9.0	7.40	49.6	YES	255
28@1pm	1.4	37.5	52.5	8.0	7.30	51.2	YES	255
29@1pm	1.4	37.5	52.5	8.0	7.30	51.2	YES	255
30@1pm	1.3	37.5	48.8	9.0	7.30	47.4	YES	255
31@1pm	1.3	37.5	48.8	9.0	7.20	45.7	YES	255

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350