

OHA - Drinking Water Services -Turbidity Monitoring Report Form

Conventional or Direct Filtration

County: Curry

Month/Year: Feb. 2022

System Name: City of Port Orford 4100670

WTP-A: WTP-A:

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1			0.02	0.02	0.02		0.02
2			0.02	0.02	0.02		0.02
3			0.02	0.02			0.02
4			0.02	0.02	0.02		0.02
5			0.02	0.02	0.02		0.02
6			0.03	0.03	0.03		0.03
7			0.03	0.03	0.03		0.03
8			0.02	0.02	0.02		0.02
9			0.02	0.02	0.02		0.02
10			0.02	0.02	0.02		0.02
11			0.02	0.02	0.02		0.02
12			0.02	0.02	0.02		0.02
13			0.02	0.02	0.02		0.02
14			0.02	0.02	0.02	0.03	0.03
15			0.02	0.02	0.02		0.02
16			0.02	0.02	0.02		0.02
17			0.02	0.02	0.02		0.02
18			0.02	0.02	0.02		0.02
19			0.02	0.02	0.02		0.02
20			0.02	0.02	0.02	0.02	0.02
21			0.02	0.02			0.02
22			0.03	0.03	0.02	0.02	0.03
23			0.02	0.02	0.02	0.02	0.02
24			0.02	0.02	0.02		0.02
25			0.02	0.02	0.02		0.02
26			0.02	0.02	0.02		0.02
27			0.03	0.03	0.03		0.03
28				Plant	Off		
29							
30							
31							

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes: Digitally signed by Dave Terrusa DN: cn=Dave Terrusa, c=US, o=H2o System Consulting, ou=DRC, email=treatment8930@gmail.com Reason: I have reviewed this document Location: (541) 253-7556 Date: 2022.03.03 10:34:14 -08'00'	David Terrusa	
	SIGNATURE:	
	541-253-7556	CERT# 6930

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP-A:

System Name:	City of Port Orford	ID# 4100670	Month/Year:	Feb. 2022	Disinfection <i>Giardia</i> Log Inactive:	1
--------------	---------------------	-------------	-------------	-----------	---	---

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm ormg/l]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1@1pm	1.4	37.5	52.5	8.0	7.30	51.2	YES	255
2@1pm	1.4	37.5	52.5	8.0	7.30	51.2	YES	255
3@1pm	1.4	37.5	52.5	9.0	7.20	46.2	YES	255
4@1pm	1.3	37.5	48.8	9.0	7.30	47.4	YES	255
5@1pm	1.4	37.5	52.5	9.0	7.30	47.9	YES	255
6@1pm	1.4	37.5	52.5	8.0	7.20	49.4	YES	255
7@1pm	1.4	37.5	52.5	8.0	7.30	51.2	YES	255
8@1pm	1.4	37.5	52.5	9.0	7.30	47.9	YES	255
9@1pm	1.3	37.5	48.8	10.0	7.40	45.9	YES	255
10@1pm	1.3	37.5	48.8	10.0	7.20	42.8	YES	255
11@1pm	1.3	37.5	48.8	10.0	7.30	44.3	YES	255
12@1pm	1.3	37.5	48.8	10.0	7.30	44.3	YES	255
13@1pm	1.3	37.5	48.8	10.0	7.30	44.3	YES	255
14@1pm	1.4	37.5	52.5	10.0	7.20	43.3	YES	255
15@1pm	1.4	37.5	52.5	9.0	7.40	49.6	YES	255
16@1pm	1.4	37.5	52.5	9.0	7.30	47.9	YES	255
17@1pm	1.2	37.5	45.0	10.0	7.30	43.8	YES	255
18@1pm	1.3	37.5	48.8	10.0	7.30	44.3	YES	255
19@1pm	1.3	37.5	48.8	10.0	7.40	45.9	YES	255
20@1pm	1.3	37.5	48.8	9.0	7.30	47.4	YES	255
21@1pm	1.3	37.5	48.8	9.0	7.30	47.4	YES	255
22@1pm	1.4	37.5	52.5	8.0	7.30	51.2	YES	255
23@1pm	1.5	37.5	56.3	7.0	7.30	55.4	YES	255
24@1pm	1.5	37.5	56.3	7.0	7.30	55.4	YES	255
25@1pm	1.5	37.5	56.3	7.0	7.20	53.4	YES	255
26@1pm	1.4	37.5	52.5	8.0	7.20	49.4	YES	255
27@1pm	1.4	37.5	52.5	8.0	7.20	49.4	YES	255
28@1pm				Plant	Off			
29@1pm								
30@1pm								
31@1pm								

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
 dwp.dnce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350