

**OHA - Drinking Water Services -Turbidity Monitoring Report Form**  
**Conventional or Direct Filtration**

County: **Curry**  
 Month/Year: **Dec. 2022**

System Name:		City of Port Orford		4100670		WTP-A: WTP-A:	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1					0.02	0.02	0.02
2			0.02	0.02	0.02	0.02	0.02
3			0.02	0.02	0.02	0.02	0.02
4			0.02	0.02	0.02		0.02
5			0.02	0.02	0.02		0.02
6			0.02	0.02	0.02		0.02
7			0.02	0.02	0.02	0.02	0.02
8			0.02				0.02
9				Plant Off			
10				Plant Off			
11				0.02	0.02	0.02	0.02
12			0.02	0.02	0.02	0.02	0.02
13			0.02	0.02	0.02	0.02	0.02
14			0.02	0.02	0.02	0.02	0.02
15			0.02	0.02	0.02	0.02	0.02
16			0.02	0.02	0.02	0.02	0.02
17			0.02	0.02	0.02		0.02
18			0.02	0.02			0.02
19			0.02	0.02	0.02	0.02	0.02
20			0.02	0.02	0.02		0.02
21				Plant Off			
22			0.02	0.02	0.02	0.02	0.02
23	0.02		0.02				0.02
24			0.02	0.02	0.02	0.02	0.02
25				0.02	0.02	0.02	0.02
26			0.02	0.02			0.02
27				Plant Off			
28			0.02	0.02	0.02	0.02	0.02
29			0.02	0.02	0.02		0.02
30			0.02	0.02	0.02		0.02
31			0.02	0.02	0.02	0.02	0.02

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? All 4-hour turbidity readings ≤ 1 NTU? All turbidity readings < IFE <sup>2</sup> triggers	CT's met everyday? (see back)	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l?
Yes/No Yes/No Yes/No	Yes/No	Yes/No

Notes:	<b>David Terrusa</b>	
	<b>SIGNATURE:</b> /S/ Dave Terrusa	1/6/2023
	<b>541-253-7556</b>	<b>CERT# 6930</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP-A:

System Name: City of Port Orford	ID# 4100670	Month/Year: Dec. 2022	Disinfection <i>Giardia</i> Log Inactive: 1
----------------------------------	-------------	-----------------------	---

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm ormg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1@4pm	1.3	37.5	48.8	9.0	7.30	47.4	YES	255
2@1pm	1.4	37.5	52.5	8.0	7.20	49.4	YES	255
3@1pm	1.4	37.5	52.5	9.0	7.40	49.6	YES	255
4@1pm	1.5	37.5	56.3	9.0	7.20	46.8	YES	255
5@1pm	1.4	37.5	52.5	9.0	7.30	47.9	YES	255
6@1pm	1.4	37.5	52.5	8.0	7.30	51.2	YES	255
7@1pm	1.4	37.5	52.5	8.0	7.20	49.4	YES	255
8@10am	1.3	37.5	48.8	9.0	7.20	45.7	YES	255
9@1pm				Plant Off				
10@1pm				Plant Off				
11@1pm	1.4	37.5	52.5	9.0	7.30	47.9	YES	255
12@1pm	1.4	37.5	52.5	9.0	7.30	47.9	YES	255
13@1pm	1.4	37.5	52.5	8.0	7.30	51.2	YES	255
14@1pm	1.4	37.5	52.5	8.0	7.20	49.4	YES	255
15@1pm	1.4	37.5	52.5	8.0	7.30	51.2	YES	255
16@1pm	1.5	37.5	56.3	7.0	7.20	53.4	YES	255
17@1pm	1.5	37.5	56.3	8.0	7.20	50.0	YES	255
18@1pm	1.5	37.5	56.3	7.0	7.20	53.4	YES	255
19@1pm	1.5	37.5	56.3	7.0	7.20	53.4	YES	255
20@1pm	1.5	37.5	56.3	9.0	7.30	48.4	YES	255
21@1pm				Plant Off				
22@1pm	1.5	37.5	56.3	9.0	7.20	46.8	YES	255
23@10am	1.5	37.5	56.3	10.0	7.20	43.8	YES	255
24@1pm	1.5	37.5	56.3	11.0	7.30	42.4	YES	255
25@9:30am	1.4	37.5	52.5	10.0	7.20	43.3	YES	255
26@9:30am	1.3	37.5	48.8	11.0	7.30	41.5	YES	255
27@1pm				Plant Off				
28@4pm	1.3	37.5	48.8	11.0	7.20	40.1	YES	255
29@1pm	1.2	37.5	45.0	11.0	7.20	39.6	YES	255
30@1pm	1.3	37.5	48.8	11.0	7.30	41.5	YES	255
31@1pm	1.2	37.5	45.0	11.0	7.30	41.0	YES	255

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:  
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350