

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: **Curry**
 Month/Year: **Jun-23**

Conventional or Direct Filtration

System Name:	City of Port Orford		4100670				WTP-A:	WTP-A:
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1			0.02	0.02	0.02	0.02	0.02	
2	0.02		0.02	0.02	0.02	0.02	0.02	
3			0.02	0.02	0.02		0.02	
4			0.02	0.02	0.02	0.02	0.02	
5			0.02	0.02	0.02	0.02	0.02	
6			0.02	0.02	0.02		0.02	
7			0.02				0.02	
8			0.02	0.02	0.02	0.02	0.02	
9			0.02	0.02	0.02	0.02	0.02	
10	0.02		0.02	0.02	0.02		0.02	
11			0.02	0.02	0.02	0.02	0.02	
12			0.02	0.02	0.02	0.02	0.02	
13			0.02	0.02	0.02	0.01	0.02	
14	0.01		0.01	1.00	0.02		0.02	
15			0.01	0.01	0.01		0.01	
16			0.01	0.01	0.01	0.01	0.01	
17			0.01	0.01	0.01		0.01	
18			0.01	0.01	0.01		0.01	
19				0.02	0.01		0.02	
20				0.02	0.02	0.01	0.02	
21			0.02	0.01	0.01	0.01	0.02	
22			0.02	0.01	0.01		0.02	
23			0.02	0.01	0.01	0.01	0.02	
24			0.01	0.02	0.02	0.01	0.02	
25			0.02	0.01	0.01	0.01	0.02	
26			0.02	0.02	0.02	0.02	0.02	
27			0.02	0.02	0.01	0.01	0.02	
28			0.02	0.02	0.02	0.02	0.02	
29			0.02	0.02	0.02	0.02	0.02	
30			0.02	0.02	0.02	0.02	0.02	
31								

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? Yes/No	CT's met everyday? (see back) Yes/No	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes/No
All 4-hour turbidity readings ≤ 1 NTU? Yes/No		
All turbidity readings < IFE ² triggers Yes/No		
Notes:	David Terrusa	
	SIGNATURE: <i>David Terrusa</i> 6 July 23	
	541-253-7556 CERT# 6930	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP-A:

System Name:	City of Port Orford	ID# 4100670	Month/Year:	Jun-23	Disinfection <i>Giardia</i> Log Inactive:	1
--------------	---------------------	-------------	-------------	--------	---	---

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm ormg/l]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1@1pm	1.2	37.5	45.0	13.0	7.20	34.3	YES	255
2@1pm	1.2	37.5	45.0	13.0	7.20	34.3	YES	255
3@1pm	1.2	37.5	45.0	13.0	7.20	34.3	YES	255
4@1pm	1.2	37.5	45.0	13.0	7.30	35.6	YES	255
5@1pm	1.2	37.5	45.0	13.0	7.20	34.3	YES	255
6@1pm	1.2	37.5	45.0	14.0	7.20	32.1	YES	255
7@1pm	1.2	37.5	45.0	13.0	7.20	34.3	YES	255
8@1pm	1.2	37.5	45.0	14.0	7.20	32.1	YES	255
9@1pm	1.2	37.5	45.0	14.0	7.20	32.1	YES	255
10@1pm	1.2	37.5	45.0	14.0	7.20	32.1	YES	255
11@1pm	1.2	37.5	45.0	14.0	7.20	32.1	YES	255
12@1pm	1.2	37.5	45.0	14.0	7.20	32.1	YES	255
13@1pm	1.2	37.5	45.0	14.0	7.20	32.1	YES	255
14@1pm	1.2	37.5	45.0	14.0	7.20	32.1	YES	255
15@1pm	1.1	37.5	41.3	14.0	7.20	31.7	YES	255
16@1pm	1.1	37.5	41.3	14.0	7.30	32.9	YES	255
17@1pm	1.1	37.5	41.3	14.0	7.30	32.9	YES	255
18@1pm	1.2	37.5	45.0	14.0	7.20	32.1	YES	255
19@1pm	1.3	37.5	48.8	13.0	7.30	36.0	YES	255
20@1pm	1.2	37.5	45.0	15.0	7.20	30.0	YES	255
21@1pm	1.1	37.5	41.3	13.0	7.20	33.9	YES	255
22@1pm	1.2	37.5	45.0	14.0	7.20	32.1	YES	255
23@1pm	1.2	37.5	45.0	14.0	7.20	32.1	YES	255
24@1pm	1.2	37.5	45.0	14.0	7.20	32.1	YES	255
25@1pm	1.2	37.5	45.0	14.0	7.20	32.1	YES	255
26@1pm	1.2	37.5	45.0	14.0	7.20	32.1	YES	255
27@1pm	1.2	37.5	45.0	15.0	7.20	30.0	YES	255
28@1pm	1.2	37.5	45.0	15.0	7.30	31.1	YES	255
29@1pm	1.2	37.5	45.0	15.0	7.20	30.0	YES	255
30@1pm	1.2	37.5	45.0	15.0	7.20	30.0	YES	255
31@1pm								

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350