

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Curry

Conventional or Direct Filtration

Month/Year: Jul-25

System Name:		City of Port Orford		ID#: 41 00670		WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1			0.03	0.03	0.03	0.03	0.03
2			0.03	0.03	0.03	0.03	0.03
3			0.03	0.03	0.04	0.04	0.04
4			0.04	0.04	0.04	0.04	0.04
5			0.04	0.04	0.04	0.04	0.04
6			0.03	0.02	0.02	0.02	0.03
7			0.02	0.02	0.02	0.02	0.02
8			0.02	0.02	0.02	0.02	0.02
9			0.03	0.03	0.03	0.02	0.03
10			0.03	0.03	0.03	0.03	0.03
11			0.03	0.03	0.04	0.04	0.04
12			0.04	0.04	0.04	0.04	0.04
13			0.02	0.02	0.02	0.02	0.02
14			0.03	0.03	0.03	0.03	0.03
15			0.04	0.03	0.03	0.03	0.04
16			0.02	0.02	0.02	0.03	0.03
17			0.02	0.03	0.03	0.03	0.03
18			0.02	0.03	0.03	0.03	0.02
19	0.04	0.04	0.03	0.03	0.03		0.04
20			0.03	0.03	0.03	0.03	0.03
21			0.03	0.03	0.03	0.04	0.04
22			0.03	0.02	0.02	0.02	0.03
23			0.02	0.02	0.02	0.03	0.03
24	0.03		0.03	0.03	0.03	0.04	0.04
25			0.03	0.02	0.02	0.02	0.03
26	0.02	0.03	0.02	0.02	0.02	0.02	0.03
27			0.03	0.03	0.03	0.03	0.03
28			0.04	0.03	0.03	0.03	0.04
29			0.04	0.05	0.05	0.05	0.05
30	0.04	0.04	0.04	0.02	0.02	0.02	0.04
31	0.02	0.02	0.02	0.02	0.02	0.02	0.02

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	Yes	CT's met everyday? (see back)	All Cl ₂ residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?	Yes	Yes	Yes
All turbidity readings < IFE ² triggers	Yes		

Notes:	PRINTED NAME: David Terrusa	
	SIGNATURE: /S/ David Terrusa	DATE: 8/4/25
	PHONE #: (541) 254-7556	CERT #: 6930

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form
WTP - : A

System Name:	City of Port Orford	ID#: 41-00670	Month/Year:	Jul-25	Disinfection <i>Giardia</i> Log Inactive:	1
---------------------	----------------------------	----------------------	--------------------	---------------	--	----------

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1	127	127.0	15.0	7.20	29.3	YES	350
2	1	127	127.0	15.0	7.20	29.3	YES	350
3	1	127	127.0	16.0	7.20	27.4	YES	350
4	1.1	127	139.7	16.0	7.30	28.8	YES	350
5	1.1	127	139.7	14.0	7.20	31.7	YES	350
6	1	127	127.0	15.0	7.20	29.3	YES	350
7	1	127	127.0	15.0	7.30	30.4	YES	350
8	1	127	127.0	15.0	7.30	30.4	YES	350
9	1	127	127.0	15.0	7.20	29.3	YES	350
10	1.1	127	139.7	15.0	7.30	30.8	YES	350
11	1.1	127	139.7	17.0	7.20	26.0	YES	350
12	1	127	127.0	15.0	7.20	29.3	YES	350
13	1	127	127.0	15.0	7.20	29.3	YES	270
14	1.1	127	139.7	15.0	7.20	29.7	YES	270
15	1.1	127	139.7	15.0	7.20	29.7	YES	270
16	1.1	127	139.7	16.0	7.30	28.8	YES	270
17	1.1	127	139.7	15.0	7.30	30.8	YES	270
18	1.1	127	139.7	15.0	7.20	29.7	YES	270
19	1.1	127	139.7	15.0	7.20	29.7	YES	270
20	1	127	127.0	15.0	7.20	29.3	YES	270
21	1	127	127.0	16.0	7.30	28.5	YES	270
22	1.1	127	139.7	15.0	7.20	29.7	YES	270
23	1.1	127	139.7	16.0	7.20	27.8	YES	270
24	1	127	127.0	16.0	7.20	27.4	YES	270
25	1	127	127.0	16.0	7.20	27.4	YES	270
26	1	127	127.0	16.0	7.30	28.5	YES	270
27	0.9	127	114.3	15.0	7.20	29.0	YES	270
28	1	127	127.0	16.0	7.20	27.4	YES	270
29	1	127	127.0	16.0	7.20	27.4	YES	270
30	1	127	127.0	16.0	7.30	28.5	YES	270
31	1	127	127.0	16.0	7.20	27.4	YES	270

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350