

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: **Curry**

Conventional or Direct Filtration

Month/Year: **Jan. 2021**

System Name: **City of Port Orford** **4100670** **WTP-A: WTP-A:**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	0.03	0.02	0.02	0.03	0.03		0.03
2			0.02	0.02	0.03		0.03
3			NO	ENTRIES			
4			0.03				0.03
5			0.03	0.02	0.02	0.03	0.03
6	0.02	0.04					0.04
7			0.03	0.03	0.03	0.03	0.03
8	0.03		0.03	0.03	0.03	0.03	0.03
9	0.03	0.03	0.03	0.03	0.03	0.03	0.03
10	0.03		0.03	0.03	0.03	0.03	0.03
11	0.03		0.03	0.03	0.03	0.03	0.03
12			NO	ENTRIES			
13			NO	ENTRIES			
14				0.03	0.03	0.03	0.03
15	0.03	0.03	0.03	0.03	0.03	0.03	0.03
16	0.03		0.03	0.03	0.03	0.03	0.03
17			0.03	0.03	0.03	0.03	0.03
18	0.03		0.03	0.03	0.03	0.03	0.03
19	0.03		0.03	0.03	0.03	0.03	0.03
20	0.03		0.03	0.03	0.03	0.03	0.03
21	0.03		0.03	0.03	0.03	0.03	0.03
22	0.03		0.03	0.03	0.03	0.03	0.03
23	0.03		0.03	0.03	0.03	0.03	0.03
24	0.03		0.03	0.03			0.03
25			0.03	0.03	0.03	0.03	0.03
26	0.03		0.03	0.03	0.03	0.03	0.03
27				0.03	0.03	0.03	0.03
28				0.03	0.03	0.03	0.03
29			0.03	0.03	0.03	0.03	0.03
30	0.03	0.03	0.03	0.03	0.03		0.03
31			NO	ENTRIES			

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / No		
All turbidity readings < IFE <sup>2</sup> triggers <input checked="" type="radio"/> Yes / No		

Notes: **David Terrusa**  
**SIGNATURE:**  
**541-253-7556** **CERT# 6930**

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP-A:

System Name:	City of Port Orford	ID# 4100670	Month/Year:	Jan. 2021	Disinfection <i>Giardia</i> Log Inactive:	1
--------------	---------------------	-------------	-------------	-----------	---	---

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup> [ppm ormg/l]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? <sup>3</sup> Yes / No	Peak Hourly Demand Flow [GPM]
1@1pm	1.3	37.5	48.8	10.0	7.30	44.3	YES	255
2@1pm	1.2	37.5	45.0	10.0	7.20	42.3	YES	255
3@1pm				NO	ENTRIES			
4@8am	1.2	37.5	45.0	10.0	7.20	42.3	YES	255
5@1pm	1.2	37.5	45.0	11.0	7.20	39.6	YES	255
6@1pm	1.2	37.5	45.0	10.0	7.30	43.8	YES	255
7@1pm	1.3	37.5	48.8	10.0	7.20	42.8	YES	255
8@1pm	1.2	37.5	45.0	11.0	7.20	39.6	YES	255
9@1pm	1.2	37.5	45.0	10.0	7.30	43.8	YES	255
10@1pm	1.2	37.5	45.0	11.0	7.20	39.6	YES	255
11@1pm	1.2	37.5	45.0	11.0	7.30	41.0	YES	255
12@1pm				NO	ENTRIES			
13@1pm				NO	ENTRIES			
14@1pm	1.2	37.5	45.0	11.0	7.30	41.0	YES	255
15@1pm	1.2	37.5	45.0	11.0	7.20	39.6	YES	255
16@1pm	1.2	37.5	45.0	11.0	7.30	41.0	YES	255
17@1pm	1.2	37.5	45.0	11.0	7.30	41.0	YES	255
18@1pm	1.2	37.5	45.0	11.0	7.30	41.0	YES	255
19@1pm	1.2	37.5	45.0	10.0	7.30	43.8	YES	255
20@1pm	1.2	37.5	45.0	10.0	7.20	42.3	YES	255
21@1pm	1.2	37.5	45.0	10.0	7.20	42.3	YES	255
22@1pm	1.3	37.5	48.8	10.0	7.30	44.3	YES	255
23@1pm	1.3	37.5	48.8	9.0	7.30	47.4	YES	255
24@1pm	1.3	37.5	48.8	9.0	7.30	47.4	YES	255
25@1pm	1.3	37.5	48.8	9.0	7.20	45.7	YES	255
26@1pm	1.3	37.5	48.8	9.0	7.20	45.7	YES	255
27@1pm	1.3	37.5	48.8	9.0	7.20	45.7	YES	255
28@1pm	1.3	37.5	48.8	9.0	7.20	45.7	YES	255
29@1pm	1.3	37.5	48.8	9.0	7.20	45.7	YES	255
30@1pm	1.3	37.5	48.8	9.0	7.30	47.4	YES	255
31@1pm				NO	ENTRIES			

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:  
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350