

OHA - Drinking Water Services -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County:

Curry

 Month/Year:

Dec 2021

System Name:	City of Port Orford		4100670				WTP-A:	WTP-A:
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1			0.02	0.02	0.02		0.02	
2			0.02	0.02	0.02	0.02	0.02	
3			0.02	0.02	0.02		0.02	
4			0.02	0.02	0.02		0.02	
5			0.02	0.02	0.02		0.02	
6			0.02	0.02	0.02		0.02	
7			0.02	0.02	0.02		0.02	
8				0.02	0.02		0.02	
9			0.02	0.02	0.02		0.02	
10			0.02	0.02	0.02	0.02	0.02	
11			No	Entries				
12			No	Entries				
13			No	Entries				
14			0.03	0.02	0.02	0.02	0.03	
15			No	Entries				
16			0.02	0.02	0.02	0.02	0.02	
17	0.02		0.02	0.02	0.02	0.02	0.02	
18	0.02		0.02	0.02	0.02	0.02	0.02	
19			0.02				0.02	
20				0.02	0.02		0.02	
21			0.02	0.02	0.02	0.02	0.02	
22			0.02	0.02	0.02		0.02	
23			0.02	0.02	0.02	0.02	0.02	
24	0.02		0.02	0.02	0.02	0.02	0.02	
25			0.02				0.02	
26			0.02	0.02	0.02		0.02	
27			0.02	0.02	0.02		0.02	
28			0.02	0.02	0.02	0.02	0.02	
29			0.02	0.02	0.02	0.02	0.02	
30			0.02	0.03	0.02	0.02	0.03	
31			0.02	0.02	0.02	0.02	0.02	

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	Yes / No	CT's met everyday? (see back)
All 4-hour turbidity readings ≤ 1 NTU?	Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l?
All turbidity readings < IFE ² triggers	Yes / No	Yes / No

Notes:  Digitally signed by Dave Terrusa DN: cn=Dave Terrusa, c=US, o=H2o System Consulting, ou=DRC, email=treatment6930@gmail.com Reason: I have reviewed this document Location: (541) 253-7556 Date: 2022.01.05 23:49:45 -08'00'	David Terrusa SIGNATURE:
	541-253-7556 CERT# 6930

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Efl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP-A:

System Name: City of Port Orford	ID# 4100670	Month/Year:	Disinfection <i>Giardia</i> Log Inactive:	1
---	--------------------	--------------------	--	---

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm ormg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1@1pm	1.3	37.5	48.8	11.0	7.30	41.5	YES	255
2@1pm	1.2	37.5	45.0	11.0	7.20	39.6	YES	255
3@1pm	1.3	37.5	48.8	11.0	7.20	40.1	YES	255
4@1pm	1.3	37.5	48.8	11.0	7.30	41.5	YES	255
5@1pm	1.3	37.5	48.8	11.0	7.30	41.5	YES	255
6@1pm	1.2	37.5	45.0	11.0	7.20	39.6	YES	255
7@1pm	1.3	37.5	48.8	11.0	7.20	40.1	YES	255
8@1pm	1.3	37.5	48.8	11.0	7.30	41.5	YES	255
9@1pm	1.2	37.5	45.0	10.0	7.20	42.3	YES	255
10@1pm	1.3	37.5	48.8	9.0	7.30	47.4	YES	255
11@1pm				NO	ENTRIES			
12@1pm				NO	ENTRIES			
13@1pm				NO	ENTRIES			
14@1pm	1.3	37.5	48.8	11.0	7.20	40.1	YES	255
15@1pm				NO	ENTRIES			
16@1pm	1.2	37.5	45.0	10.0	7.30	43.8	YES	255
17@1pm	1.3	37.5	48.8	10.0	7.20	42.8	YES	255
18@1pm	1.2	37.5	45.0	10.0	7.20	42.3	YES	255
19@9AM	1.2	37.5	45.0	10.0	7.30	43.8	YES	255
20@1pm	1.3	37.5	48.8	11.0	7.20	40.1	YES	255
21@1pm	1.3	37.5	48.8	11.0	7.20	40.1	YES	255
22@1pm	1.3	37.5	48.8	11.0	7.20	40.1	YES	255
23@1pm	1.3	37.5	48.8	11.0	7.20	40.1	YES	255
24@1pm	1.3	37.5	48.8	10.0	7.20	42.8	YES	255
25@8:30AM	1.2	37.5	45.0	10.0	7.20	42.3	YES	255
26@1pm	1.3	37.5	48.8	9.0	7.30	47.4	YES	255
27@1pm	1.3	37.5	48.8	9.0	7.30	47.4	YES	255
28@1pm	1.3	37.5	48.8	9.0	7.20	45.7	YES	255
29@1pm	1.4	37.5	52.5	9.0	7.20	46.2	YES	255
30@1pm	1.4	37.5	52.5	9.0	7.20	46.2	YES	255
31@1pm	1.4	37.5	52.5	9.0	7.20	46.2	YES	255

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350