


OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Grant**
 Month/Year: **Nov-25**

System Name: **Prairie City** ID# **41** **00673** WTP : TP - **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1							0.03
2							0.07
3							0.08
4							0.07
5							0.08
6							0.10
7							0.10
8							0.10
9							0.08
10							0.08
11							0.09
12							0.08
13							0.07
14							0.08
15							0.06
16							0.07
17							0.07
18							0.09
19							0.09
20							0.10
21							0.09
22							0.09
23							0.08
24							0.08
25							0.09
26							0.09
27							0.10
28							0.10
29							0.09
30							0.09
31							0.08

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes / No	CT's met everyday? (see back) Yes / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? Yes / No
All daily turbidity readings ≤ 5 NTU? Yes / No		

Notes:	PRINTED NAME: Michiel Patterson	
	SIGNATURE: 	12/9/2025
	PHONE # (541)820-3636	CERT # 400250

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A
 Disinfection *Giardia* Log
 Inactiv: 1.0

System Name: **Prairie City** ID# **41** 00673 Month/Year: **Sep-25**

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)+7	Actual CT	Temp	pH	Required CT	CT Met? ³	Plant Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.6	290	174.0	15.0	8.00	37.7	YES	167
2	0.8	372	297.6	15.0	8.00	38.6	YES	178
3	0.8	341	272.8	15.0	8.00	38.6	YES	145
4	0.7	512	358.4	15.0	8.00	38.1	YES	96
5	0.6	662	397.2	15.0	8.00	37.7	YES	74
6	0.6	358	214.8	15.0	8.00	37.7	YES	138
7	0.6	314	188.4	15.0	8.00	37.7	YES	158
8	0.5	314	157.0	15.0	8.00	37.3	YES	158
9	0.5	314	157.0	15.0	8.00	37.3	YES	158
10	0.5	316	158.0	15.0	8.00	37.3	YES	157
11	0.5	314	157.0	15.0	8.00	37.3	YES	158
12	0.5	316	158.0	15.0	8.00	37.3	YES	157
13	0.5	316	158.0	15.0	8.00	37.3	YES	157
14	0.5	314	157.0	15.0	8.00	37.3	YES	158
15	0.5	316	158.0	15.0	8.00	37.3	YES	157
16	0.5	312	156.0	15.0	8.00	37.3	YES	159
17	0.5	314	157.0	15.0	8.00	37.3	YES	158
18	0.5	316	158.0	15.0	8.00	37.3	YES	157
19	0.5	314	157.0	15.0	8.00	37.3	YES	158
20	0.5	314	157.0	15.0	8.00	37.3	YES	158
21	0.5	318	159.0	15.0	8.00	37.3	YES	156
22	0.5	278	139.0	15.0	8.00	37.3	YES	174
23	0.5	319	159.5	15.0	8.00	37.3	YES	152
24	0.5	334	167.0	15.0	8.00	37.3	YES	148
25	0.5	425	212.5	15.0	8.00	37.3	YES	116
26	0.5	443	221.5	15.0	8.00	37.3	YES	112
27	0.5	440	220.0	15.0	8.00	37.3	YES	112
28	0.5	316	158.0	15.0	8.00	37.3	YES	157
29	0.5	314	157.0	15.0	8.00	37.3	YES	158
30	0.5	316	158.0	15.0	8.00	37.3	YES	157
31								

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

±

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350