

OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Grant**
 Month/Year: **Feb-26**

System Name: **Prairie City** ID# **41** 00673 WTP: **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1							0.07
2							0.07
3							0.06
4							0.07
5							0.09
6							0.07
7							0.07
8							0.07
9							0.08
10							0.07
11							0.08
12							0.08
13							0.08
14							0.08
15							0.08
16							0.08
17							0.08
18							0.08
19							0.08
20							0.07
21							0.08
22							0.07
23							0.08
24							0.07
25							0.07
26							0.07
27							0.08
28							0.08
29							
30							
31							

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	Yes / No	CT's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes / No	Yes / No	Yes / No

Notes:	PRINTED NAME: Michiel Patterson	
	SIGNATURE: <i>Michiel Patterson</i>	3/4/2026
	PHONE # (541)820-3636	CERT # 400250

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

System Name: **Prairie City** ID# **41** 00673 Month/Year: **Nov-25** Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)+7	Actual CT	Temp	pH	Required CT	CT Met? ³	Plant Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.5	326	163.0	10.0	8.00	51.9	YES	152
2	0.5	334	167.0	10.0	8.00	51.9	YES	148
3	0.5	328	164.0	10.0	8.00	51.9	YES	151
4	0.6	328	196.8	10.0	8.00	52.5	YES	151
5	0.5	316	158.0	10.0	8.00	51.9	YES	157
6	0.5	302	151.0	10.0	8.00	51.9	YES	164
7	0.5	318	159.0	10.0	8.00	51.9	YES	156
8	0.4	312	124.8	10.0	8.00	51.3	YES	159
9	0.3	343	102.9	10.0	8.00	50.7	YES	144
10	0.4	310	124.0	10.0	8.00	51.3	YES	160
11	0.4	302	120.8	10.0	8.00	51.3	YES	164
12	0.5	316	158.0	10.0	8.00	51.9	YES	157
13	0.6	324	194.4	10.0	8.00	52.5	YES	153
14	0.5	247	123.5	10.0	8.00	51.9	YES	196
15	0.6	312	187.2	10.0	8.00	52.5	YES	159
16	0.5	318	159.0	10.0	8.00	51.9	YES	156
17	0.5	361	180.5	10.0	8.00	51.9	YES	137
18	0.5	277	138.5	10.0	8.00	51.9	YES	179
19	0.5	314	157.0	10.0	8.00	51.9	YES	158
20	0.5	312	156.0	10.0	8.00	51.9	YES	159
21	0.5	326	163.0	10.0	8.00	51.9	YES	152
22	0.5	320	160.0	10.0	8.00	51.9	YES	155
23	0.5	337	168.5	10.0	8.00	51.9	YES	147
24	0.5	318	159.0	10.0	8.00	51.9	YES	156
25	0.5	324	162.0	10.0	8.00	51.9	YES	153
26	0.6	327	196.2	10.0	8.00	52.5	YES	151
27	0.5	326	163.0	10.0	8.00	51.9	YES	152
28	0.5	299	149.5	10.0	8.00	51.9	YES	166
29								
30								
31								

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours. ±

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350