

OHA - Drinking Water Services -Turbidity Monitoring Report

County: **Columbia**

Conventional or Direct Filtration

Aug-2025

System Name: **City of Rainier**ID#: **4100689**WTP : **TP -**

Day	12 AM 00:00 [NTU]	4 AM 04:00 [NTU]	8 AM 08:00 [NTU]	NOON 12:00 [NTU]	4 PM 16:00 [NTU]	8 PM 20:00 [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.05	0.05	0.05	0.05	0.06	0.06	0.06
2	0.06	0.05	0.05	0.05	0.06	0.06	0.06
3	0.05	0.05	0.05	0.05	0.05	0.06	0.06
4	0.06	0.05	0.05	0.05	0.05	0.06	0.06
5	0.05	0.14	0.06	0.06	0.06	0.06	0.14
6	0.05	0.05	0.05	0.05	0.06	0.05	0.06
7	0.05	0.06	0.06	0.06	0.06	0.05	0.06
8	0.06	0.05	0.06	0.06	0.05	0.06	0.06
9	0.06	0.06	0.06	0.06	0.06	0.05	0.06
10	0.06	0.06	0.05	0.06	0.06	0.06	0.06
11	0.06	0.06	0.06	0.06	0.06	0.06	0.06
12	0.06	0.06	0.06	0.06	0.06	0.06	0.06
13	0.06	0.06	0.06	0.06	0.06	0.06	0.06
14	0.06	0.06	0.06	0.06	0.06	0.06	0.06
15	0.06	0.06	0.06	0.06	0.06	0.06	0.06
16	0.06	0.06	0.06	0.06	0.06	0.06	0.06
17	0.06	0.06	0.06	0.06	0.05	0.06	0.06
18	0.06	0.06	0.06	0.06	0.06	0.06	0.06
19	0.06	0.06	0.06	0.06	0.06	0.06	0.06
20	0.06	0.06	0.06	0.07	0.06	0.06	0.07
21	0.06	0.06	0.06	0.06	0.06	0.06	0.06
22	0.06	0.07	0.06	0.06	0.06	0.06	0.07
23	0.06	0.06	0.06	0.06	0.06	0.06	0.06
24	0.07	0.06	0.06	0.06	0.07	0.07	0.07
25	0.06	0.06	0.06	0.06	0.06	0.06	0.06
26	0.07	0.06	0.06	0.07	0.06	0.06	0.07
27	0.06	0.06	0.06	0.06	0.06	0.06	0.06
28	0.06	0.06	0.07	0.06	0.07	0.06	0.07
29	0.06	0.07	0.06	0.06	0.07	0.06	0.07
30	0.06	0.07	0.06	0.06	0.06	0.06	0.07
31	0.06	0.06	0.07	0.06	0.06	0.06	0.07

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings $\leq$ 0.3 NTU?**YES**

CT's met everyday?

All Cl₂ residual at entry pointAll 4-hour turbidity readings $\leq$ 1 NTU?**YES**See **YES**
page 2 $\geq$ 0.2 mg/l?**YES**All turbidity readings < IFE² triggers**YES**

Notes:

PRINTED NAME: **Darrel Lockhard**SIGNATURE: *Darrel Lockhard*DATE: **8/8/25**PHONE #: **(541) 222-9997**CERT #: **T2853**

DHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	
System Name: CITY OF RAINIER			ID#: 4100689		Aug-2025		Disinfection Giardia Log Inactive:	0.5
Day	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.7	160.0	107.8	23.0	7.5	9.2	YES	1000
2	0.7	160.0	108.3	23.7	7.5	8.8	YES	1000
3	0.6	160.0	98.9	23.9	7.5	8.6	YES	1000
4	0.7	160.0	104.6	21.9	7.4	9.6	YES	1000
5	0.7	160.0	104.2	21.5	7.4	9.8	YES	1000
6	0.7	160.0	109.0	22.3	7.4	9.3	YES	1000
7	0.7	160.0	111.7	21.2	7.3	9.7	YES	1000
8	0.7	160.0	116.3	21.7	7.3	9.4	YES	1000
9	0.6	160.0	103.5	21.0	7.4	10.1	YES	1000
10	0.7	160.0	105.6	22.0	7.4	9.5	YES	1000
11	0.7	160.0	113.6	23.0	7.4	8.9	YES	1000
12	0.7	160.0	107.8	27.3	7.4	6.6	YES	1000
13	0.8	160.0	130.6	26.1	7.4	7.3	YES	1000
14	0.7	160.0	118.7	24.5	7.4	8.1	YES	1000
15	0.8	160.0	124.2	23.2	7.4	8.9	YES	1000
16	0.7	160.0	113.9	22.6	7.4	9.2	YES	1000
17	0.7	160.0	113.4	22.8	7.4	9.0	YES	1000
18	0.6	160.0	102.1	22.5	7.4	9.2	YES	1000
19	0.6	160.0	96.3	22.0	7.4	9.4	YES	1000
20	0.6	160.0	91.8	22.9	7.4	8.8	YES	1000
21	0.7	160.0	109.4	23.5	7.4	8.6	YES	1000
22	0.8	160.0	121.0	24.4	7.4	8.2	YES	1000
23	0.7	160.0	110.4	25.7	7.4	7.4	YES	1000
24	0.7	160.0	106.7	25.6	7.4	7.4	YES	1000
25	0.7	160.0	106.1	25.0	7.4	7.7	YES	1000
26	0.6	160.0	102.2	24.5	7.4	8.0	YES	1000
27	0.8	160.0	121.1	24.6	7.4	8.0	YES	1000
28	0.8	160.0	121.1	24.0	7.4	8.4	YES	1000
29	0.7	160.0	105.6	23.4	7.4	8.6	YES	1000
30	0.6	160.0	101.6	23.1	7.4	8.8	YES	1000
31	0.7	160.0	116.0	23.4	7.4	8.7	YES	1000