


OHA - Drinking Water Services -Turbidity Monitoring Report Form  
Conventional or Direct Filtration

County: Columbia  
Jun-2023

System Name: City of Rainier ID#: 4100689					WTP : TP -		
Day	12 AM 00:00 [NTU]	4 AM 04:00 [NTU]	8 AM 08:00 [NTU]	NOON 12:00 [NTU]	4 PM 16:00 [NTU]	8 PM 20:00 [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	0.10	0.08	0.13	0.10	OFF	0.08	0.13
2	0.08	0.09	0.12	OFF	0.08	OFF	0.12
3	0.12	OFF	0.12	OFF	0.07	0.08	0.12
4	0.10	0.11	0.08	0.06	OFF	0.08	0.11
5	0.11	0.06	OFF	0.07	OFF	0.07	0.11
6	0.08	0.13	0.08	0.12	0.09	0.07	0.13
7	0.07	0.14	0.07	0.10	0.10	0.10	0.14
8	0.08	0.09	0.09	OFF	0.12	0.07	0.12
9	0.09	OFF	0.11	0.06	0.12	0.07	0.12
10	0.10	0.12	OFF	0.07	0.09	0.06	0.12
11	0.09	0.07	OFF	0.07	OFF	OFF	0.09
12	0.10	0.09	0.06	OFF	0.11	OFF	0.11
13	0.07	0.09	0.09	0.13	0.08	0.13	0.13
14	0.07	0.09	0.07	0.09	0.15	0.07	0.15
15	0.08	0.10	0.07	0.08	0.09	0.07	0.10
16	0.15	0.07	0.10	0.07	OFF	0.06	0.15
17	0.08	0.08	0.12	0.07	0.08	OFF	0.12
18	0.07	OFF	0.08	0.07	0.06	OFF	0.08
19	0.06	0.06	0.07	0.10	0.08	OFF	0.10
20	0.08	OFF	0.06	OFF	0.06	0.07	0.08
21	0.06	0.14	0.07	0.07	0.10	0.08	0.14
22	0.08	0.07	0.12	0.07	0.11	0.07	0.12
23	0.07	0.09	0.08	0.07	OFF	0.08	0.09
24	0.08	0.07	0.10	0.06	0.08	0.07	0.10
25	0.08	0.08	0.10	0.06	OFF	0.07	0.10
26	OFF	0.10	0.10	0.06	0.10	0.08	0.10
27	0.10	0.13	0.07	0.07	0.10	OFF	0.13
28	0.08	0.08	0.12	0.07	0.09	0.07	0.12
29	0.09	0.09	OFF	0.08	0.09	0.07	0.09
30	0.09	0.07	0.08	0.09	0.07	OFF	0.09

Conventional or Direct Filtration			Monthly Summary (Answer Yes or No)			
95% of 4-hour turbidity readings ≤ 0.3 NTU?	YES	CT's met everyday?	All Cl <sub>2</sub> residual at entry point			
All 4-hour turbidity readings ≤ 1 NTU?	YES	See page 2	YES	≥ 0.2 mg/l?	YES	
All turbidity readings < IFE <sup>2</sup> triggers	YES					

Notes:

PRINTED NAME: Elizabeth Lawrence	
SIGNATURE: 	DATE: 7/10/23
CERT #: T004530	
PHONE #: (360) 281-5613	

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	
System Name: CITY OF RAINIER				ID#: 4100689		Jun-2023	Disinfection Giardia Log Inactive:	0.5
Day	Residual at [ppm or mg/L]	Contact Time [T] [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? <sup>3</sup> Yes / No	Peak Hourly Demand Flow [GPM]
1	0.7	160.0	113.8	20.6	7.5	10.8	YES	1000
2	0.7	160.0	111.8	20.9	7.5	10.6	YES	1000
3	0.6	160.0	99.7	21.3	7.5	10.3	YES	1000
4	0.6	160.0	91.4	21.5	7.5	10.1	YES	1000
5	0.6	160.0	93.8	23.1	7.5	9.0	YES	1000
6	0.6	160.0	91.0	21.9	7.5	9.7	YES	1000
7	0.7	160.0	107.5	24.7	7.5	8.3	YES	1000
8	0.7	160.0	105.6	24.3	7.5	8.6	YES	1000
9	0.7	160.0	108.3	23.8	7.5	8.8	YES	1000
10	0.6	160.0	96.2	23.4	7.5	8.9	YES	1000
11	0.6	160.0	90.1	23.6	7.5	8.7	YES	1000
12	0.6	160.0	90.7	22.7	7.4	9.1	YES	1000
13	0.6	160.0	93.3	23.3	7.5	8.8	YES	1000
14	0.6	160.0	92.8	22.3	7.5	9.5	YES	1000
15	0.7	160.0	107.2	21.8	7.5	10.0	YES	1000
16	0.7	160.0	106.6	22.4	7.5	9.6	YES	1000
17	0.6	160.0	95.0	22.9	7.5	9.2	YES	1000
18	0.6	160.0	95.2	21.8	7.5	9.9	YES	1000
19	0.6	160.0	95.0	21.1	7.5	10.4	YES	1000
20	0.6	160.0	91.2	22.5	7.5	9.4	YES	1000
21	0.6	160.0	101.0	23.0	7.5	9.2	YES	1000
22	0.7	160.0	108.0	23.8	7.5	8.7	YES	1000
23	0.7	160.0	110.4	23.4	7.5	9.1	YES	1000
24	0.7	160.0	115.2	22.8	7.5	9.4	YES	1000
25	0.7	160.0	104.0	23.3	7.5	9.0	YES	1000
26	0.7	160.0	105.0	23.4	7.5	9.0	YES	1000
27	0.7	160.0	109.1	23.3	7.5	9.1	YES	1000
28	0.8	160.0	120.3	23.4	7.5	9.2	YES	1000
29	0.8	160.0	120.0	25.7	7.5	7.7	YES	1000
30	0.7	160.0	118.1	24.6	7.5	8.4	YES	1000