

**OHA - Drinking Water Services - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Douglas**  
 Month/Year: **Feb, 2025**

System Name:		Reedsport			4100699		WTP : TP -		Clear lake
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]		
1	0.27	0.26	0.26	0.27	0.26	0.26	0.48		
2	0.26	0.28	0.26	0.26	0.25	0.26	0.52		
3	0.27	0.25	0.25	0.27	0.36	0.24	0.45		
4	0.24	0.30	0.64	0.25	0.24	0.25	0.51		
5	0.25	0.24	0.24	0.40	0.26	0.24	0.40		
6	0.24	0.24	0.25	0.26	0.23	0.23	0.61		
7	0.24	0.23	0.24	0.23	0.29	0.29	0.40		
8	0.24	0.22	0.23	0.25	0.28	0.23	0.49		
9	0.24	0.23	0.60	0.26	0.23	0.24	0.48		
10	0.24	0.23	0.23	0.23	0.29	0.25	0.77		
11	0.24	0.29	0.23	0.23	0.22	0.25	0.48		
12	0.24	0.22	0.22	0.22	0.23	0.23	0.45		
13	0.50	0.23	0.25	0.22	0.23	0.23	0.42		
14	0.23	0.23	0.22	0.23	0.24	0.22	0.57		
15	0.70	0.24	0.39	0.23	0.35	0.21	0.54		
16	0.21	0.20	0.20	0.22	0.23	0.22	0.43		
17	0.21	0.22	0.21	0.21	0.21	0.24	0.39		
18	0.21	0.21	0.48	0.59	0.22	0.21	0.48		
19	0.22	0.23	0.21	0.21	0.23	0.22	0.51		
20	0.22	0.25	0.21	0.32	0.23	0.23	0.56		
21	0.21	0.26	0.23	0.21	0.41	0.22	0.59		
22	0.20	0.20	0.20	0.21	0.20	0.21	0.38		
23	0.53	0.25	0.25	0.24	0.24	0.29	0.44		
24	0.27	0.23	0.23	0.31	0.40	0.38	0.65		
25	0.35	0.32	0.34	0.32	0.30	0.30	0.61		
26	0.32	0.32	0.30	0.30	0.31	0.29	0.55		
27	0.29	0.29	0.40	0.32	0.30	0.29	0.54		
28	0.31	0.30	0.28	0.31	0.41	31.00	0.59		
29									
30									
31									

<b>Slow Sand/Membrane/DE Filtration/Unfiltered</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup>	<b>yes</b>	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	<b>yes</b>	<b>Yes</b>	<b>Yes</b>
<b>Notes:</b>			
		<b>SIGNATURE:</b> <i>Mike Woolley</i>	<b>3/7/2025</b>
		<b>541-707-0283</b>	<b>681921</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :  
 Disinfection *Giardia* Log  
 Inactiv: 1.0

System Name: Reedsport 4100699 Month/Year: Feb, 2025

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.78	74	57.7	9.4	7.61	48.5	y	832
2	0.78	74	57.7	9.4	7.61	48.5	y	838.4
3	0.78	74	57.7	9.1	7.64	50.0	Y	1061.4
4	0.8	74	59.2	9.2	7.63	49.6	y	837.2
5	0.8	74	59.2	9.2	7.59	48.9	y	845
6	0.78	74	57.7	9.2	7.59	48.8	y	846.2
7	0.8	74	59.2	9.1	7.62	49.8	y	999.6
8	0.81	74	59.9	8.8	7.60	50.5	y	846.3
9	0.81	74	59.9	8.8	7.60	50.5	y	842.2
10	0.81	74	59.9	8.5	7.50	49.7	y	1727.9
11	0.86	74	63.6	9.0	7.55	49.2	y	841.1
12	0.83	74	61.4	8.3	7.61	52.5	y	1212.9
13	0.78	74	57.7	8.5	7.59	51.1	y	844.8
14	0.77	74	57.0	9.0	7.56	48.9	y	847.2
15	0.72	74	53.3	9.1	7.53	47.8	y	839.8
16	0.72	74	53.3	9.1	7.53	47.8	y	1019.2
17	0.66	74	48.8	9.2	7.50	46.6	y	841.1
18	0.81	74	59.9	9.4	7.36	44.6	y	884
19	0.76	74	56.2	9.0	7.35	45.3	y	842.4
20	0.71	74	52.5	9.5	7.38	44.1	y	842.5
21	0.7	74	51.8	8.9	7.51	48.0	y	1045.2
22	0.72	74	53.3	9.5	7.52	46.4	y	843.8
23	0.72	74	53.3	9.5	7.52	46.4	y	845
24	0.74	74	54.8	10.0	7.53	45.1	y	971
25	0.73	74	54.0	9.9	7.48	44.6	y	847.5
26	0.75	74	55.5	9.9	7.52	45.3	y	869.6
27	0.81	74	59.9	9.8	7.58	46.9	y	838.3
28	0.76	74	56.2	9.5	7.53	46.7	y	957.8
29								
30								
31								

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013

## Oregon DHS - Drinking Water Services – Surface Water Quality Data


System Name: Reedsport ID# 41 00699 Month/Year: Feb. 2025  
 Minimum UVT [%] during month: 4.95 ity sensor variation from reference sensor %: 2.29

Minimum Validated UVT : {Insert Req'd Value}

Date	Peak Hourly [gpm/unit]	Minimum Intensity [ <sup>mW</sup> /cm <sup>2</sup> ]	All Lamps On? [Y or N]	Daily Water [gal]	Water outside [gal]	Cumulative % Off-Spec Water Produced (Mo. Sum {B}) + (Mo. Sum {A}) * 100 [%]
1	832	4.95	y	600,000	0	
2	838.4	4.95	y	600,000	0	
3	1061.4	4.95	y	600,000	0	
4	837.2	4.95	y	500,000	0	
5	845	4.95	y	600,000	0	
6	846.2	4.95	y	600,000	0	
7	999.6	4.95	y	500,000	0	
8	846.3	4.95	y	500,000	0	
9	842.2	4.95	y	600,000	0	
10	1727.9	4.95	y	600,000	0	
11	841.1	4.95	y	600,000	0	
12	1212.9	4.95	y	600,000	0	
13	844.8	4.95	y	600,000	0	
14	847.2	4.95	y	600,000	0	
15	839.8	4.95	y	500,000	0	
16	1019.2	4.95	y	600,000	0	
17	841.1	4.95	y	600,000	0	
18	884	4.95	y	600,000	0	
19	842.4	4.95	y	600,000	0	
20	842.5	4.95	y	600,000	0	
21	1045.2	4.95	y	500,000	0	
22	843.8	4.95	y	600,000	0	
23	845	4.95	y	600,000	0	
24	971	4.95	y	600,000	0	
25	847.5	4.95	y	600,000	0	
26	869.6	4.95	y	600,000	0	
27	838.3	4.95	y	600,000	0	
28	857.8	4.95	y	500,000	0	
29						
30						
31						
Monthly Cumulative % Off-Spec Water Produced						

rev 1/11 I:\MC\forms\Turbidity Report Form – UV and opt mod.doc

Signature:



Op Cert #: 681921


Date: 3/7/2025

## Raw Water Fecal Coliform 6 Month Running Average Report

**CITY OF REEDSPORT**  
**Monthly Report**

**PWS ID:4100699**

**Raw Water Fecal Coliform Per 100ml**

Date	Sep-24	Oct-24	Nov-24	Dec-24	Jan-25	Feb-25
1		0				
2				2	0	
3	17	0		0	0	0
4	2		0			4.5
5	0		0	0		
6					0	0
7		0	0		2	
8		0				
9	4.5			2	0	
10	7.8	0		0		0
11						0
12	0		0	4.5		
13			0		2	13
14			0		0	
15		0				
16	0	0		0	0	
17	2	0		0		0
18			7.8			0
19	0			0		
20					0	0
21		0	0		0	
22		0		0		
23	0				0	
24	0	0	2			0
25			0			0
26	0			0		
27				0	2	0
28		4.5			0	
29		4.5	0			
30	0			0	0	
31		0				
AVERAGE	2.561538462	0.642857143	0.890909091	0.653846154	0.428571429	1.458333333
6 MONTH	AVERAGE ENDING					1.106009269
SIGNED:					3/7/2025	