

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Douglas**
 Month/Year: **June, 2025**

System Name: **Reedsport** **4100699** WTP : TP - **Clear lake**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.85	0.73	0.55	0.61	0.63	0.74	0.89
2	0.67	0.72	0.58	0.56	0.67	0.83	0.87
3	0.66	0.63	0.60	0.51	0.60	0.68	0.74
4	0.61	0.56	0.54	0.51	0.51	0.56	0.64
5	0.55	0.51	0.50	0.45	0.48	0.51	0.62
6	0.58	0.51	0.49	0.45	0.57	0.70	0.58
7	0.56	0.52	0.45	0.43	0.47	0.49	0.58
8	0.45	0.43	0.42	0.38	0.40	0.40	0.47
9	0.42	0.41	0.35	0.38	0.41	0.44	0.44
10	0.43	0.39	0.37	0.36	0.36	0.39	0.44
11	0.42	0.37	0.36	0.33	0.36	0.37	0.42
12	0.37	0.38	0.36	0.35	0.40	0.51	0.45
13	0.40	0.39	0.74	0.35	0.36	0.40	0.43
14	0.38	0.38	0.37	0.33	0.39	0.39	0.42
15	0.39	0.96	0.37	0.36	0.38	0.41	0.42
16	0.39	0.35	0.34	0.33	0.34	0.36	0.38
17	0.98	0.35	0.33	0.33	0.34	0.34	0.39
18	0.35	0.33	0.29	0.33	0.37	0.36	0.40
19	0.35	0.65	0.28	0.34	0.40	0.42	0.39
20	0.36	0.31	0.33	0.29	0.28	0.28	0.37
21	0.29	0.28	0.28	0.28	0.29	0.30	0.33
22	0.29	0.29	0.29	0.29	0.32	0.32	0.36
23	0.33	0.36	0.31	0.30	0.34	0.34	0.43
24	0.34	0.32	0.30	0.29	0.30	0.31	0.40
25	0.31	0.30	0.30	0.30	0.30	0.32	0.38
26	0.31	0.31	0.58	0.28	0.30	0.31	0.41
27	0.38	0.33	0.30	0.29	0.33	0.31	0.37
28	0.34	0.33	0.31	0.32	0.38	0.40	0.46
29	0.38	0.31	0.30	0.31	0.72	0.38	0.47
30	0.53	0.34	0.34	0.33	0.35	0.39	0.45
31							

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 1 NTU? ²	yes	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All daily turbidity readings $\leq$ 5 NTU?	yes	Yes	Yes
Notes:			
		SIGNATURE: <i>Michael W. Woleg</i>	
		7/8/2025	
		541-707-0283	681921

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

Oregon DHS - Drinking Water Services – Surface Water Quality Data

System Name: Reedsport ID# 41 00699 Month/Year: Jun / 2025
 Minimum UVT [%] during month: 4.95 ity sensor variation from reference sensor %: 2.6

Minimum Validated UVT : {Insert Req'd Value}

Date	Peak Hourly [gpm/unit]	Minimum Intensity [^{mW} /cm ²]	All Lamps On? [Y or N]	Daily Water [gal]	Water outside [gal]	Cumulative % Off-Spec Water Produced (Mo. Sum {B}) ÷ (Mo. Sum {A}) * 100 [%]
1	1150.5	4.95	y	800,000	0	
2	1192.3	4.95	y	900,000	0	
3	1652.3	4.95	y	700,000	0	
4	1261.1	4.95	y	800,000	0	
5	1588.9	4.95	y	900,000	0	
6	1133.7	4.95	y	1,000,000	0	
7	1259.6	4.95	y	800,000	0	
8	1393.8	4.95	y	800,000	0	
9	1504.2	4.95	y	1,100,000	0	
10	1210.4	4.95	y	800,000	0	
11	1366.3	4.95	y	900,000	0	
12	1411.9	4.95	y	800,000	0	
13	1545.8	4.95	y	900,000	0	
14	1430.2	4.95	y	900,000	0	
15	1181.4	4.95	y	900,000	0	
16	1550.8	4.95	y	800,000	0	
17	1414.6	4.95	y	900,000	0	
18	1620.1	4.95	y	800,000	0	
19	1212.9	4.95	y	900,000	0	
20	1258.3	4.95	y	800,000	0	
21	998.5	4.95	y	700,000	0	
22	1222.1	4.95	y	700,000	0	
23	2678.1	4.95	y	700,000	0	
24	1164.9	4.95	y	900,000	0	
25	1328.8	4.95	y	800,000	0	
26	1162.3	4.95	y	700,000	0	
27	1417.3	4.95	y	1,000,000	0	
28	1578.6	4.95	y	1,000,000	0	
29	1296.5	4.95	y	900,000	0	
30	1261.2	4.95	y	900,000	0	
31						
Monthly Cumulative % Off-Spec Water Produced						

rev 1/11 I:\MC\forms\Turbidity Report Form – UV and opt mod.doc

Signature: Michael Woley Op Cert #: 681921 Date: 7/8/2025

Raw Water Fecal Coliform 6 Month Running Average Report

CITY OF REEDSPORT

PWS ID:4100699

Monthly Report

Raw Water Fecal Coliform Per 100ml

Date	Jan-25	Feb-25	Mar-25	Apr-25	May-25	Jun-25	
1				0	0		
2	0					0	
3	0	0	0	0		4.5	
4		4.5	0				
5					0	0	
6	0	0	0		0		
7	2			0			
8				0	0		
9	0					0	
10		0	0	0		0	
11		0	0				
12					0	2	
13	2	13	0		0		
14	0			0			
15				0	0		
16	0					2	
17		0	0	0		0	
18		0	0				
19					0	0	
20	0	0	0		0		
21	0			0			
22				0	0		
23	0					0	
24		0	0	0		0	
25		0	0				
26						0	
27	2	0	0		0		
28	0			0	0		
29				0	0		
30	0					0	
31				0			
AVERAGE	0.428571429	1.458333333	0	0	0		
6 MONTH					AVERAGE ENDING		0.314484127
SIGNED: 				7/8/2025			