

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Douglas**
 Month/Year: **July, 2025**

System Name:		Reedsport 4100699					WTP : TP - Clear lake
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.36	0.36	0.36	0.35	0.39	0.38	0.46
2	0.40	0.38	0.38	0.37	0.38	0.40	0.47
3	0.40	0.49	0.36	0.36	0.39	0.41	0.49
4	0.43	0.41	0.40	0.39	0.40	0.58	0.53
5	0.41	0.42	0.40	0.39	0.41	0.46	0.51
6	0.45	0.43	0.42	0.41	0.45	0.47	0.58
7	0.45	0.46	0.45	0.44	0.33	0.36	0.60
8	0.47	0.38	0.31	0.31	0.39	0.38	0.46
9	0.30	0.31	0.30	0.31	0.33	0.34	0.36
10	0.32	0.34	0.31	0.33	0.35	0.38	0.41
11	0.36	0.33	0.32	0.39	0.40	0.58	0.38
12	0.36	0.33	0.32	0.33	0.35	0.36	0.40
13	0.36	0.36	0.32	0.32	0.33	0.43	0.42
14	0.34	0.34	0.33	0.33	0.37	0.38	0.46
15	0.35	0.36	0.34	0.32	0.36	0.35	0.43
16	0.36	0.33	0.33	0.33	0.35	0.34	0.40
17	0.36	0.34	0.32	0.32	0.35	0.35	0.43
18	0.41	0.36	0.33	0.32	0.34	0.35	0.45
19	0.36	0.37	0.32	0.33	0.35	0.35	0.45
20	0.35	0.34	0.34	0.32	0.33	0.35	0.45
21	0.34	0.33	0.31	0.45	0.37	0.38	0.48
22	0.37	0.36	0.33	0.33	0.34	0.37	0.44
23	0.39	0.34	0.33	0.32	0.36	0.34	0.43
24	0.35	0.34	0.33	0.33	0.33	0.35	0.41
25	0.35	0.36	0.35	0.33	0.35	0.35	0.43
26	0.36	0.36	0.36	0.33	0.35	0.34	0.43
27	0.36	0.33	0.32	0.33	0.36	0.34	0.44
28	0.35	0.34	0.42	0.34	0.34	0.35	0.42
29	0.35	0.34	0.33	0.34	0.36	0.39	0.49
30	0.42	0.36	0.35	0.36	0.37	0.39	0.47
31	0.38	0.38	0.37	0.37	0.39	0.39	0.61

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 1 NTU? ²	yes	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All daily turbidity readings $\leq$ 5 NTU?	yes	Yes	Yes
Notes:			
		SIGNATURE: <i>Mike Woolley</i>	8/7/2025
		541-707-0283	681921

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

System Name: Reedsport

4100699

Month/Year: July,2025

Disinfection *Giardia* Log

Inactiv:

1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.7	74	51.8	18.4	7.47	25.0	y	1439.3
2	0.74	74	54.8	18.3	7.41	24.7	y	1464
3	0.68	74	50.3	18.5	7.41	24.2	Y	1245.6
4	0.71	74	52.5	18.4	7.39	24.3	y	1510.8
5	0.74	74	54.8	18.6	7.41	24.2	y	1419
6	0.74	74	54.8	18.6	7.41	24.2	y	1428.8
7	0.75	74	55.5	18.7	7.42	24.1	y	1474.3
8	0.65	74	48.1	18.3	7.43	24.6	y	1353.7
9	0.64	74	47.4	18.9	7.41	23.4	y	1207.8
10	0.65	74	48.1	19.2	7.36	22.6	y	1348.3
11	0.68	74	50.3	19.1	7.46	23.7	y	1328.6
12	0.68	74	50.3	19.1	7.43	23.4	y	1413.4
13	0.68	74	50.3	19.1	7.43	23.4	y	1417.1
14	0.68	74	50.3	19.1	7.40	23.1	y	1645.1
15	0.67	74	49.6	18.9	7.47	24.1	y	1361.3
16	0.63	74	46.6	19.0	7.43	23.4	y	1639.6
17	0.68	74	50.3	19.3	7.47	23.4	y	1430.2
18	0.69	74	51.1	19.3	7.43	23.1	y	1429.6
19	0.68	74	50.3	19.4	7.42	22.9	y	1339.1
20	0.68	74	50.3	19.4	7.42	22.9	y	1300.2
21	0.67	74	49.6	19.5	7.41	22.6	y	1337.8
22	0.59	74	43.7	19.5	7.44	22.6	y	1668.2
23	0.64	74	47.4	19.8	7.46	22.5	y	1427.6
24	0.66	74	48.8	19.5	7.44	22.8	y	1468.9
25	0.68	74	50.3	19.6	7.43	22.6	y	1211.8
26	0.73	74	54.0	19.6	7.43	22.8	y	1305.3
27	0.73	74	54.0	19.6	7.43	22.8	y	1597.9
28	0.78	74	57.7	19.5	7.42	23.0	y	1326.2
29	0.71	74	52.5	19.9	7.38	21.8	y	1363.8
30	0.69	74	51.1	19.9	7.39	21.9	y	1226.2
31	0.74	74	54.8	20.0	7.41	22.0	y	1305.3

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.


Revised October 2013

Oregon DHS - Drinking Water Services – Surface Water Quality Data

System Name: Reedsport **ID#** 41 00699 **Month/Year:** Jul / 2025
Minimum UVT [%] during month: 4.95 **ity sensor variation from reference sensor %:** 2.52
Minimum Validated UVT : {Insert Req'd Value}

Date	Peak Hourly	Minimum Intensity	All Lamps On?	Daily Water	Water outside	Cumulative % Off-Spec Water Produced
	[gpm/unit]	[^{mW} / _{cm²}]	[Y or N]	[gal]	[gal]	(Mo. Sum {B}) ÷ (Mo. Sum {A}) * 100 [%]
1	1439.3	4.95	y	900,000	0	
2	1464	4.95	y	900,000	0	
3	1245.6	4.95	y	900,000	0	
4	1510.8	4.95	y	1,000,000	0	
5	1419	4.95	y	1,000,000	0	
6	1428.8	4.95	y	900,000	0	
7	1474.3	4.95	y	900,000	0	
8	1353.7	4.95	y	1,000,000	0	
9	1207.8	4.95	y	900,000	0	
10	1348.3	4.95	y	900,000	0	
11	1328.6	4.95	y	1,000,000	0	
12	1413.4	4.95	y	1,000,000	0	
13	1417.1	4.95	y	1,000,000	0	
14	1645.1	4.95	y	1,000,000	0	
15	1361.3	4.95	y	1,000,000	0	
16	1639.6	4.95	y	900,000	0	
17	1430.2	4.95	y	900,000	0	
18	1429.6	4.95	y	1,000,000	0	
19	1339.1	4.95	y	900,000	0	
20	1300.2	4.95	y	900,000	0	
21	1337.8	4.95	y	900,000	0	
22	1668.2	4.95	y	900,000	0	
23	1427.6	4.95	y	1,000,000	0	
24	1468.9	4.95	y	900,000	0	
25	1211.8	4.95	y	900,000	0	
26	1305.3	4.95	y	1,000,000	0	
27	1597.9	4.95	y	1,000,000	0	
28	1326.2	4.95	y	900,000	0	
29	1363.8	4.95	y	1,000,000	0	
30	1226.2	4.95	y	1,000,000	0	
31	1305.3	4.95	y	800,000	0	
Monthly Cumulative % Off-Spec Water Produced						

rev 1/11 I:\MC\forms\Turbidity Report Form - UV and opt mod.doc

Signature:  **Op Cert #:** 681921 **Date:** 8/7/2025


Raw Water Fecal Coliform 6 Month Running Average Report

CITY OF REEDSPORT

PWS ID:4100699

Monthly Report

Raw Water Fecal Coliform Per 100ml

Date	Feb-25	Mar-25	Apr-25	May-25	Jun-25	Jul-25
1			0	0		0
2					0	2
3	0	0	0		4.5	
4	4.5	0				
5				0	0	
6	0	0		0		
7			0			0
8			0	0		2
9					0	
10	0	0	0		0	2
11	0	0				
12				0	2	
13	13	0		0		
14			0			0
15			0	0		3.6
16					2	
17	0	0	0		0	0
18	0	0				
19				0	0	
20	0	0		0		
21			0			0
22			0	0		0
23					0	
24	0	0	0		0	4.5
25	0	0				
26					0	
27	0	0		0		
28			0	0		4.5
29			0	0		
30					0	2
31			0			0
AVERAGE	1.458333333	0	0	0	0	
6 MONTH AVERAGE ENDING					0.243055556	
SIGNED: 				8/7/2025		