


OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Douglas**
 Month/Year: **August, 2025**

System Name:		Reedsport		4100699			WTP : TP -		Clear lake
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]		
1	0.35	0.39	0.41	0.37	0.39	0.43	0.41		
2	0.40	0.42	0.42	0.39	0.44	0.42	0.47		
3	0.44	0.44	0.41	0.40	0.41	0.42	0.45		
4	0.44	0.41	0.44	0.42	0.44	0.45	0.51		
5	0.45	0.45	0.42	0.42	0.34	0.35	0.50		
6	0.36	0.37	0.33	0.33	0.35	0.39	0.42		
7	0.38	0.37	0.36	0.37	0.36	0.43	0.44		
8	0.34	0.35	0.37	0.39	0.43	0.43	0.45		
9	0.35	0.37	0.53	0.37	0.39	0.36	0.47		
10	0.37	0.41	0.37	0.40	0.43	0.39	0.51		
11	0.34	0.39	0.36	0.31	0.35	0.41	0.00		
12	0.39	0.36	0.36	0.35	0.38	0.39	0.45		
13	0.38	0.38	0.38	0.39	0.40	0.41	0.47		
14	0.40	0.40	0.41	0.37	0.41	0.40	0.51		
15	0.39	0.36	0.36	0.37	0.37	0.39	0.42		
16	0.38	0.38	0.81	0.37	0.39	0.40	0.43		
17	0.40	0.82	0.38	0.37	0.38	0.40	0.45		
18	0.43	0.38	0.38	0.35	0.37	0.38	0.47		
19	0.39	0.38	0.36	0.40	0.40	0.40	0.46		
20	0.41	0.38	0.37	0.37	0.40	0.48	0.53		
21	0.41	0.37	0.38	0.36	0.43	0.41	0.51		
22	0.40	0.39	0.39	0.37	0.37	0.39	0.46		
23	0.41	0.46	0.37	0.37	0.38	0.39	0.46		
24	0.39	0.39	0.39	0.38	0.40	0.40	0.48		
25	0.39	0.40	0.40	0.39	0.41	0.42	0.48		
26	0.42	0.41	0.42	0.41	0.36	0.36	0.66		
27	0.35	0.39	0.36	0.34	0.36	0.35	0.41		
28	0.37	0.37	0.35	0.34	0.33	0.35	0.42		
29	0.33	0.33	0.34	0.33	0.38	0.40	0.35		
30	0.34	0.40	0.35	0.33	0.35	0.35	0.42		
31	0.36	0.34	0.34	0.34	0.38	0.39	0.40		

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 1 NTU? ²	yes	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All daily turbidity readings $\leq$ 5 NTU?	yes	Yes	Yes
Notes:			
		SIGNATURE: 	9/8/2025
		541-707-0283	681921

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form
WTP- :
System Name: Reedsport
4100699
Month/Year: August,25
Disinfection *Giardia* Log
Inactiv:
1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.63	74	46.6	20.2	7.40	21.4	y	1251.1
2	0.66	74	48.8	20.3	7.39	21.2	y	1353.1
3	0.66	74	48.8	20.3	7.39	21.2	y	1292.3
4	0.69	74	51.1	20.4	7.37	21.0	y	1269.8
5	0.66	74	48.8	20.1	7.42	21.8	y	1644.7
6	0.67	74	49.6	20.7	7.38	20.6	y	1150.5
7	0.81	74	59.9	20.5	7.39	21.3	y	1474.5
8	0.78	74	57.7	20.4	7.33	20.9	y	1129.8
9	0.71	74	52.5	20.5	7.36	20.8	y	1275.5
10	0.71	74	52.5	20.5	7.36	20.8	y	1331.3
11	0.64	74	47.4	20.6	7.39	20.7	y	1443.8
12	0.65	74	48.1	20.8	7.42	20.7	y	1383.2
13	0.62	74	45.9	20.8	7.41	20.6	y	2176.2
14	0.68	74	50.3	20.9	7.39	20.4	y	1384.7
15	0.63	74	46.6	21.0	7.36	19.9	y	1321.2
16	0.64	74	47.4	21.1	7.38	20.0	y	1555.1
17	0.64	74	47.4	21.1	7.38	20.0	y	1250.9
18	0.64	74	47.4	21.1	7.39	20.1	y	1224.7
19	0.59	74	43.7	21.5	7.37	19.3	y	1190.7
20	0.64	74	47.4	21.3	7.43	20.1	y	1281.8
21	0.64	74	47.4	21.1	7.42	20.3	y	1473
22	0.71	74	52.5	21.2	7.42	20.3	y	1336.4
23	0.69	74	51.1	21.2	7.49	20.8	y	1175.4
24	0.69	74	51.1	21.2	7.49	20.8	y	1252.1
25	0.67	74	49.6	21.2	7.55	21.2	y	1336.2
26	0.66	74	48.8	21.1	7.51	21.0	y	1322.2
27	0.64	74	47.4	20.9	7.49	21.1	y	1404.2
28	0.69	74	51.1	20.7	7.51	21.7	y	1235.1
29	0.68	74	50.3	20.6	7.54	22.0	y	1306.6
30	0.7	74	51.8	20.6	7.52	21.9	y	1224.7
31	0.7	74	51.8	20.6	7.52	21.9	y	1282

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013

Oregon DHS - Drinking Water Services – Surface Water Quality Data


System Name: Reedsport **ID# 41 00699** **Month/Year:** August,25
Minimum UVT [%] during month: 4.95 ity sensor variation from reference sensor %: 3.67

Minimum Validated UVT : {Insert Req'd Value}

Date	Peak Hourly [gpm/unit]	Minimum Intensity [^{mW} /cm ²]	All Lamps On? [Y or N]	Daily Water [gal]	Water outside [gal]	Cumulative % Off-Spec Water Produced (Mo. Sum {B}) ÷ (Mo. Sum {A}) * 100 [%]
1	1251.1	4.95	y	1,000,000	0	
2	1353.6	4.95	y	900,000	0	
3	1292.3	4.95	y	900,000	0	
4	1269.8	4.95	y	900,000	0	
5	1644.7	4.95	y	1,000,000	0	
6	1150.5	4.95	y	900,000	0	
7	1474.5	4.95	y	1,000,000	0	
8	1129.8	4.95	y	900,000	0	
9	1275.5	4.95	y	1,000,000	0	
10	1331.3	4.95	y	1,000,000	0	
11	1443.8	4.95	y	1,100,000	0	
12	1383.2	4.95	y	1,100,000	0	
13	2176.2	4.95	y	900,000	0	
14	1384.7	4.95	y	1,100,000	0	
15	1321.2	4.95	y	800,000	0	
16	1555.1	4.95	y	800,000	0	
17	1250.9	4.95	y	900,000	0	
18	1224.7	4.95	y	900,000	0	
19	1190.7	4.95	y	700,000	0	
20	1281.8	4.95	y	900,000	0	
21	1473	4.95	y	1,000,000	0	
22	1336.4	4.95	y	1,100,000	0	
23	1175.4	4.95	y	900,000	0	
24	1252.1	4.95	y	900,000	0	
25	1336.2	4.95	y	800,000	0	
26	1322.2	4.95	y	800,000	0	
27	1404.2	4.95	y	900,000	0	
28	1235.1	4.95	y	800,000	0	
29	1306.6	4.95	y	700,000	0	
30	1224.7	4.95	y	900,000	0	
31	1282	4.95	y	900,000	0	
Monthly Cumulative % Off-Spec Water Produced						

rev 1/11 I:\MC\forms\Turbidity Report Form – UV and opt mod.doc

Signature:



Op Cert #: 681921

Date: 9/8/2025


Raw Water Fecal Coliform 6 Month Running Average Report

CITY OF REEDSPORT

PWS ID:4100699

Monthly Report

Raw Water Fecal Coliform Per 100ml

Date	Mar-25	Apr-25	May-25	Jun-25	Jul-25	Aug-25
1		0	0		0	
2				0	2	
3	0	0		4.5		
4	0					0
5			0	0		0
6	0		0			
7		0			0	0
8		0	0		2	
9				0		
10	0	0		0	2	
11	0					0
12			0	2		0
13	0		0			
14		0			0	0
15		0	0		3.6	
16				2		
17	0	0		0	0	
18	0					0
19			0	0		0
20	0		0			
21		0			0	0
22		0	0		0	
23				0		
24	0	0		0	4.5	
25	0					0
26				0		2
27	0		0			
28		0	0		4.5	0
29		0	0			
30				0	2	
31		0			0	
AVERAGE	0	0	0	0.653846154	0	
6 MONTH					AVERAGE ENDING	
					0.108974359	
SIGNED: 				9/8/2025		