


OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Douglas
Month/Year: September, 2025

System Name:		Reedsport		4100699		WTP : TP -		Clear lake
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]	
1	0.34	0.35	0.34	0.34	0.33	0.37	0.41	
2	0.35	0.34	0.34	0.33	0.36	0.38	0.42	
3	0.34	0.72	0.34	0.35	0.36	0.35	0.44	
4	0.39	0.35	0.35	0.34	0.36	0.40	0.43	
5	0.37	0.36	0.35	0.35	0.34	0.33	0.38	
6	0.34	0.33	0.34	0.34	0.36	0.34	0.37	
7	0.34	0.33	0.34	0.34	0.37	0.36	0.43	
8	0.36	0.35	0.35	0.34	0.33	0.34	0.45	
9	0.86	0.36	0.34	0.36	0.35	0.36	0.42	
10	0.34	0.34	0.36	0.35	0.35	0.38	0.43	
11	0.37	0.36	0.37	0.37	0.35	0.36	0.54	
12	0.39	0.35	0.36	0.35	0.34	0.33	0.44	
13	0.37	0.36	0.37	0.38	0.36	0.36	0.44	
14	0.35	0.33	0.36	0.34	0.36	0.36	0.42	
15	0.37	0.36	0.36	0.36	0.36	0.38	0.45	
16	0.37	0.37	0.35	0.35	0.34	0.34	0.45	
17	0.43	0.38	0.38	0.35	0.36	0.39	0.45	
18	0.41	0.42	0.41	0.37	0.39	0.44	0.60	
19	0.40	0.39	0.40	0.38	0.36	0.36	0.44	
20	0.41	0.39	0.40	0.42	0.38	0.39	0.48	
21	0.38	0.37	0.37	0.38	0.39	0.39	0.47	
22	0.39	0.40	0.39	0.39	0.39	0.41	0.54	
23	0.43	0.40	0.40	0.39	0.41	0.39	0.60	
24	0.43	0.40	0.41	0.40	0.48	0.60	0.51	
25	0.43	0.43	0.43	0.41	0.70	0.47	0.57	
26	0.45	0.44	0.46	0.46	0.39	0.42	0.66	
27	0.34	0.31	0.31	0.32	0.32	0.38	0.45	
28	0.31	0.30	0.30	0.30	0.40	0.30	0.37	
29	0.32	0.30	0.30	0.32	0.30	0.32	0.36	
30	0.31	0.30	0.31	0.31	0.58	0.36	0.75	
31								

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	yes	Yes	Yes

Notes:

SIGNATURE: 	10/7/2025
541-707-0283	681921

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form
WTP- :
Disinfection *Giardia* Log
System Name: Reedsport
4100699
Month/Year: September,25
Inactiv:
1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.63	74	46.6	20.5	7.50	21.7	y	1020.1
2	0.65	74	48.1	20.6	7.51	21.7	y	1203.9
3	0.69	74	51.1	20.4	7.48	21.9	y	1032.4
4	0.6	74	44.4	20.4	7.35	20.6	y	1100
5	0.61	74	45.1	20.6	7.36	20.4	y	1088.2
6	0.61	74	45.1	20.4	7.37	20.8	y	992.1
7	0.61	74	45.1	20.4	7.37	20.8	y	1233.9
8	0.61	74	45.1	20.3	7.37	20.9	y	1331.4
9	0.67	74	49.6	20.2	7.39	21.4	y	924.5
10	0.61	74	45.1	20.3	7.34	20.7	y	993.3
11	0.59	74	43.7	20.2	7.37	21.0	y	1158.3
12	0.45	74	33.3	20.1	7.35	20.7	y	959.5
13	0.5	74	37.0	20.2	7.34	20.6	y	851.5
14	0.5	74	37.0	20.2	7.34	20.6	y	1176.6
15	0.55	74	40.7	20.2	7.32	20.5	y	1194.6
16	0.55	74	40.7	19.8	7.31	21.0	y	990.8
17	0.6	74	44.4	19.3	7.38	22.5	y	1045.2
18	0.65	74	48.1	19.8	7.31	21.3	y	1023.8
19	0.65	74	48.1	19.8	7.39	21.9	y	1149.3
20	0.7	74	51.8	19.6	7.37	22.2	y	1097
21	0.7	74	51.8	19.6	7.37	22.2	y	1059.7
22	0.74	74	54.8	19.3	7.35	22.6	y	1276.7
23	0.65	74	48.1	19.6	7.31	21.6	y	1103.8
24	0.63	74	46.6	19.4	7.38	22.4	y	1191.9
25	0.6	74	44.4	18.7	7.38	23.4	y	1598
26	0.63	74	46.6	18.7	7.34	23.1	y	1038.9
27	0.65	74	48.1	18.8	7.36	23.2	y	1252.7
28	0.65	74	48.1	18.8	7.36	23.2	y	1261.2
29	0.67	74	49.6	18.9	7.38	23.3	y	1024.6
30	0.62	74	45.9	18.6	7.42	24.0	y	1019.2
31		74					y	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013

Oregon DHS - Drinking Water Services – Surface Water Quality Data

System Name: Reedsport ID# 41 00699 Month/Year: September, 2025
 Minimum UVT [%] during month: 4.95 UVT sensor variation from reference sensor %: 2.12

Minimum Validated UVT : {Insert Req'd Value}

Date	Peak Hourly [gpm/unit]	Minimum Intensity [^{mW} /cm ²]	All Lamps On? [Y or N]	Daily Water [gal]	Water outside [gal]	Cumulative % Off-Spec Water Produced (Mo. Sum {B}) ÷ (Mo. Sum {A}) * 100 [%]
1	1020.1	4.95	y	900,000	0	
2	1203.9	4.95	y	1,000,000	0	
3	1032.4	4.95	y	800,000	0	
4	1100	4.95	y	800,000	0	
5	1088.2	4.95	y	800,000	0	
6	992.1	4.95	y	700,000	0	
7	1233.9	4.95	y	700,000	0	
8	1331.4	4.95	y	800,000	0	
9	924.5	4.95	y	800,000	0	
10	993.3	4.95	y	700,000	0	
11	1158.3	4.95	y	600,000	0	
12	959.5	4.95	y	800,000	0	
13	851.5	4.95	y	700,000	0	
14	1176.6	4.95	y	600,000	0	
15	1194.6	4.95	y	800,000	0	
16	990.8	4.95	y	700,000	0	
17	1045.2	4.95	y	600,000	0	
18	1023.8	4.95	y	700,000	0	
19	1149.3	4.95	y	800,000	0	
20	1097	4.95	y	700,000	0	
21	1059.7	4.95	y	600,000	0	
22	1276.7	4.95	y	700,000	0	
23	1103.8	4.95	y	800,000	0	
24	1191.9	4.95	y	800,000	0	
25	1598	4.95	y	700,000	0	
26	1038.9	4.95	y	700,000	0	
27	1252.7	4.95	y	700,000	0	
28	1261.2	4.95	y	700,000	0	
29	1024.6	4.95	y	600,000	0	
30	1019.2	4.95	y	700,000	0	
31		4.95	y		0	
Monthly Cumulative % Off-Spec Water Produced						

rev 1/11 I:\MC\forms\Turbidity Report Form – UV and opt mod.doc

Signature: Mike Woolley Op Cert #: 681921 Date: 10/7/2025

Raw Water Fecal Coliform 6 Month Running Average Report

CITY OF REEDSPORT


PWS ID:4100699

Monthly Report

Raw Water Fecal Coliform Per 100ml

Date	Apr-25	May-25	Jun-25	Jul-25	Aug-25	Sep-25
1	0	0		0		
2			0	2		0
3	0		4.5			0
4					0	0
5		0	0		0	
6		0				
7	0			0	0	
8	0	0		2		0
9			0			14
10	0		0	2		
11					0	0
12		0	2		0	
13		0				
14	0			0	0	
15	0	0		3.6		4.5
16			2			0
17	0		0	0		
18					0	4.5
19		0	0		0	
20		0				
21	0			0	0	
22	0	0		0		0
23			0			11
24	0		0	4.5		
25					0	4.5
26			0		2	
27		0				
28	0	0		4.5	0	
29	0	0				4.5
30			0	2		0
31	0			0		
AVERAGE	0	0	0.653846154	1.471428571	0	0

6 MONTH	AVERAGE ENDING	0.354212454
---------	----------------	-------------

SIGNED: 	10/7/2025
---	-----------