

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Douglas**
 Month/Year: **October, 25**
 WTP : TP - **Clear lake**

System Name: Reedsport		4100699						
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]	
1	0.37	0.40	0.33	0.38	0.80	0.33	0.51	
2	0.33	0.33	0.33	0.33	0.33	0.32	0.40	
3	0.32	0.32	0.34	0.32	0.32	0.33	0.41	
4	0.33	0.30	0.30	0.30	0.31	0.31	0.44	
5	0.32	0.30	0.31	0.31	0.31	0.34	0.46	
6	0.31	0.30	0.31	0.30	0.30	0.33	0.42	
7	0.32	0.27	0.27	0.27	0.29	0.27	0.40	
8	0.89	0.31	0.28	0.28	0.29	0.30	0.46	
9	0.29	0.28	0.62	0.29	0.29	0.45	0.42	
10	0.28	0.29	0.29	0.28	0.32	0.33	0.41	
11	0.28	0.29	0.68	0.29	0.28	0.29	0.41	
12	0.29	0.29	0.29	0.29	0.29	0.29	0.44	
13	0.30	0.29	0.30	0.29	0.30	0.30	0.55	
14	0.30	0.29	0.32	0.30	0.32	0.35	0.49	
15	0.30	0.32	0.30	0.31	0.35	0.30	0.43	
16	0.30	0.34	0.30	0.29	0.30	0.32	0.39	
17	0.31	0.31	0.31	0.32	0.29	0.28	0.43	
18	0.44	0.33	0.68	0.33	0.37	0.33	0.45	
19	0.32	0.32	0.32	0.33	0.33	0.34	0.61	
20	0.33	0.33	0.33	0.34	0.33	0.36	0.46	
21	0.74	0.35	0.48	0.34	0.34	0.36	0.57	
22	0.35	0.35	0.35	0.37	0.34	0.50	0.51	
23	0.35	0.35	0.36	0.36	0.36	0.36	0.44	
24	0.36	0.36	0.43	0.40	0.40	0.44	0.52	
25	0.39	0.33	0.32	0.43	0.49	0.45	0.55	
26	0.47	0.41	0.40	0.39	0.41	0.43	0.49	
27	0.51	0.45	0.43	0.51	0.47	0.47	0.59	
28	0.55	0.94	0.52	0.31	0.29	0.30	0.60	
29	0.28	0.30	0.30	0.30	0.29	0.31	0.40	
30	0.31	0.29	0.30	0.28	0.30	0.29	0.33	
31	0.30	0.64	0.29	0.29	0.29	0.28	0.35	

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 1 NTU? ²	yes	CT's met everyday? (see back)	All Cl ₂ residual at entry point $\geq$ 0.2 mg/l?
All daily turbidity readings $\leq$ 5 NTU?	yes	Yes	Yes
Notes:			
		SIGNATURE: <i>Mike Woolley</i>	11/6/2025
		541-707-0283	681921

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

Disinfection *Giardia* Log

System Name: Reedsport

4100699

Month/Year: October,25

Inactiv:

1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.61	74	45.1	18.2	7.37	24.1	y	943.9
2	0.67	74	49.6	18.3	7.40	24.4	y	1019.2
3	0.65	74	48.1	18.5	7.32	23.3	y	956.4
4	0.63	74	46.6	18.4	7.33	23.5	y	1151.9
5	0.63	74	46.6	18.4	7.33	23.5	y	942.7
6	0.6	74	44.4	18.3	7.34	23.7	y	1142.8
7	0.6	74	44.4	18.4	7.31	23.2	y	1020.7
8	0.59	74	43.7	18.3	7.34	23.6	y	1027.1
9	0.61	74	45.1	18.1	7.36	24.2	y	943.9
10	0.63	74	46.6	18.1	7.31	23.8	y	981.5
11	0.65	74	48.1	18.0	7.33	24.2	y	886.7
12	0.65	74	48.1	18.0	7.33	24.2	y	989.5
13	0.67	74	49.6	17.7	7.35	24.9	y	871
14	0.68	74	50.3	17.5	7.33	25.1	y	1161
15	0.66	74	48.8	17.4	7.31	25.0	y	1073.8
16	0.65	74	48.1	17.2	7.32	25.4	y	985.6
17	0.67	74	49.6	17.3	7.33	25.4	y	842.5
18	0.66	74	48.8	17.2	7.35	25.8	y	1007.6
19	0.66	74	48.8	17.2	7.35	25.8	y	906.2
20	0.65	74	48.1	17.1	7.37	26.1	y	898.2
21	0.7	74	51.8	17.1	7.35	26.0	y	1086.8
22	0.67	74	49.6	17.1	7.35	26.0	y	868.4
23	0.68	74	50.3	16.8	7.37	26.7	y	1119.4
24	0.66	74	48.8	17.5	7.36	25.3	y	876.2
25	0.71	74	52.5	16.9	7.36	26.5	y	911.5
26	0.71	74	52.5	16.9	7.36	26.5	y	1110.1
27	0.75	74	55.5	16.2	7.36	27.9	y	950.5
28	0.68	74	50.3	16.1	7.30	27.3	y	876.2
29	0.58	74	42.9	16.1	7.30	27.0	y	998.6
30	0.64	74	47.4	16.9	7.30	25.7	y	899.2
31	0.69	74	51.1	16.3	7.34	27.3	y	1218.8

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.


Revised October 2013

Oregon DHS - Drinking Water Services – Surface Water Quality Data

System Name: Reedsport ID# 41 00699 Month/Year: October,25
 Minimum UVT [%] during month: 4.95 ity sensor variation from reference sensor %: 2.77
 Minimum Validated UVT : {Insert Req'd Value}

Date	Peak Hourly [gpm/unit]	Minimum Intensity [^{mW} /cm ²]	All Lamps On? [Y or N]	Daily Water [gal]	Water outside [gal]	Cumulative % Off-Spec Water Produced (Mo. Sum (B)) ÷ (Mo. Sum (A)) * 100 [%]
1	943.9	4.95	y	700,000	0	
2	1019.2	4.95	y	600,000	0	
3	956.4	4.95	y	600,000	0	
4	1151.9	4.95	y	600,000	0	
5	942.7	4.95	y	600,000	0	
6	1142.8	4.95	y	700,000	0	
7	1020.7	4.95	y	600,000	0	
8	1027.1	4.95	y	700,000	0	
9	943.9	4.95	y	700,000	0	
10	981.5	4.95	y	700,000	0	
11	886.7	4.95	y	600,000	0	
12	989.5	4.95	y	500,000	0	
13	871	4.95	y	600,000	0	
14	1161	4.95	y	700,000	0	
15	1073.8	4.95	y	600,000	0	
16	985.6	4.95	y	500,000	0	
17	842.5	4.95	y	700,000	0	
18	1007.6	4.95	y	600,000	0	
19	906.2	4.95	y	600,000	0	
20	898.2	4.95	y	600,000	0	
21	1086.8	4.95	y	700,000	0	
22	868.4	4.95	y	600,000	0	
23	1119.4	4.95	y	500,000	0	
24	876.2	4.95	y	700,000	0	
25	911.5	4.95	y	600,000	0	
26	1110.1	4.95	y	600,000	0	
27	950.5	4.95	y	600,000	0	
28	876.2	4.95	y	600,000	0	
29	998.6	4.95	y	500,000	0	
30	899.4	4.95	y	600,000	0	
31	1218.8	4.95	y	600,000	0	
Monthly Cumulative % Off-Spec Water Produced						

rev 1/11 I:\MC\forms\Turbidity Report Form – UV and opt mod.doc

Signature:  Op Cert #: 681921 Date: 11/6/2025


Raw Water Fecal Coliform 6 Month Running Average Report

CITY OF REEDSPORT

PWS ID:4100699

Monthly Report

Raw Water Fecal Coliform Per 100ml

Date	May-25	Jun-25	Jul-25	Aug-25	Sep-25	Oct-25
1	0		0			
2		0	2		0	
3		4.5			0	0
4				0	0	
5	0	0		0		
6	0					0
7			0	0		0
8	0		2		0	
9		0			14	0
10		0	2			
11				0	0	
12	0	2		0		
13	0					0
14			0	0		0
15	0		3.6		4.5	
16		2			0	0
17		0	0			
18				0	4.5	
19	0	0		0		
20	0					0
21			0	0		4.5
22	0		0		0	
23		0			11	2
24		0	4.5			
25				0	4.5	
26		0		2		
27	0					0
28	0		4.5	0		2
29	0				4.5	
30		0	2		0	0
31			0			
AVERAGE	0	0.653846154	1.471428571	0	0	0
6 MONTH AVERAGE ENDING					0.354212454	
SIGNED: 				11/6/2025		