

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Douglas**
 Month/Year: **November,25**

System Name:		Reedsport		4100699		WTP : TP -		Clear lake
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]	
1	0.29	0.28	0.28	0.32	0.32	0.30	0.36	
2	0.31	0.30	0.30	0.29	0.30	0.33	0.41	
3	0.28	0.29	0.29	0.30	0.29	0.29	0.36	
4	0.31	0.32	0.81	0.29	0.30	0.51	0.37	
5	0.29	0.28	0.31	0.34	0.54	0.50	0.43	
6	0.43	0.44	0.42	0.39	0.41	0.42	0.56	
7	0.39	0.38	0.39	0.39	0.29	0.28	0.46	
8	0.38	0.35	0.35	0.49	0.36	0.38	0.50	
9	0.35	0.34	0.34	0.34	0.34	0.36	0.38	
10	0.34	0.33	0.33	0.34	0.33	0.33	0.52	
11	0.33	0.33	0.33	0.33	0.31	0.32	0.41	
12	0.33	0.32	0.31	0.29	0.29	0.30	0.37	
13	0.30	0.28	0.28	0.29	0.29	0.29	0.35	
14	0.29	0.29	0.28	0.39	0.40	0.40	0.43	
15	0.29	0.28	0.30	0.32	0.28	0.29	0.36	
16	0.29	0.32	0.27	0.27	0.28	0.67	0.39	
17	0.27	0.27	0.27	0.27	0.27	0.29	0.37	
18	0.29	0.27	0.27	0.28	0.30	0.27	0.47	
19	0.27	0.29	0.27	0.27	0.26	0.28	0.44	
20	0.28	0.27	0.26	0.27	0.71	0.26	0.45	
21	0.27	0.27	0.26	0.75	0.28	0.29	0.46	
22	0.25	0.23	0.25	0.22	0.27	0.27	0.48	
23	0.28	0.25	0.29	0.31	0.25	0.26	0.43	
24	0.29	0.25	0.25	0.26	0.33	0.27	0.47	
25	0.30	0.26	0.26	0.31	0.26	0.26	0.41	
26	0.34	0.26	0.26	0.25	0.26	0.25	0.46	
27	0.29	0.27	0.25	0.27	0.29	0.29	0.51	
28	0.27	0.28	0.28	0.31	0.27	0.27	0.42	
29	0.27	0.27	0.27	0.27	0.33	0.49	0.45	
30	0.27	0.26	0.31	0.69	0.27	0.55	0.44	
31								

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 1 NTU? ²	yes	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All daily turbidity readings $\leq$ 5 NTU?	yes	Yes	Yes
Notes:			
		SIGNATURE:	12/9/2025
		541-707-0283	681921

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form
WTP- :
Disinfection *Giardia* Log
System Name: Reedsport
4100699
Month/Year: November,25
Inactiv:
1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.7	74	51.8	16.3	7.33	27.3	y	885.1
2	0.7	74	51.8	16.3	7.33	27.3	y	899.7
3	0.71	74	52.5	16.2	7.37	27.9	y	897
4	0.69	74	51.1	15.7	7.33	28.4	y	1189.4
5	0.71	74	52.5	16.0	7.34	28.0	y	1358.7
6	0.7	74	51.8	16.2	7.28	27.0	y	1188.4
7	0.67	74	49.6	15.5	7.31	28.5	y	1031.1
8	0.68	74	50.3	15.7	7.31	28.1	y	942.6
9	0.68	74	50.3	15.7	7.31	28.1	y	1084.1
10	0.68	74	50.3	15.9	7.31	27.7	y	1157.1
11	0.65	74	48.1	15.7	7.30	27.9	y	919.2
12	0.64	74	47.4	15.8	7.31	27.8	y	1122.9
13	0.68	74	50.3	15.4	7.30	28.6	y	1400.3
14	0.49	74	36.3	15.7	7.37	28.1	y	1114.2
15	0.53	74	39.2	15.6	7.39	28.7	y	1053.1
16	0.53	74	39.2	15.6	7.39	28.7	y	937.4
17	0.57	74	42.2	15.4	7.40	29.3	y	1258.6
18	0.56	74	41.4	14.8	7.37	30.1	y	1196.9
19	0.63	74	46.6	14.7	7.44	31.4	y	1050.4
20	0.61	74	45.1	14.7	7.51	32.1	y	1433.9
21	0.64	74	47.4	14.5	7.61	33.9	y	865.9
22	0.66	74	48.8	14.3	7.59	34.2	y	932.5
23	0.66	74	48.8	14.3	7.59	34.2	y	1009.9
24	0.68	74	50.3	14.0	7.56	34.6	y	969.3
25	0.67	74	49.6	14.2	7.54	33.8	y	1842.3
26	0.62	74	45.9	14.2	7.52	33.4	y	1057.1
27	0.64	74	47.4	14.9	7.40	30.5	y	863.4
28	0.63	74	46.6	14.2	7.47	32.8	y	949.1
29	0.64	74	47.4	13.9	7.52	34.1	y	828.3
30	0.64	74	47.4	13.9	7.52	34.1	y	1050.6
31		74					y	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013

Oregon DHS - Drinking Water Services – Surface Water Quality Data

System Name: Reedsport ID# 41 00699 Month/Year: November,25
 Minimum UVT [%] during month: 4.95 ity sensor variation from reference sensor %: 1.83
 Minimum Validated UVT : {Insert Req'd Value}

Date	Peak Hourly	Minimum Intensity	All Lamps On?	Daily Water	Water outside	Cumulative % Off-Spec Water Produced
	[gpm/unit]	[^{mW} /cm ²]	[Y or N]	[gal]	[gal]	(Mo. Sum {B}) ÷ (Mo. Sum {A}) * 100 [%]
1	885.3	4.95	y	600,000	0	
2	899.7	4.95	y	700,000	0	
3	897	4.95	y	700,000	0	
4	1189.4	4.95	y	600,000	0	
5	1358.7	4.95	y	500,000	0	
6	1188.4	4.95	y	500,000	0	
7	1031.7	4.95	y	700,000	0	
8	942.6	4.95	y	600,000	0	
9	1084.1	4.95	y	600,000	0	
10	1157.1	4.95	y	600,000	0	
11	919.2	4.95	y	600,000	0	
12	1122.9	4.95	y	600,000	0	
13	1400.3	4.95	y	600,000	0	
14	1114.2	4.95	y	700,000	0	
15	1053.1	4.95	y	600,000	0	
16	937.4	4.95	y	600,000	0	
17	1258.6	4.95	y	600,000	0	
18	1196.9	4.95	y	600,000	0	
19	1050.4	4.95	y	600,000	0	
20	1433.9	4.95	y	600,000	0	
21	865.9	4.95	y	600,000	0	
22	932.5	4.95	y	600,000	0	
23	1009.9	4.95	y	600,000	0	
24	969.3	4.95	y	600,000	0	
25	1842.3	4.95	y	500,000	0	
26	1057.1	4.95	y	600,000	0	
27	863.4	4.95	y	600,000	0	
28	949.1	4.95	y	600,000	0	
29	928.3	4.95	y	700,000	0	
30	1050.6	4.95	y	700,000	0	
31		4.95	y		0	
Monthly Cumulative % Off-Spec Water Produced						

rev 1/11 I:\MC\forms\Turbidity Report Form – UV and opt mod.doc

Signature: Michael Wootley Op Cert #: 681921 Date: 12/9/2025

Raw Water Fecal Coliform 6 Month Running Average Report

CITY OF REEDSPORT

PWS ID:4100699

Monthly Report

Raw Water Fecal Coliform Per 100ml

Date	Jun-25	Jul-25	Aug-25	Sep-25	Oct-25	Nov-25
1		0				
2	0	2		0		
3	4.5			0	0	2
4			0	0		0
5	0		0			
6					0	6.8
7		0	0		0	
8		2		0		
9	0			14	0	
10	0	2				4.5
11			0	0		2
12	2		0			
13					0	11
14		0	0		0	
15		3.6		4.5		
16	2			0	0	
17	0	0				2
18			0	4.5		4.5
19	0		0			
20					0	1.8
21		0	0		4.5	
22		0		0		
23	0			11	2	2
24	0	4.5				0
25			0	4.5		2
26	0		2			
27					0	
28		4.5	0		2	
29				4.5		
30	0	2		0	0	
31		0				
AVERAGE	0.653846154	1.471428571	0.166666667	3.071428571	0.653846154	3.216666667
6 MONTH AVERAGE ENDING					1.538980464	
SIGNED: <i>Michael Woolley</i>				12/9/2025		